

LHASA, China

WMO: 555910

Lat: 29.6586N

Lon: 91.1353E

Elev: 11975

StdP: 9.36

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.1	19.3	-24.1	2.3	43.3	-20.3	2.8	41.7	17.5	47.8	13.9	46.0	3.4	90	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	19.3	78.1	51.1	75.6	51.1	73.5	50.9	55.6	69.3	54.7	68.2	54.0	67.2	5.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
51.3	88.8	59.0	50.4	85.8	58.5	49.7	83.4	58.3	29.4	69.7	28.7	68.4	28.1	67.7	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	10.8	9.3	DB	11.8	81.2	2.9	2.4	9.7	83.0	8.0	84.4	6.4	85.8	4.4	87.5	(4)
(5)			WB	7.4	58.5	1.7	3.4	6.1	60.9	5.2	62.9	4.2	64.8	3.0	67.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	33.3	37.6	43.1	49.0	56.7	63.0	62.7	61.4	58.8	50.9	41.7	35.3	(6)	
	DBStd	11.54	4.96	5.14	4.85	4.78	5.60	4.83	3.83	3.22	3.50	5.07	3.92	4.64	(7)	
	HDD50	1927	518	349	221	74	9	0	0	0	0	51	249	456	(8)	
	HDD65	5721	983	768	679	480	262	93	94	119	187	437	698	921	(9)	
	CDD50	1750	0	0	7	44	217	391	393	353	264	80	1	0	(10)	
	CDD65	68	0	0	0	0	5	34	22	6	1	0	0	0	(11)	
	CDH74	400	0	0	0	1	45	207	115	27	5	0	0	0	(12)	
	CDH80	21	0	0	0	0	1	13	7	0	0	0	0	0	(13)	
(14) Wind	WSAvg	4.0	4.0	4.5	4.7	4.6	4.7	4.6	3.9	3.6	3.5	3.6	3.3	3.3	(14)	
(15) Precipitation	PrecAvg	17.3	0.0	0.0	0.1	0.3	1.1	3.1	4.8	5.1	2.4	0.4	0.0	0.0	(15)	
	PrecMax	31.3	0.2	0.2	0.7	1.1	3.1	7.6	8.2	11.1	5.4	1.5	0.9	0.5	(16)	
	PrecMin	9.0	0.0	0.0	0.0	0.0	0.0	0.2	1.4	1.1	0.6	0.0	0.0	0.0	(17)	
	PrecStd	4.4	0.0	0.0	0.2	0.2	0.8	1.7	1.7	2.0	1.0	0.4	0.1	0.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.2	60.5	67.4	71.7	78.6	81.8	80.9	76.7	74.6	71.1	62.7	58.3	(19)	
		MCWB	33.9	34.9	38.4	43.0	48.0	51.1	52.2	53.4	51.1	45.6	37.1	34.1	(20)	
	2%	DB	52.8	56.3	61.7	66.9	74.7	78.9	77.1	74.3	72.1	68.0	59.0	53.8	(21)	
		MCWB	31.4	32.9	36.2	40.5	46.7	50.7	52.6	52.8	50.4	44.8	35.8	32.0	(22)	
	5%	DB	48.6	53.2	58.1	63.8	71.5	76.3	74.4	72.3	69.8	65.4	56.1	50.4	(23)	
		MCWB	29.3	31.5	34.7	39.1	45.5	50.7	52.9	52.5	50.1	43.7	34.5	30.5	(24)	
	10%	DB	45.1	49.9	55.1	61.0	68.4	73.8	71.9	70.2	67.7	62.6	53.2	46.9	(25)	
		MCWB	27.6	30.2	33.4	38.3	44.6	50.5	52.7	52.4	49.7	42.2	33.3	29.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.0	35.8	39.6	44.6	52.5	55.9	57.3	56.7	54.4	49.4	39.8	34.7	(27)	
		MCDB	57.7	58.0	63.1	64.0	70.9	71.2	70.7	69.9	68.0	64.2	56.8	56.4	(28)	
	2%	WB	31.9	33.4	37.2	42.7	49.5	54.5	55.8	55.3	53.1	47.6	37.1	32.3	(29)	
		MCDB	51.4	54.3	58.0	61.8	67.9	70.0	69.3	68.7	66.1	62.5	55.0	52.3	(30)	
	5%	WB	29.6	31.9	35.7	41.2	47.8	53.5	54.9	54.5	52.2	46.2	35.5	30.7	(31)	
		MCDB	47.7	51.9	54.8	59.2	65.7	68.9	68.2	67.3	64.6	60.0	53.3	49.4	(32)	
	10%	WB	27.8	30.5	34.3	39.7	46.5	52.6	54.2	53.7	51.3	44.8	34.0	29.2	(33)	
		MCDB	44.2	48.9	52.5	56.4	63.6	67.4	67.2	66.1	63.3	58.0	51.4	46.4	(34)	
(35) Mean Daily Temperature Range	MDBR		24.5	23.0	21.9	21.2	20.3	19.3	17.9	17.4	18.6	23.1	25.8	26.1	(35)	
	5% DB	MCDBR	30.3	28.1	27.0	25.5	23.2	21.4	20.6	19.9	21.0	25.6	29.4	30.1	(36)	
		MCWBR	16.0	14.2	11.6	9.0	6.7	5.6	5.3	5.1	5.6	8.2	12.9	15.2	(37)	
	5% WB	MCDBR	29.4	26.9	24.9	22.6	21.2	18.9	17.8	17.4	17.8	21.2	27.8	29.3	(38)	
		MCWBR	15.8	13.8	10.7	8.2	6.7	6.0	5.8	5.6	5.7	7.0	12.5	15.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.193	0.215	0.263	0.315	0.314	0.305	0.305	0.302	0.283	0.243	0.202	0.184	(40)	
	taud		2.679	2.608	2.469	2.337	2.424	2.535	2.577	2.578	2.597	2.676	2.732	2.769	(41)	
	Ebn at Noon		345	342	327	310	308	309	309	310	316	326	339	346	(42)	
	Edh at Noon		23	27	34	40	37	33	32	31	30	25	22	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		1369	1612	1837	1953	2039	2072	1832	1757	1704	1666	1489	1342	(44)	
	RadStd		92	102	121	118	100	111	115	106	95	97	82	54	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.01	+1.01	-6.17	N/A	N/A	-0.67	-238	-457	+270	+32	(46)
(47)	Regional (1 neighbor)	+0.63	N/A	-6.16	N/A	N/A	N/A	-238	-457	+270	+32	(47)

Nomenclature: See separate page