

TINGRI, China

WMO: 556640

Lat: 28.6542N

Lon: 87.1202E

Elev: 14108

StdP: 8.60

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.4	3.4	-32.1	1.5	25.2	-28.6	1.9	24.1	34.8	35.3	31.1	35.4	0.7	40	0.684

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	69.3	45.8	67.4	45.7	65.6	45.5	49.8	62.4	48.9	61.5	48.2	60.7	8.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
45.2	76.7	53.7	44.4	74.3	52.8	43.6	72.0	52.5	26.0	62.7	25.4	61.6	24.8	61.0	59.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.7	22.3	18.9	-6.1	73.4	3.6	1.8	-8.7	74.6	-10.8	75.7	-12.8	76.7	-15.4	78.0		
			-8.2	51.7	2.9	1.9	-10.2	53.1	-11.9	54.2	-13.5	55.2	-15.6	56.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.0	21.2	24.1	30.2	37.3	45.8	54.3	55.4	53.9	50.9	39.8	30.2	24.2
	DBStd	13.08	5.36	5.06	4.61	4.35	4.45	3.22	2.99	2.85	3.00	5.53	4.11	5.54
	HDD50	4502	893	725	613	381	142	6	2	5	25	316	593	801
	HDD65	9486	1358	1145	1078	831	595	322	298	345	424	781	1043	1266
	CDD50	491	0	0	0	0	12	133	169	125	51	1	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.3	5.8	7.1	7.6	7.4	6.5	5.0	4.0	3.6	3.7	4.3	4.2	4.4
Precipitation	PrecAvg	13.6	0.1	0.1	0.1	0.2	0.6	1.4	4.7	4.8	1.4	0.2	0.0	0.0
	PrecMax	18.5	0.3	0.2	0.2	0.6	1.4	3.7	9.6	8.3	4.1	0.7	0.7	0.2
	PrecMin	8.1	0.0	0.0	0.0	0.0	0.1	0.4	2.4	2.1	0.4	0.0	0.0	0.0
	PrecStd	2.9	0.1	0.0	0.0	0.1	0.4	0.8	1.8	1.7	0.9	0.2	0.1	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	51.4	57.3	61.2	68.6	72.0	71.9	68.4	66.9	62.1	54.5	51.8
		MCWB	29.4	30.3	33.8	35.9	41.4	45.5	46.9	47.7	44.9	39.5	32.4	30.2
	2%	DB	44.4	46.4	52.0	57.6	65.2	69.6	69.2	66.2	64.4	59.4	51.2	47.5
		MCWB	26.5	27.8	31.0	34.7	40.7	45.1	47.1	47.5	43.9	38.6	30.9	28.5
	5%	DB	40.4	42.7	48.1	54.5	62.1	67.7	67.0	64.4	62.6	56.9	48.5	44.0
		MCWB	24.5	25.8	29.1	33.5	39.4	45.1	46.8	47.3	43.9	37.3	29.8	26.9
	10%	DB	36.7	39.5	45.1	51.5	59.4	65.7	64.6	62.4	60.8	54.1	45.5	40.5
		MCWB	22.7	24.2	27.9	32.4	38.0	44.8	46.9	47.1	43.6	35.7	28.4	25.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.6	31.2	34.7	39.4	46.2	50.3	50.8	51.6	49.5	44.3	36.1	32.8
		MCDB	47.2	48.5	52.6	54.8	61.2	66.0	64.1	63.5	61.4	56.3	49.3	47.2
	2%	WB	27.3	28.4	32.2	36.6	43.8	48.9	49.6	49.8	47.5	41.4	32.7	29.6
		MCDB	42.9	44.7	49.3	52.9	59.6	64.2	62.1	61.3	59.3	55.4	47.6	45.2
	5%	WB	25.0	26.3	30.2	34.9	41.7	47.8	48.9	48.8	46.4	39.5	30.7	27.4
		MCDB	39.6	41.7	46.5	51.4	57.5	62.8	61.4	60.3	58.1	53.1	46.1	43.2
	10%	WB	22.8	24.5	28.3	33.3	39.9	46.8	48.2	48.0	45.3	37.5	28.9	25.2
		MCDB	36.1	38.9	44.0	49.6	55.7	61.5	60.7	59.3	57.0	50.8	44.5	40.0
Mean Daily Temperature Range	5% DB	MDBR	32.0	30.6	29.4	28.1	26.4	23.9	18.5	17.5	21.4	28.6	32.9	34.4
		MCDBR	37.4	36.0	34.2	32.2	30.0	26.8	22.6	20.5	23.9	29.8	36.8	38.5
		MCWBR	24.0	22.1	18.9	15.1	11.7	9.0	6.6	6.4	7.8	12.2	20.3	23.7
	5% WB	MCDBR	36.1	33.9	32.2	29.1	26.0	21.1	17.8	17.2	19.2	26.0	34.3	38.0
	MCWBR	24.0	21.6	19.1	15.3	11.8	8.1	6.8	6.7	7.7	11.6	20.4	24.5	
Clear-Sky Solar Irradiance	taub	0.173	0.190	0.230	0.280	0.283	0.283	0.286	0.280	0.258	0.209	0.177	0.165	
	taud	2.711	2.622	2.501	2.376	2.439	2.506	2.544	2.566	2.592	2.704	2.761	2.802	
	Ebn at Noon	356	353	340	322	318	316	315	318	325	341	352	357	
	Edh at Noon	23	27	33	39	37	34	33	32	30	25	21	20	
All-Sky Solar Radiation	RadAvg	1321	1535	1847	2030	2141	2058	1781	1690	1755	1766	1495	1325	
	RadStd	101	140	96	148	138	141	114	79	97	100	76	78	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.61	N/A	N/A	N/A	N/A	N/A	N/A	-324	+92	N/A
(47)	Regional (1 neighbor)	+0.61	N/A	N/A	N/A	N/A	N/A	N/A	-292	+131	N/A

Nomenclature: See separate page