

LHUNZE, China

WMO: 556960

Lat: 28.4135N

Lon: 92.4600E

Elev: 3861

StdP: 62.76

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.9	-12.4	-28.1	0.5	1.2	-25.5	0.6	1.3	11.5	5.5	10.4	5.5	0.5	340	0.631

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.5	21.7	9.6	20.7	9.5	19.8	9.4	11.6	18.3	11.1	17.6	10.7	16.9	3.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.5	12.0	12.9	9.0	11.6	12.8	8.6	11.3	12.7	46.3	18.5	44.7	17.7	43.4	17.1	14.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 9.1	8.0	6.9		-17.0	24.2	1.8	0.9	-18.3	24.9	-19.4	25.5	-20.4	26.0	-21.7	26.7	
(5)			DB	-18.6	12.4	2.5	0.7	-20.4	12.9	-21.9	13.3	-23.3	13.7	-25.2	14.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-3.0	-0.9	2.2	5.8	10.4	14.3	14.3	13.8	12.4	7.3	2.1	-1.1	
	DBStd	6.61	2.50	2.36	2.25	2.16	2.51	1.72	1.49	1.59	1.64	2.94	2.18	2.56	
	HDD10.0	1778	404	304	241	127	26	1	0	1	2	93	237	343	
	HDD18.3	4317	662	537	499	377	246	122	124	141	178	343	487	602	
	CDD10.0	502	0	0	0	1	38	129	135	118	73	8	0	0	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH23.3	3	0	0	0	0	0	2	1	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	2.5	2.3	2.7	2.9	2.9	3.0	2.9	2.4	2.3	2.3	2.4	2.0	2.0	
Precipitation	PrecAvg	269	0	1	2	6	14	42	79	78	40	6	2	1	
	PrecMax	415	1	6	11	20	32	119	162	149	87	22	15	12	
	PrecMin	121	0	0	0	0	2	5	24	21	13	0	0	0	
	PrecStd	62	0	1	2	5	8	25	30	29	18	7	4	2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	13.7	17.1	19.0	21.2	23.2	22.9	22.1	21.1	19.2	16.1	13.6	
		MCWB	0.7	1.4	3.4	6.0	7.8	9.5	10.5	10.4	9.4	6.5	2.6	1.1	
	2%	DB	9.7	11.2	13.9	16.2	19.7	21.8	21.2	20.7	19.7	17.6	13.6	10.9	
		MCWB	-1.0	0.2	2.1	4.2	7.2	9.3	10.3	10.3	8.9	6.0	1.7	-0.3	
	5%	DB	7.2	9.2	11.8	14.5	18.3	20.8	20.0	19.6	18.6	16.1	11.8	8.8	
		MCWB	-2.0	-0.6	1.1	3.3	6.5	9.3	10.4	10.1	8.6	5.2	1.0	-1.1	
	10%	DB	5.2	7.2	10.0	13.0	16.8	19.7	18.9	18.4	17.6	14.6	10.0	6.7	
		MCWB	-2.9	-1.5	0.4	2.7	6.1	9.1	10.2	9.9	8.4	4.5	0.3	-2.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.3	2.4	4.5	7.7	10.3	12.1	12.2	12.1	10.7	8.3	3.7	1.6
			MCDB	11.0	11.4	14.7	16.0	18.3	19.7	18.8	19.0	17.8	15.8	12.7	11.6
		2%	WB	-0.5	0.9	3.0	5.5	8.8	11.2	11.6	11.4	10.1	7.5	2.5	0.1
			MCDB	8.4	9.6	11.8	13.3	16.5	18.4	17.9	17.9	16.8	14.9	11.7	9.9
5%		WB	-1.7	-0.3	1.8	4.4	7.9	10.6	11.2	10.9	9.6	6.7	1.6	-0.8	
		MCDB	6.5	8.1	10.0	12.0	15.4	17.6	17.4	17.2	16.0	13.6	10.4	8.1	
10%		WB	-2.7	-1.3	0.8	3.5	7.1	10.1	10.7	10.5	9.1	6.0	0.7	-1.8	
		MCDB	4.8	6.5	8.7	10.9	14.5	16.9	16.7	16.4	15.3	12.2	8.8	6.2	
Mean Daily Temperature Range		5% DB	MDBR	18.7	17.7	16.4	14.5	12.7	11.5	9.8	10.1	11.5	15.5	18.7	18.8
			MCDBR	21.9	21.2	19.8	17.2	14.3	13.0	11.5	11.8	13.0	16.9	21.2	21.4
			MCWBR	12.2	10.9	8.9	6.4	4.0	3.2	2.9	3.2	3.7	5.8	9.7	11.0
		5% WB	MCDBR	21.0	19.8	17.8	15.2	12.3	10.7	9.7	10.0	10.7	13.1	19.3	20.7
	MCWBR		12.0	10.5	8.7	6.0	4.0	3.3	2.9	2.9	3.2	4.6	9.0	10.8	
	Clear-Sky Solar Irradiance	taub		0.225	0.263	0.332	0.351	0.315	0.302	0.298	0.300	0.285	0.252	0.229	0.211
taud		2.532	2.421	2.206	2.216	2.425	2.552	2.591	2.569	2.579	2.638	2.601	2.631		
Ebn at Noon		1045	1019	955	942	971	978	981	982	995	1022	1034	1053		
Edh at Noon		86	106	141	144	117	103	99	100	96	84	80	74		
All-Sky Solar Radiation	RadAvg		3.97	4.43	4.89	5.22	5.57	5.37	4.91	4.81	4.65	4.83	4.36	3.95	
	RadStd		0.22	0.26	0.32	0.30	0.28	0.29	0.29	0.32	0.26	0.31	0.33	0.23	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	-0.57	-3.40	+0.34	N/A	+0.44	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		+0.35	N/A	-3.42	N/A	N/A	N/A	-132	-254	+150	+18

Nomenclature: See separate page