

PAGRI, China

WMO: 557730

Lat: 27.7211N

Lon: 89.1539E

Elev: 14108

StdP: 8.60

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.4	0.6	-24.6	2.4	22.9	-18.9	3.3	23.0	37.3	25.9	31.3	28.3	0.8	180	0.845

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	56.4	46.0	54.9	45.7	53.6	45.2	48.2	54.2	47.4	53.1	46.6	52.0	15.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
45.5	77.7	51.5	44.8	75.4	50.5	44.1	73.4	49.7	24.8	54.6	24.2	53.4	23.7	52.3	52.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.3	22.9	20.6	-8.2	60.8	4.0	2.7	-11.1	62.8	-13.5	64.4	-15.7	65.9	-18.6	67.9		
			-9.2	50.5	3.8	1.1	-11.9	51.3	-14.1	52.0	-16.3	52.6	-19.0	53.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.2	18.5	20.7	27.2	33.7	39.6	46.1	47.8	47.2	44.2	35.2	27.7	22.0
	DBStd	11.33	6.42	5.72	5.24	4.44	3.86	2.71	1.82	1.85	2.69	5.29	4.80	6.54
	HDD50	5762	977	820	708	490	321	119	71	88	174	459	668	867
	HDD65	11233	1442	1240	1173	940	786	568	534	552	624	924	1118	1332
	CDD50	4	0	0	0	0	0	1	2	1	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.6	7.2	7.3	7.0	7.3	8.8	9.5	8.2	7.6	7.5	7.7	6.4	6.7
Precipitation	PrecAvg	16.3	0.2	0.3	0.7	1.0	1.0	2.2	4.2	3.9	2.1	0.8	0.1	0.0
	PrecMax	20.7	1.1	1.4	1.5	1.9	2.3	4.7	8.0	6.1	3.9	6.4	0.6	0.4
	PrecMin	11.5	0.0	0.0	0.1	0.3	0.3	0.5	2.3	2.0	0.8	0.0	0.0	0.0
	PrecStd	2.2	0.2	0.3	0.4	0.4	0.4	0.9	1.3	1.1	0.7	1.3	0.1	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.9	48.3	50.5	51.8	54.9	58.0	58.5	57.8	56.0	52.0	51.4	51.3
		MCWB	29.4	29.9	33.4	36.7	41.5	45.5	47.9	48.1	45.2	39.8	31.2	30.5
	2%	DB	43.0	42.2	45.5	48.5	52.2	55.5	56.1	55.7	53.8	49.5	46.4	45.6
		MCWB	26.5	26.8	31.2	35.5	40.2	45.1	47.4	47.2	44.7	37.7	29.8	28.0
	5%	DB	38.0	38.0	41.7	45.8	50.0	53.7	54.5	54.2	52.1	47.3	43.0	41.0
		MCWB	24.1	25.3	29.7	34.2	39.4	44.9	46.9	46.7	44.0	36.6	29.2	25.9
	10%	DB	33.2	34.2	38.1	43.3	47.8	52.1	53.0	52.7	50.5	45.1	39.8	36.8
		MCWB	21.5	23.6	28.4	33.2	38.5	44.3	46.5	46.1	43.3	35.7	27.9	23.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.4	30.9	36.6	40.0	44.1	48.0	49.5	49.5	47.3	42.3	34.4	31.3
		MCDB	48.5	45.2	45.4	48.8	51.3	54.4	55.9	55.7	53.7	48.9	44.4	47.5
	2%	WB	27.1	28.2	33.1	37.6	42.7	46.8	48.4	48.2	45.8	40.7	32.1	28.5
		MCDB	41.4	39.3	41.9	45.7	49.4	52.9	54.4	54.1	52.0	47.0	41.9	44.4
	5%	WB	24.3	26.0	30.8	35.7	41.2	46.0	47.5	47.3	44.9	39.3	30.5	26.4
		MCDB	36.7	36.1	39.2	43.2	47.3	51.8	53.1	52.8	50.6	44.6	40.1	39.7
	10%	WB	21.9	24.0	29.0	34.1	39.8	45.1	46.8	46.5	43.9	37.7	28.8	24.2
		MCDB	32.3	32.9	36.7	41.2	45.8	50.5	52.0	51.6	49.1	42.4	37.8	35.9
Mean Daily Temperature Range	5% DB	MDBR	29.2	25.9	21.7	18.4	15.7	12.8	11.3	12.0	13.6	19.8	26.4	30.2
		MCDBR	35.7	32.1	27.1	22.2	19.1	15.1	14.2	14.7	16.1	21.5	31.3	35.5
		MCWBR	22.2	19.5	14.8	11.2	9.3	7.2	7.6	8.2	8.7	11.6	17.5	20.7
	5% WB	MCDBR	34.2	30.0	23.6	20.2	15.7	12.6	12.3	13.1	14.2	16.3	26.9	34.3
		MCWBR	22.0	19.1	13.9	11.1	8.2	6.6	7.0	7.7	8.0	9.3	16.4	21.0
Clear-Sky Solar Irradiance	taub	0.218	0.249	0.303	0.345	0.321	0.305	0.290	0.287	0.281	0.263	0.257	0.221	
	taud	2.529	2.443	2.294	2.212	2.375	2.489	2.577	2.585	2.553	2.554	2.476	2.563	
	Ebn at Noon	335	329	313	301	307	309	314	316	317	320	316	330	
	Edh at Noon	28	33	41	46	39	35	32	31	31	29	29	25	
All-Sky Solar Radiation	RadAvg	1224	1361	1498	1594	1589	1474	1382	1383	1327	1454	1317	1217	
	RadStd	106	109	80	114	108	89	107	95	80	74	106	87	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.56	N/A	-5.17	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	+0.59	N/A	-5.17	N/A	N/A	N/A	N/A	-173	+11	N/A	

Nomenclature: See separate page