

PAGRI, China

WMO: 557730

Lat: 27.7211N

Lon: 89.1539E

Elev: 4300

StdP: 59.27

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.7	-17.4	-31.4	0.3	-5.1	-28.3	0.5	-5.0	16.7	-3.4	14.0	-2.1	0.4	180	0.845

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.3	(c) 13.6	(d) 7.8	(e) 12.7	(f) 7.6	(g) 12.0	(h) 7.3	(i) 9.0	(j) 12.3	(k) 8.6	(l) 11.7	(m) 8.1	(n) 11.1	(o) 6.8	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.5	11.1	10.8	7.1	10.8	10.3	6.7	10.5	9.9	39.9	12.6	38.5	11.9	37.3	11.3	11.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 11.7	(b) 10.2	(c) 9.2	(d) DB	(e) -22.3	(f) 16.0	(g) 2.2	(h) 1.5	(i) -24.0	(j) 17.1	(k) -25.3	(l) 18.0	(m) -26.5	(n) 18.8	(o) -28.1	(p) 19.9	(q) 11.9
(a) 11.7	(b) 10.2	(c) 9.2	(d) WB	(e) -22.9	(f) 10.3	(g) 2.1	(h) 0.6	(i) -24.4	(j) 10.7	(k) -25.6	(l) 11.1	(m) -26.8	(n) 11.4	(o) -28.3	(p) 11.9	(q) 11.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.2	-7.5	-6.3	-2.7	0.9	4.2	7.8	8.8	8.4	6.8	1.8	-2.4	-5.5		
	DBStd	6.30	3.57	3.18	2.91	2.47	2.15	1.51	1.01	1.03	1.49	2.94	2.66	3.64		
	HDD10.0	3201	543	456	393	272	178	66	39	49	97	255	371	482		
	HDD18.3	6241	801	689	652	522	437	316	297	307	347	513	621	740		
	CDD10.0	2	0	0	0	0	0	1	1	1	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	3.4	3.2	3.3	3.1	3.3	4.0	4.3	3.7	3.4	3.4	3.4	2.9	3.0		
(15) Precipitation	PrecAvg	415	4	7	19	26	25	55	106	98	53	20	2	1		
	PrecMax	527	29	36	38	49	58	120	202	156	100	162	16	9		
	PrecMin	291	0	0	3	7	8	12	58	51	21	0	0	0		
	PrecStd	56	6	8	10	10	11	23	33	28	18	33	3	2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	9.1	10.3	11.0	12.7	14.5	14.7	14.3	13.3	11.1	10.8	10.7		
		MCWB	-1.4	-1.1	0.8	2.6	5.3	7.5	8.8	8.9	7.3	4.4	-0.5	-0.8		
	2%	DB	6.1	5.7	7.5	9.2	11.2	13.1	13.4	13.2	12.1	9.7	8.0	7.6		
		MCWB	-3.1	-2.9	-0.5	1.9	4.5	7.3	8.6	8.5	7.1	3.2	-1.2	-2.2		
	5%	DB	3.3	3.3	5.4	7.7	10.0	12.1	12.5	12.3	11.2	8.5	6.1	5.0		
		MCWB	-4.4	-3.7	-1.3	1.2	4.1	7.1	8.3	8.2	6.7	2.6	-1.6	-3.4		
	10%	DB	0.7	1.2	3.4	6.3	8.8	11.2	11.7	11.5	10.3	7.3	4.3	2.7		
		MCWB	-5.8	-4.7	-2.0	0.7	3.6	6.8	8.0	7.8	6.3	2.0	-2.3	-4.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.9	-0.6	2.6	4.4	6.7	8.9	9.7	9.7	8.5	5.7	1.3	-0.4		
		MCDB	9.2	7.3	7.4	9.3	10.7	12.5	13.3	13.2	12.0	9.4	6.9	8.6		
	2%	WB	-2.7	-2.1	0.6	3.1	5.9	8.2	9.1	9.0	7.7	4.8	0.1	-1.9		
		MCDB	5.2	4.0	5.5	7.6	9.7	11.6	12.4	12.3	11.1	8.3	5.5	6.9		
	5%	WB	-4.3	-3.3	-0.7	2.1	5.1	7.8	8.6	8.5	7.1	4.0	-0.8	-3.1		
		MCDB	2.6	2.3	4.0	6.2	8.5	11.0	11.7	11.6	10.3	7.0	4.5	4.3		
	10%	WB	-5.6	-4.4	-1.7	1.1	4.3	7.3	8.2	8.0	6.6	3.2	-1.8	-4.3		
		MCDB	0.2	0.5	2.6	5.1	7.7	10.3	11.1	10.9	9.5	5.8	3.2	2.1		
(35) Mean Daily Temperature Range	MDBR		16.2	14.4	12.0	10.2	8.7	7.1	6.3	6.7	7.6	11.0	14.6	16.8		
	5% DB	MCDBR	19.9	17.8	15.1	12.3	10.6	8.4	7.9	8.2	8.9	12.0	17.4	19.7		
		MCWBR	12.3	10.8	8.2	6.2	5.2	4.0	4.2	4.6	4.8	6.4	9.7	11.5		
	5% WB	MCDBR	19.0	16.7	13.1	11.2	8.7	7.0	6.9	7.3	7.9	9.0	14.9	19.0		
		MCWBR	12.2	10.6	7.7	6.2	4.6	3.7	3.9	4.3	4.5	5.2	9.1	11.6		
(40) Clear-Sky Solar Irradiance	taub		0.218	0.249	0.303	0.345	0.321	0.305	0.290	0.287	0.281	0.263	0.257	0.221		
	taud		2.529	2.443	2.294	2.212	2.375	2.489	2.577	2.585	2.553	2.554	2.476	2.563		
	Ebn at Noon		1057	1038	988	949	967	975	989	996	1000	1009	996	1041		
	Edh at Noon		87	104	129	145	123	110	100	99	98	92	91	80		
(44) All-Sky Solar Radiation	RadAvg		3.86	4.29	4.72	5.03	5.01	4.65	4.36	4.36	4.18	4.58	4.15	3.83		
	RadStd		0.33	0.34	0.25	0.36	0.34	0.28	0.34	0.30	0.25	0.23	0.34	0.27		

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
(46) Station Only		+0.31	N/A	-2.87	+0.30	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		+0.33	N/A	-2.87	N/A	N/A	N/A	-96	+6

Nomenclature: See separate page