

YUSHU, China

WMO: 560290

Lat: 33.0014N

Lon: 96.9642E

Elev: 12197

StdP: 9.27

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.9	3.0	-21.5	2.7	25.6	-18.4	3.2	23.7	17.0	31.8	15.4	32.3	1.1	290	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	74.3	52.5	71.5	51.6	68.9	50.7	55.1	69.1	53.8	67.1	52.7	64.8	3.7	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
50.5	87.0	58.7	49.4	83.4	57.7	48.4	80.3	57.2	29.2	69.4	28.1	67.4	27.2	65.2	64.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	11.6	9.4	DB	-6.7	79.4	5.0	2.2	-10.3	81.0	-13.2	82.2	-16.1	83.4	-19.7	85.0	(4)
(5)			WB	-8.2	57.5	4.5	2.1	-11.4	58.9	-14.0	60.2	-16.6	61.3	-19.8	62.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	40.4	21.1	26.5	33.4	41.0	48.0	54.0	57.5	56.7	51.7	40.8	30.4	22.5	(6)
(7)		DBStd	13.73	6.15	5.41	5.23	4.69	4.53	4.55	4.04	4.08	4.91	5.49	4.32	5.59	(7)
(8)		HDD50	4217	895	657	514	272	94	14	2	3	37	290	587	852	(8)
(9)		HDD65	8986	1360	1077	979	720	528	331	233	256	398	750	1037	1317	(9)
(10)		CDD50	708	0	0	0	2	30	133	236	212	90	5	0	0	(10)
(11)		CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)
(12)		CDH74	79	0	0	0	0	1	6	33	35	4	0	0	0	(12)
(13)		CDH80	2	0	0	0	0	0	0	1	1	0	0	0	0	(13)
(14)	Wind	WSAvg	2.9	3.0	3.6	3.8	3.6	3.3	2.6	2.4	2.2	2.2	2.3	2.6	2.6	(14)
(15)	Precipitation	PrecAvg	19.2	0.1	0.2	0.3	0.6	2.0	3.9	4.2	3.5	3.1	1.0	0.1	0.1	(15)
(16)		PrecMax	24.8	0.6	0.5	0.8	1.5	3.7	6.1	7.8	5.8	4.8	3.0	0.6	0.6	(16)
(17)		PrecMin	10.7	0.0	0.0	0.0	0.0	0.7	0.6	1.8	1.0	0.8	0.2	0.0	0.0	(17)
(18)		PrecStd	2.9	0.1	0.2	0.2	0.4	0.8	1.1	1.4	1.3	0.9	0.7	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	50.3	59.2	66.0	71.0	74.6	77.7	77.7	73.9	67.6	52.2	47.4	(19)
MCWB			29.1	30.1	35.1	40.2	45.7	52.2	55.2	52.9	50.6	45.1	32.8	28.9	(20)	
2%		DB	42.3	46.3	53.3	60.6	66.3	70.6	74.0	74.3	69.6	59.8	48.5	42.8	(21)	
		MCWB	26.2	28.6	32.9	38.3	43.8	51.0	53.7	52.5	50.2	42.7	31.0	26.7	(22)	
5%		DB	38.3	43.0	49.6	56.8	62.6	67.4	71.0	71.2	66.1	55.2	45.8	39.5	(23)	
		MCWB	24.4	27.1	31.4	36.5	42.5	50.1	52.6	51.8	49.0	39.9	29.9	25.1	(24)	
10%		DB	34.7	39.8	46.2	53.7	59.3	64.2	68.1	67.9	62.4	51.6	42.9	36.1	(25)	
		MCWB	22.5	25.5	29.9	35.4	41.5	48.5	51.7	51.0	47.9	38.3	28.5	23.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.7	31.0	36.1	42.2	49.1	55.2	58.4	56.2	54.0	47.2	34.9	30.1	(27)
MCD B			46.0	47.1	55.4	60.1	64.7	69.2	71.8	71.0	67.5	62.1	46.6	46.0	(28)	
2%		WB	26.9	29.1	33.7	40.0	46.8	53.2	55.7	54.6	52.1	44.7	32.7	27.2	(29)	
		MCD B	41.0	44.2	50.2	56.0	60.0	66.6	69.8	68.8	64.9	56.2	45.1	41.4	(30)	
5%		WB	24.8	27.7	32.2	38.2	45.1	51.7	54.2	53.3	50.6	42.6	30.9	25.4	(31)	
		MCD B	36.9	41.3	47.0	52.7	57.5	64.0	67.3	66.6	62.4	51.7	43.1	38.4	(32)	
10%		WB	22.9	26.1	30.8	36.7	43.5	50.4	53.0	52.2	49.2	40.5	29.4	23.6	(33)	
		MCD B	33.7	38.3	44.1	50.2	55.3	60.9	64.8	64.3	59.7	48.4	41.0	35.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	27.3	25.8	24.5	23.1	21.2	19.2	20.6	21.8	21.3	21.8	25.8	28.0	(35)
MCD BR			32.9	31.2	30.1	29.8	27.8	24.4	26.2	28.2	27.3	27.6	29.7	32.4	(36)	
MCWBR			20.3	17.8	14.6	12.9	10.5	8.6	9.6	10.0	10.2	11.9	15.3	19.4	(37)	
5% WB		MCD BR	30.8	28.7	26.5	25.3	22.2	20.2	21.0	22.1	22.5	23.4	26.5	31.0	(38)	
		MCWBR	19.2	16.5	13.1	11.4	9.2	8.2	8.3	8.6	8.9	10.4	14.0	18.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.212	0.242	0.300	0.340	0.336	0.314	0.302	0.297	0.276	0.255	0.219	0.198	(40)	
(41)		taud	2.549	2.467	2.282	2.196	2.302	2.487	2.564	2.564	2.599	2.583	2.602	2.632	(41)	
(42)		Ebn at Noon	331	326	311	300	301	306	309	311	316	318	325	333	(42)	
(43)		Edh at Noon	25	30	40	46	42	35	32	31	29	27	23	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1112	1384	1744	2027	2034	1840	1853	1713	1529	1349	1263	1085	(44)	
(45)		RadStd	85	67	90	114	123	107	101	147	100	69	47	62	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	-2.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.83	+1.75	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page