

YUSHU, China

WMO: 560290

Lat: 33.0014N

Lon: 96.9642E

Elev: 3718

StdP: 63.94

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.3	-16.1	-29.7	0.4	-3.6	-28.0	0.5	-4.6	7.6	-0.1	6.9	0.2	0.5	290	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	23.5	11.4	22.0	10.9	20.5	10.4	12.8	20.6	12.1	19.5	11.5	18.2	1.6	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.3	12.4	14.8	9.7	11.9	14.3	9.1	11.5	14.0	49.9	20.8	47.5	19.7	45.4	18.4	18.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.4	5.2	4.2	-21.5	26.3	2.8	1.2	-23.5	27.2	-25.1	27.9	-26.7	28.6	-28.7	29.4
			-22.3	14.2	2.5	1.1	-24.1	15.0	-25.6	15.6	-27.0	16.3	-28.8	17.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.7	-6.0	-3.0	0.8	5.0	8.9	12.2	14.2	13.7	11.0	4.9	-0.9	-5.3	(6)
(7)		DBStd	7.63	3.42	3.00	2.91	2.60	2.51	2.53	2.24	2.27	2.73	3.05	2.40	3.11	(7)
(8)		HDD10.0	2343	497	365	286	151	52	8	1	2	21	161	326	473	(8)
(9)		HDD18.3	4992	756	598	544	400	293	184	129	142	221	417	576	732	(9)
(10)		CDD10.0	393	0	0	0	1	17	74	131	118	50	3	0	0	(10)
(11)		CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)
(12)		CDH23.3	44	0	0	0	0	1	3	18	19	2	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	0	1	1	0	0	0	0	(13)
(14)	Wind	WSAvg	1.3	1.4	1.6	1.7	1.6	1.5	1.2	1.1	1.0	1.0	1.2	1.1	(14)	
(15)	Precipitation	PrecAvg	487	3	4	8	14	52	100	106	88	80	26	3	2	(15)
(16)		PrecMax	630	14	13	21	39	93	156	197	147	121	77	16	14	(16)
(17)		PrecMin	271	0	0	0	0	18	16	45	26	21	5	0	0	(17)
(18)		PrecStd	73	3	4	5	9	20	29	35	34	23	19	4	3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	10.2	15.1	18.9	21.7	23.7	25.4	25.4	23.3	19.8	11.2	8.5	(19)
(20)			MCWB	-1.6	-1.1	1.7	4.6	7.6	11.2	12.9	11.6	10.3	7.3	0.5	-1.7	(20)
(21)		2%	DB	5.7	8.0	11.8	15.9	19.0	21.5	23.3	23.5	20.9	15.4	9.2	6.0	(21)
(22)			MCWB	-3.2	-1.9	0.5	3.5	6.6	10.6	12.1	11.4	10.1	6.0	-0.6	-2.9	(22)
(23)		5%	DB	3.5	6.1	9.8	13.8	17.0	19.7	21.7	21.8	19.0	12.9	7.7	4.2	(23)
(24)			MCWB	-4.2	-2.7	-0.3	2.5	5.8	10.0	11.4	11.0	9.4	4.4	-1.2	-3.8	(24)
(25)		10%	DB	1.5	4.3	7.9	12.0	15.2	17.9	20.1	20.0	16.9	10.9	6.0	2.3	(25)
(26)			MCWB	-5.3	-3.6	-1.2	1.9	5.3	9.2	10.9	10.6	8.8	3.5	-1.9	-4.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.3	-0.5	2.3	5.7	9.5	12.9	14.7	13.4	12.2	8.4	1.6	-1.1	(27)
(28)			MCDWB	7.8	8.4	13.0	15.6	18.2	20.7	22.1	21.6	19.7	16.7	8.1	7.8	(28)
(29)		2%	WB	-2.9	-1.6	1.0	4.4	8.2	11.8	13.1	12.6	11.2	7.1	0.4	-2.6	(29)
(30)			MCDWB	5.0	6.8	10.1	13.3	15.6	19.2	21.0	20.4	18.3	13.4	7.3	5.2	(30)
(31)		5%	WB	-4.0	-2.4	0.1	3.4	7.3	11.0	12.3	11.9	10.3	5.9	-0.6	-3.7	(31)
(32)			MCDWB	2.7	5.2	8.3	11.5	14.2	17.8	19.6	19.2	16.9	11.0	6.1	3.5	(32)
(33)		10%	WB	-5.1	-3.3	-0.7	2.6	6.4	10.2	11.7	11.2	9.6	4.7	-1.4	-4.6	(33)
(34)			MCDWB	0.9	3.5	6.7	10.1	13.0	16.1	18.2	17.9	15.4	9.1	5.0	1.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.2	14.3	13.6	12.9	11.8	10.7	11.4	12.1	11.8	12.1	14.3	15.6	(35)
(36)			MCDBR	18.3	17.4	16.7	16.5	15.5	13.6	14.5	15.6	15.2	15.4	16.5	18.0	(36)
(37)			MCWBR	11.3	9.9	8.1	7.1	5.8	4.8	5.3	5.5	5.7	6.6	8.5	10.8	(37)
(38)		5% WB	MCDBR	17.1	16.0	14.7	14.1	12.3	11.2	11.6	12.3	12.5	13.0	14.7	17.2	(38)
(39)			MCWBR	10.7	9.2	7.3	6.3	5.1	4.5	4.6	4.8	4.9	5.8	7.8	10.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.212	0.242	0.300	0.340	0.336	0.314	0.302	0.297	0.276	0.255	0.219	0.198	(40)	
(41)		taud	2.549	2.467	2.282	2.196	2.302	2.487	2.564	2.564	2.599	2.583	2.602	2.632	(41)	
(42)		Ebn at Noon	1042	1029	979	946	948	964	974	979	995	1002	1026	1050	(42)	
(43)		Edh at Noon	79	96	126	145	132	109	101	99	91	85	74	68	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.51	4.36	5.50	6.39	6.41	5.80	5.84	5.40	4.82	4.25	3.98	3.42	(44)	
(45)		RadStd	0.27	0.21	0.28	0.36	0.39	0.34	0.32	0.46	0.32	0.22	0.15	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	-1.55	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (2 neighbors)	+0.46	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page