

DARLAG, China

WMO: 560460

Lat: 33.7577N

Lon: 99.6474E

Elev: 3968

StdP: 61.90

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -24.3	(c) -21.9	(d) -31.5	(e) 0.3	(f) -16.9	(g) -29.5	(h) 0.4	(i) -14.4	(j) 13.2	(k) -2.4	(l) 11.0	(m) -3.3	(n) 0.5	(o) 200	(p) 0.759

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.0	(c) 19.1	(d) 9.8	(e) 17.6	(f) 9.3	(g) 16.2	(h) 8.7	(i) 11.2	(j) 17.1	(k) 10.4	(l) 15.9	(m) 9.7	(n) 14.6	(o) 2.6	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
8.9	11.7	13.6	8.3	11.2	12.9	7.7	10.7	12.3	45.5	17.3	43.1	16.1	40.8	14.8	14.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.5	(b) 7.8	(c) 6.3	(e) -28.4	(f) 21.9	(g) 2.6	(h) 1.1	(i) -30.2	(j) 22.7	(k) -31.7	(l) 23.3	(m) -33.2	(n) 23.9	(o) -35.0	(p) 24.7		
(a) 9.5	(b) 7.8	(c) 6.3	(e) -28.8	(f) 12.7	(g) 2.5	(h) 0.6	(i) -30.5	(j) 13.2	(k) -32.0	(l) 13.5	(m) -33.4	(n) 13.9	(o) -35.2	(p) 14.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.5	-11.0	-8.1	-4.0	1.3	5.0	8.4	10.6	10.3	7.4	1.3	-5.2	-10.2		
	DBStd	8.24	3.71	3.62	3.34	2.86	2.53	2.52	2.26	2.38	2.84	3.16	3.12	3.72		
	HDD10.0	3551	651	506	433	262	156	60	20	27	87	269	455	627		
	HDD18.3	6497	909	739	692	512	413	297	239	250	329	527	705	885		
	CDD10.0	96	0	0	0	0	1	13	39	35	8	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	2.1	2.0	2.3	2.5	2.5	2.4	2.2	2.1	1.9	1.9	1.9	1.9	1.8		
	PrecAvg	546	5	6	13	24	55	104	112	98	90	32	5	3		
(15) Precipitation	PrecMax	699	19	20	31	49	83	151	230	188	197	70	16	8		
	PrecMin	417	0	1	3	8	22	50	51	41	43	12	0	0		
	PrecStd	73	4	4	7	11	16	27	43	33	41	15	4	2		
	PrecStd	73	4	4	7	11	16	27	43	33	41	15	4	2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.8	6.4	9.7	14.3	17.0	18.7	21.1	21.1	19.4	15.2	7.2	4.7		
		MCWB	-4.5	-2.9	-0.8	2.2	5.9	9.7	10.9	10.4	9.0	5.4	-1.8	-3.7		
	2%	DB	1.0	3.6	6.8	11.4	14.4	16.7	19.1	19.1	16.6	11.0	5.2	1.8		
		MCWB	-5.7	-4.3	-2.1	1.3	4.7	8.7	10.2	9.9	8.5	3.4	-2.8	-5.3		
	5%	DB	-1.0	1.6	4.8	9.5	12.6	15.1	17.5	17.4	14.6	8.8	3.4	-0.3		
		MCWB	-6.9	-5.1	-2.9	0.5	3.8	7.9	9.6	9.4	7.8	2.1	-3.4	-6.5		
	10%	DB	-3.1	-0.3	3.0	7.6	10.8	13.6	16.0	15.8	12.7	6.9	1.7	-2.3		
		MCWB	-8.1	-6.1	-3.7	-0.2	3.3	7.3	9.1	8.8	6.8	1.2	-4.2	-7.5		
	0.4%	WB	-4.0	-2.7	-0.2	3.7	7.9	11.3	12.2	12.3	10.5	6.7	-1.0	-3.3		
		MCDB	2.6	4.9	7.7	10.8	15.1	17.1	18.4	18.0	16.5	13.3	4.7	4.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-5.5	-3.9	-1.3	2.4	6.4	9.9	11.3	11.1	9.4	4.9	-2.0	-5.0		
		MCDB	0.4	2.5	5.2	8.9	12.0	15.2	17.2	17.1	14.7	9.6	3.7	1.3		
	5%	WB	-6.7	-4.8	-2.3	1.3	5.2	9.0	10.6	10.3	8.5	3.4	-2.9	-6.2		
		MCDB	-1.6	0.9	3.2	7.4	10.2	13.5	16.0	15.8	13.2	7.2	2.3	-0.8		
	10%	WB	-7.8	-5.8	-3.1	0.5	4.2	8.1	9.8	9.5	7.6	2.1	-3.8	-7.3		
		MCDB	-3.4	-0.6	2.1	6.1	8.9	12.2	14.5	14.4	11.7	5.5	1.1	-2.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.6	14.3	12.5	10.9	10.1	9.2	10.0	10.7	10.4	10.4	13.7	15.8		
		MCDBR	18.2	17.3	15.7	14.4	13.9	11.5	13.0	13.6	13.1	13.3	15.7	18.1		
		MCWBR	12.5	11.0	8.6	6.2	5.7	5.1	5.8	6.1	6.2	6.5	9.1	12.0		
		MCDBR	17.1	15.7	13.1	12.2	10.8	9.4	10.3	10.8	11.0	11.2	13.9	17.3		
	5% WB	MCWBR	11.9	10.1	7.4	5.7	5.2	4.9	5.0	5.4	5.6	5.8	8.2	11.7		
		MCWBR	11.9	10.1	7.4	5.7	5.2	4.9	5.0	5.4	5.6	5.8	8.2	11.7		
(40) Clear-Sky Solar Irradiance	taub		0.203	0.231	0.286	0.314	0.314	0.296	0.288	0.283	0.262	0.242	0.210	0.191		
	taud		2.568	2.483	2.311	2.269	2.366	2.531	2.596	2.595	2.640	2.614	2.610	2.630		
	Ebn at Noon		1052	1040	993	972	969	981	988	992	1010	1016	1035	1056		
	Edh at Noon		76	94	122	134	123	104	97	96	87	81	72	67		
(44) All-Sky Solar Radiation	RadAvg		3.44	4.21	5.38	6.24	6.08	5.78	6.15	5.72	4.78	4.17	3.84	3.29		
	RadStd		0.29	0.30	0.30	0.36	0.32	0.47	0.37	0.53	0.39	0.25	0.19	0.17		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.53	+1.00	N/A	+0.61	N/A	N/A	-179	-219	+40
(47) Regional (3 neighbors)		+0.48	+0.76	N/A	N/A	N/A	N/A	-161	-184	+23

Nomenclature: See separate page