

HEZUO, China

WMO: 560800

Lat: 34.9910N

Lon: 102.9048E

Elev: 9547

StdP: 10.29

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.9	(c) 0.4	(d) -20.8	(e) 2.5	(f) 19.1	(g) -17.1	(h) 3.1	(i) 18.3	(j) 19.4	(k) 34.1	(l) 15.9	(m) 33.4	(n) 1.2	(o) 340	(p) 0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	74.3	56.0	71.5	54.5	68.7	53.3	59.5	69.0	57.9	66.6	56.3	64.5	5.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.4	97.6	63.8	54.8	92.0	62.1	53.3	86.8	60.7	31.2	69.0	29.8	67.0	28.6	64.3	66.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.4	(b) 12.7	(c) 10.8	(e) -9.8	(f) 80.3	(g) 3.7	(h) 2.2	(i) -12.5	(j) 81.9	(k) -14.6	(l) 83.2	(m) -16.7	(n) 84.4	(o) -19.4	(p) 86.0		
(4) 15.4	(5) 12.7	(6) 10.8	(7) -9.8	(8) 80.3	(9) 3.7	(10) 2.2	(11) -12.5	(12) 81.9	(13) -14.6	(14) 83.2	(15) -16.7	(16) 84.4	(17) -19.4	(18) 86.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	39.4	18.0	23.6	32.1	40.9	47.3	53.0	57.3	56.8	50.5	41.1	30.3	20.7
	DBStd	14.51	5.60	6.40	6.27	5.89	4.96	4.21	4.30	4.62	5.18	4.93	5.79	4.86
	HDD50	4526	992	738	554	277	112	17	2	3	53	279	592	907
	HDD65	9357	1457	1158	1019	723	549	360	242	257	437	741	1042	1372
	CDD50	648	0	0	0	4	28	107	227	214	66	2	0	0
	CDD65	5	0	0	0	0	0	0	2	2	1	0	0	0
	CDH74	91	0	0	0	2	1	4	47	30	7	0	0	0
	CDH80	3	0	0	0	0	0	0	2	1	0	0	0	0
	WSAvg	3.6	2.9	3.5	4.2	4.4	4.4	3.9	3.7	3.5	3.5	3.3	2.9	2.7
	PrecAvg	21.6	0.1	0.2	0.6	1.3	2.9	2.9	4.4	4.2	3.1	1.6	0.3	0.0
(15) Precipitation	PrecMax	31.5	0.3	0.5	1.4	2.5	7.0	6.2	7.1	8.4	4.8	3.5	0.7	0.3
	PrecMin	14.7	0.0	0.0	0.0	0.4	1.3	1.2	1.9	1.5	0.8	0.5	0.0	0.0
	PrecStd	3.9	0.1	0.1	0.3	0.6	1.3	1.3	1.4	1.7	1.1	0.7	0.2	0.1
	PrecStd	3.9	0.1	0.1	0.3	0.6	1.3	1.3	1.4	1.7	1.1	0.7	0.2	0.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	47.0	54.3	61.7	68.9	71.2	73.4	78.1	77.4	73.7	64.5	55.7	47.5	30.4
	0.4% MCWB	29.4	33.2	38.5	44.0	46.7	54.2	57.3	57.8	56.7	45.1	36.8	30.1	20.7
	2% DB	41.3	47.7	54.8	63.1	66.7	69.6	74.9	73.7	68.1	59.1	51.1	42.3	21.1
	2% MCWB	26.7	30.6	35.4	41.7	46.7	52.3	56.5	56.3	52.5	43.3	34.0	27.5	17.5
	5% DB	37.1	42.7	50.2	58.8	63.4	66.7	71.8	70.8	64.1	55.1	47.5	38.7	23.7
	5% MCWB	24.4	28.1	33.6	40.5	45.6	51.2	55.3	55.6	50.6	41.5	32.7	25.7	17.5
	10% DB	32.5	38.0	45.8	54.8	59.9	64.0	68.6	67.5	60.6	51.5	43.6	34.9	23.7
	10% MCWB	22.0	26.2	31.8	39.2	44.7	50.0	54.6	54.6	49.7	40.5	30.8	23.7	17.5
	0.4% WB	30.0	33.9	40.5	47.8	52.3	58.6	61.4	61.9	59.8	48.9	38.3	30.4	20.7
	0.4% MCDB	46.0	52.6	58.6	63.2	63.3	67.1	72.4	72.7	68.2	58.7	51.4	45.4	30.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	26.9	30.9	36.9	44.2	49.8	55.9	59.4	59.6	56.0	45.9	35.8	27.9	17.5
	2% MCDB	40.6	46.2	51.1	57.4	60.5	63.8	69.4	68.9	64.3	54.1	47.3	41.2	30.4
	5% WB	24.5	28.7	34.6	42.2	47.7	53.9	58.0	57.9	53.6	43.8	33.7	26.0	17.5
	5% MCDB	36.5	41.4	47.4	55.0	58.2	61.3	67.0	66.2	60.9	51.7	44.2	38.0	23.7
	10% WB	22.0	26.5	32.4	40.4	46.1	52.1	56.4	56.4	51.2	41.8	31.9	23.9	17.5
	10% MCDB	32.1	37.4	43.9	52.1	56.8	60.5	64.8	64.2	57.7	49.0	41.8	34.4	23.7
(35) Mean Daily Temperature Range	MDBR	29.5	27.8	24.4	23.3	21.4	19.6	19.8	20.0	18.5	20.1	26.0	30.0	30.0
	5% DB	37.0	36.3	33.4	32.2	29.5	26.3	27.0	26.0	25.7	26.8	31.9	35.5	35.5
	MCWBR	24.4	21.6	16.6	13.8	11.9	10.7	10.5	10.4	11.0	12.2	16.6	22.4	22.4
	5% WB	35.5	33.6	28.4	27.0	23.9	20.0	20.6	20.5	20.3	21.6	27.4	33.7	33.7
	MCWBR	23.7	20.3	14.7	12.6	10.8	9.0	8.7	8.7	9.6	10.9	14.6	21.5	21.5
	MCWBR	23.7	20.3	14.7	12.6	10.8	9.0	8.7	8.7	9.6	10.9	14.6	21.5	21.5
(40) Clear-Sky Solar Irradiance	taub	0.273	0.319	0.381	0.419	0.411	0.401	0.390	0.389	0.363	0.323	0.275	0.250	0.250
	taud	2.369	2.219	2.036	1.978	2.097	2.206	2.295	2.282	2.335	2.387	2.441	2.472	2.472
	Ebn at Noon	297	292	280	275	278	279	282	280	284	287	295	302	302
	Edn at Noon	30	39	51	57	51	46	42	41	37	32	27	25	25
(44) All-Sky Solar Radiation	RadAvg	1025	1253	1530	1731	1749	1685	1734	1613	1274	1188	1067	977	977
	RadStd	68	71	89	88	82	124	186	137	108	110	63	36	36

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+58	N/A
Regional (6 neighbors)	+0.72	+1.04	N/A	N/A	N/A	N/A	N/A	N/A	+58	N/A

Nomenclature: See separate page