

WUDU, China

WMO: 560960

Lat: 33.4025N

Lon: 104.9175E

Elev: 3540

StdP: 12.91

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.7	29.9	3.9	7.7	35.1	7.5	9.2	37.4	14.1	42.2	11.9	41.6	2.7	40	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	93.5	68.7	91.2	68.4	88.9	67.7	72.5	85.9	71.4	84.2	70.4	83.0	8.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.2	122.7	76.3	68.0	117.3	76.7	66.7	112.3	76.5	38.9	85.7	37.8	84.3	36.9	82.6	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.0	11.8	10.0	23.5	97.5	2.7	1.6	21.5	98.6	19.9	99.6	18.3	100.5	16.3	101.6
			19.0	73.7	2.7	1.5	17.1	74.7	15.6	75.6	14.1	76.4	12.1	77.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.5	39.2	45.0	53.5	63.1	69.6	75.1	79.1	78.0	69.5	60.6	51.0	40.9
	DBStd	14.72	4.31	5.53	7.02	6.51	5.30	4.68	4.73	5.13	5.47	4.94	5.59	4.14
	HDD50	871	334	154	42	2	0	0	0	0	0	1	56	282
	HDD65	3185	799	559	360	109	20	1	0	0	18	152	421	746
	CDD50	4694	0	16	152	394	606	754	902	869	586	329	85	1
	CDD65	1532	0	0	5	51	162	305	437	404	153	15	0	0
	CDH74	12836	0	0	43	368	1111	2401	4230	3766	862	55	0	0
	CDH80	4832	0	0	4	75	291	864	1824	1545	223	6	0	0
Wind	WSAvg	3.7	3.0	3.7	4.2	4.6	4.4	4.1	4.3	4.1	3.4	3.0	2.8	2.7
Precipitation	PrecAvg	19.1	0.1	0.1	0.6	1.4	2.2	2.7	3.7	3.4	3.1	1.4	0.4	0.0
	PrecMax	27.2	0.3	0.6	1.1	3.4	3.9	5.4	6.6	7.5	6.7	2.7	1.6	0.2
	PrecMin	14.1	0.0	0.0	0.0	0.3	0.9	0.7	1.1	1.0	1.0	0.4	0.1	0.0
	PrecStd	3.1	0.1	0.1	0.3	0.7	0.8	1.3	1.5	1.5	1.5	0.6	0.3	0.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.2	66.0	78.9	86.2	89.6	94.6	96.9	95.8	90.3	79.3	68.2	55.4
		MCWB	41.2	46.8	55.4	59.4	62.1	65.9	70.4	70.7	67.7	61.2	53.7	42.7
	2%	DB	52.2	61.0	73.6	81.9	86.2	90.9	93.9	93.1	85.6	74.9	65.4	52.7
		MCWB	39.2	45.1	52.1	58.0	61.8	65.4	69.5	69.7	65.9	59.6	52.2	41.2
	5%	DB	49.6	57.6	69.4	78.3	83.3	88.0	91.4	90.6	82.2	71.7	62.7	50.6
		MCWB	38.0	43.7	50.9	56.8	60.8	65.2	69.1	69.3	64.7	58.3	51.1	39.9
	10%	DB	47.1	54.3	65.5	74.7	80.5	85.2	89.0	88.1	78.9	68.9	60.0	48.7
		MCWB	36.6	41.9	49.6	55.6	60.2	64.8	68.8	68.8	64.1	57.3	49.7	38.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.3	48.8	58.7	63.7	66.5	71.7	74.4	73.6	71.2	64.4	54.9	44.5
		MCDB	52.9	62.4	74.9	77.6	80.5	79.9	90.2	88.0	82.9	73.8	65.6	53.4
	2%	WB	40.4	46.4	53.9	60.8	64.8	69.7	72.8	72.4	69.0	61.8	53.2	42.5
		MCDB	50.4	58.1	68.8	76.1	79.1	81.0	86.3	86.4	79.7	70.8	62.5	50.7
	5%	WB	38.8	44.7	52.0	58.8	63.5	68.4	71.7	71.4	67.1	60.3	52.1	41.0
		MCDB	48.1	55.7	66.3	73.7	77.1	80.3	84.4	85.0	77.6	69.0	60.9	49.0
	10%	WB	37.4	43.0	50.3	57.2	62.1	67.2	70.7	70.4	65.4	58.6	50.7	39.7
		MCDB	46.2	53.1	63.8	71.4	75.2	79.3	83.2	83.5	75.5	66.6	58.8	47.7
Mean Daily Temperature Range	5% DB	MDBR	13.1	13.5	15.7	17.2	17.3	16.3	15.8	15.5	12.8	12.3	12.9	13.1
		MCDBR	17.6	20.4	23.4	23.9	22.6	22.3	20.4	19.4	19.0	17.9	16.4	15.1
		MCWBR	10.1	10.6	9.8	8.0	6.8	5.9	4.9	4.6	5.6	7.0	7.9	8.4
	5% WB	MCDBR	15.7	17.5	20.6	19.9	18.1	16.0	15.5	15.6	14.4	14.7	14.6	12.9
MCWBR		9.3	9.2	9.0	7.5	6.4	5.1	4.3	4.4	5.1	6.3	7.2	7.6	
Clear-Sky Solar Irradiance	taub	0.502	0.573	0.630	0.629	0.592	0.568	0.574	0.610	0.579	0.548	0.497	0.454	
	taud	1.746	1.636	1.571	1.614	1.757	1.864	1.892	1.781	1.816	1.812	1.833	1.877	
	Ebn at Noon	209	209	211	221	231	236	234	222	221	214	210	216	
	Edh at Noon	58	72	82	82	72	65	62	69	64	59	53	48	
All-Sky Solar Radiation	RadAvg	836	935	1182	1448	1540	1484	1481	1361	980	868	816	801	
	RadStd	83	127	115	117	135	141	215	173	96	124	99	86	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	-2.50	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)		+0.56	N/A	-1.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page