

WUDU, China

WMO: 560960

Lat: 33.4025N

Lon: 104.9175E

Elev: 1079

StdP: 89.02

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.4	-1.2	-15.6	1.1	1.7	-13.6	1.3	3.0	6.3	5.7	5.3	5.4	1.2	40	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	34.2	20.4	32.9	20.2	31.6	19.8	22.5	29.9	21.9	29.0	21.4	28.3	3.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	17.5	24.6	20.0	16.8	24.8	19.3	16.0	24.7	72.5	29.9	70.1	29.0	68.0	28.1	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.3	5.3	4.5	-4.7	36.4	1.5	0.9	-5.8	37.0	-6.7	37.5	-7.6	38.0	-8.7	38.7		
			DB	WB												
			-7.2	23.2	1.5	0.8	-8.3	23.7	-9.1	24.2	-10.0	24.7	-11.0	25.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	4.0	7.2	12.0	17.3	20.9	24.0	26.2	25.6	20.9	15.9	10.5	5.0
	DBStd	8.18	2.40	3.07	3.90	3.61	2.94	2.60	2.63	2.85	3.04	2.74	3.11	2.30
	HDD10.0	484	186	86	23	1	0	0	0	0	0	1	31	157
	HDD18.3	1769	444	311	200	61	11	1	0	0	10	84	234	414
	CDD10.0	2608	0	9	84	219	337	419	501	483	326	183	47	1
	CDD18.3	851	0	0	3	28	90	169	243	224	85	8	0	0
	CDH23.3	7131	0	0	24	204	617	1334	2350	2092	479	31	0	0
	CDH26.7	2684	0	0	2	42	162	480	1013	858	124	3	0	0
Wind	WSAvg	1.6	1.3	1.7	1.9	2.1	2.0	1.8	1.9	1.8	1.5	1.3	1.2	1.2
Precipitation	PrecAvg	485	2	3	14	36	57	69	95	87	78	35	9	1
	PrecMax	690	8	14	28	87	99	137	168	191	169	68	41	5
	PrecMin	358	0	0	0	8	22	18	27	26	26	10	2	0
	PrecStd	80	2	3	8	17	21	32	38	38	37	15	8	1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	18.9	26.1	30.1	32.0	34.8	36.1	35.5	32.4	26.3	20.1	13.0
		MCWB	5.1	8.2	13.0	15.2	16.7	18.9	21.3	21.5	19.8	16.2	12.1	5.9
	2%	DB	11.2	16.1	23.1	27.7	30.1	32.7	34.4	33.9	29.8	23.8	18.6	11.5
		MCWB	4.0	7.3	11.2	14.4	16.6	18.6	20.8	20.9	18.8	15.3	11.2	5.1
	5%	DB	9.8	14.2	20.8	25.7	28.5	31.1	33.0	32.6	27.9	22.1	17.1	10.3
		MCWB	3.3	6.5	10.5	13.8	16.0	18.5	20.6	20.7	18.2	14.6	10.6	4.4
	10%	DB	8.4	12.4	18.6	23.7	26.9	29.6	31.7	31.1	26.1	20.5	15.6	9.3
		MCWB	2.6	5.5	9.8	13.1	15.7	18.2	20.4	20.4	17.8	14.1	9.8	3.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	9.3	14.8	17.6	19.1	22.0	23.6	23.1	21.8	18.0	12.7	7.0
		MCDB	11.6	16.9	23.9	25.3	27.0	26.6	32.3	31.1	28.3	23.2	18.7	11.9
	2%	WB	4.7	8.0	12.2	16.0	18.2	21.0	22.7	22.4	20.6	16.6	11.8	5.8
		MCDB	10.2	14.5	20.5	24.5	26.2	27.2	30.2	30.2	26.5	21.5	17.0	10.4
	5%	WB	3.7	7.1	11.1	14.9	17.5	20.2	22.0	21.9	19.5	15.7	11.2	5.0
		MCDB	8.9	13.2	19.1	23.2	25.1	26.8	29.1	29.5	25.3	20.6	16.1	9.5
	10%	WB	3.0	6.1	10.2	14.0	16.7	19.6	21.5	21.3	18.6	14.8	10.4	4.3
		MCDB	7.9	11.7	17.7	21.9	24.0	26.3	28.4	28.6	24.2	19.2	14.9	8.7
Mean Daily Temperature Range	5% DB	MDBR	7.3	7.5	8.7	9.6	9.6	9.1	8.8	8.6	7.1	6.9	7.2	7.3
		MCDBR	9.8	11.4	13.0	13.3	12.6	12.4	11.3	10.8	10.6	10.0	9.1	8.4
		MCWBR	5.6	5.9	5.5	4.5	3.8	3.3	2.7	2.6	3.1	3.9	4.4	4.7
	5% WB	MCDBR	8.7	9.7	11.5	11.1	10.0	8.9	8.6	8.7	8.0	8.2	8.1	7.2
		MCWBR	5.2	5.1	5.0	4.2	3.5	2.8	2.4	2.4	2.8	3.5	4.0	4.2
Clear-Sky Solar Irradiance	taub	0.502	0.573	0.630	0.629	0.592	0.568	0.574	0.610	0.579	0.548	0.497	0.454	
	taud	1.746	1.636	1.571	1.614	1.757	1.864	1.892	1.781	1.816	1.812	1.833	1.877	
	Ebn at Noon	659	658	664	696	729	745	737	701	698	674	662	682	
	Edh at Noon	183	226	260	260	227	204	197	217	201	186	166	151	
All-Sky Solar Radiation	RadAvg	2.63	2.95	3.73	4.56	4.86	4.68	4.67	4.29	3.09	2.74	2.57	2.53	
	RadStd	0.26	0.40	0.36	0.37	0.43	0.45	0.68	0.55	0.30	0.39	0.31	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-1.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.31	N/A	-0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page