

DEGE, China

WMO: 561440

Lat: 31.8032N

Lon: 98.5765E

Elev: 10614

StdP: 9.87

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	14.2	-16.4	3.3	28.7	-13.1	4.0	27.4	17.9	44.4	14.4	43.5	1.5	110	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	78.7	55.1	75.8	54.4	73.1	53.5	58.4	70.8	57.3	69.7	56.2	67.9	4.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.8	95.7	62.1	53.6	91.6	60.7	52.6	88.4	60.1	31.0	71.1	30.0	69.8	29.1	68.4	65.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	9.6	7.8	7.3	84.3	2.2	2.3	5.7	85.9	4.4	87.3	3.2	88.5	1.6	90.2		
(5)			3.7	60.6	1.9	1.5	2.3	61.7	1.2	62.6	0.2	63.4	-1.2	64.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.9	30.7	35.4	40.6	46.8	53.7	58.9	61.4	60.8	56.2	47.5	38.2	31.6		
	DBStd	11.76	4.71	4.68	4.35	4.25	4.62	4.38	3.74	3.97	4.31	5.04	4.14	4.22		
	HDD50	2471	599	410	292	113	16	1	0	0	6	111	353	570		
	HDD65	6633	1064	830	756	545	351	187	119	138	263	542	803	1035		
	CDD50	1335	0	0	1	18	131	269	355	334	193	34	0	0		
	CDD65	21	0	0	0	0	0	5	9	7	0	0	0	0		
	CDH74	449	0	0	0	2	22	94	144	160	26	1	0	0		
	CDH80	39	0	0	0	0	1	9	10	17	2	0	0	0		
	WSAvg	2.8	2.7	2.8	3.1	3.2	3.1	2.8	2.8	2.8	2.6	2.6	2.3	2.3		
	PrecAvg	24.1	0.0	0.1	0.4	0.9	2.1	4.8	5.5	4.4	4.5	1.2	0.2	0.1		
(15) Precipitation	PrecMax	29.5	0.3	0.6	1.4	1.9	3.8	9.3	10.2	10.4	7.4	3.0	0.9	0.3		
	PrecMin	16.7	0.0	0.0	0.0	0.1	0.3	1.8	2.4	0.8	1.1	0.2	0.0	0.0		
	PrecStd	3.4	0.1	0.1	0.4	0.4	0.8	1.8	1.7	2.0	1.5	0.7	0.2	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	58.1	64.3	70.5	76.9	81.1	81.5	82.3	77.2	71.9	59.2	52.6		
		MCWB	33.0	35.1	39.8	43.9	50.1	54.1	57.0	55.6	53.9	50.2	38.4	33.0		
	2%	DB	48.7	53.6	59.4	65.8	72.6	76.6	78.0	78.3	73.3	66.6	55.2	48.5		
		MCWB	30.6	33.0	37.1	42.3	48.4	54.1	56.1	55.4	53.2	47.3	35.8	31.0		
	5%	DB	45.0	50.0	56.0	62.4	69.3	72.8	74.9	75.0	69.9	62.4	52.3	45.3		
		MCWB	28.8	31.7	35.9	40.7	47.3	53.4	55.6	54.9	52.7	45.2	34.7	29.4		
	10%	DB	41.7	46.4	52.6	59.0	66.0	69.2	71.7	71.3	66.3	58.3	48.8	42.0		
		MCWB	27.1	30.2	34.5	39.7	46.2	52.4	55.1	54.2	51.7	43.4	33.3	27.8		
	0.4%	WB	33.5	36.0	40.9	46.2	52.8	58.6	60.4	59.4	57.0	52.0	40.1	33.6		
		MCDB	52.7	54.8	59.7	65.2	70.0	71.0	71.5	70.9	69.7	67.0	53.3	50.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	31.0	33.8	38.7	44.1	50.8	56.7	59.0	57.8	55.4	49.6	37.8	31.5		
		MCDB	46.9	51.1	54.9	60.2	67.5	68.5	71.5	70.4	68.0	62.5	50.9	46.0		
	5%	WB	29.1	32.2	37.2	42.5	49.4	55.6	57.8	56.6	54.1	47.6	35.8	29.9		
		MCDB	43.4	48.1	52.1	57.6	64.8	67.5	70.1	69.2	65.6	58.4	49.2	43.9		
	10%	WB	27.5	30.7	35.7	41.2	47.9	54.4	56.7	55.6	52.9	45.5	34.1	28.3		
		MCDB	40.6	44.9	49.5	55.1	61.7	65.5	68.1	67.4	63.4	54.7	47.1	41.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	25.5	24.5	24.0	23.0	23.3	21.0	21.5	21.7	21.4	22.7	25.3	26.0		
		MCDBR	29.2	29.5	30.3	29.5	29.1	27.1	27.4	28.9	27.2	28.2	28.6	28.7		
		MCWBR	16.1	15.1	14.2	12.1	10.7	9.2	9.6	9.9	10.4	11.6	13.9	15.9		
		MCDBR	27.5	27.1	25.9	24.4	24.3	21.7	21.9	22.0	22.0	24.2	26.0	27.7		
	5% WB	MCWBR	15.4	14.0	12.1	10.3	9.0	7.9	8.0	7.9	8.9	10.2	13.1	15.5		
(40) Clear-Sky Solar Irradiance	taub		0.250	0.290	0.356	0.377	0.353	0.328	0.326	0.325	0.297	0.271	0.243	0.228		
	taud		2.484	2.358	2.135	2.131	2.308	2.495	2.528	2.514	2.572	2.577	2.573	2.579		
	Ebn at Noon		315	308	292	289	296	302	302	302	309	313	317	320		
	Edh at Noon		28	35	47	49	42	35	33	33	30	28	25	23		
(44) All-Sky Solar Radiation	RadAvg		1233	1451	1785	2006	1997	1888	1949	1836	1591	1374	1327	1184		
	RadStd		86	99	123	128	147	169	151	193	114	70	64	64		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-2.30	+2.02	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	+0.77	+1.01	-3.17	+1.10	N/A	N/A	N/A	-297	+187	+9

Nomenclature: See separate page