

DEGE, China

WMO: 561440

Lat: 31.8032N

Lon: 98.5765E

Elev: 3235

StdP: 68.04

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -11.4	(c) -9.9	(d) -26.9	(e) 0.5	(f) -1.8	(g) -25.0	(h) 0.6	(i) -2.6	(j) 8.0	(k) 6.9	(l) 6.4	(m) 6.4	(n) 0.7	(o) 110	(p) 0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	25.9	12.9	24.3	12.5	22.8	12.0	14.7	21.5	14.0	20.9	13.5	19.9	2.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.6	13.7	16.7	12.0	13.1	15.9	11.5	12.6	15.6	54.1	21.7	51.9	21.0	49.9	20.2	18.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.4	4.3	3.5	-13.7	29.1	1.2	1.3	-14.6	30.0	-15.3	30.7	-16.0	31.4	-16.9	32.3		
			-15.7	15.9	1.1	0.8	-16.5	16.5	-17.1	17.0	-17.7	17.5	-18.5	18.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-0.7	1.9	4.8	8.2	12.1	15.0	16.4	16.0	13.5	8.6	3.5	-0.2		
	DBStd	6.54	2.62	2.60	2.42	2.36	2.56	2.43	2.08	2.20	2.39	2.80	2.30	2.35		
	HDD10.0	1373	333	228	162	63	9	1	0	0	3	62	196	317		
	HDD18.3	3685	591	461	420	303	195	104	66	77	146	301	446	575		
	CDD10.0	742	0	0	1	10	73	149	197	186	107	19	0	0		
	CDD18.3	12	0	0	0	0	0	3	5	4	0	0	0	0		
	CDH23.3	249	0	0	0	1	12	52	80	89	14	1	0	0		
	CDH26.7	22	0	0	0	0	1	5	6	9	1	0	0	0		
(14) Wind	WSAvg	1.2	1.2	1.3	1.4	1.4	1.4	1.2	1.3	1.2	1.2	1.2	1.0	1.0		
(15) Precipitation	PrecAvg	613	1	3	10	23	53	123	140	111	114	31	4	2		
	PrecMax	749	8	15	36	47	96	237	260	263	189	76	24	8		
	PrecMin	424	0	0	0	3	8	45	61	21	28	4	0	0		
	PrecStd	87	2	3	9	11	21	46	42	50	38	19	5	2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	14.5	17.9	21.4	25.0	27.3	27.5	27.9	25.1	22.2	15.1	11.5		
		MCWB	0.5	1.7	4.3	6.6	10.1	12.3	13.9	13.1	12.2	10.1	3.6	0.5		
	2%	DB	9.3	12.0	15.2	18.8	22.6	24.8	25.5	25.7	22.9	19.2	12.9	9.2		
		MCWB	-0.8	0.6	2.8	5.7	9.1	12.3	13.4	13.0	11.8	8.5	2.1	-0.6		
	5%	DB	7.2	10.0	13.4	16.9	20.7	22.7	23.8	23.9	21.0	16.9	11.3	7.4		
		MCWB	-1.8	-0.2	2.1	4.9	8.5	11.9	13.1	12.7	11.5	7.3	1.5	-1.5		
	10%	DB	5.4	8.0	11.5	15.0	18.9	20.7	22.0	21.8	19.1	14.6	9.4	5.5		
		MCWB	-2.7	-1.0	1.4	4.3	7.9	11.3	12.8	12.3	11.0	6.3	0.7	-2.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.8	2.2	4.9	7.9	11.5	14.8	15.8	15.2	13.9	11.1	4.5	0.9		
		MCDB	11.5	12.7	15.4	18.5	21.1	21.6	22.0	21.6	20.9	19.5	11.8	10.3		
	2%	WB	-0.6	1.0	3.7	6.7	10.4	13.7	15.0	14.3	13.0	9.8	3.2	-0.3		
		MCDB	8.3	10.6	12.7	15.7	19.7	20.3	21.9	21.3	20.0	17.0	10.5	7.8		
	5%	WB	-1.6	0.1	2.9	5.8	9.7	13.1	14.3	13.7	12.3	8.6	2.1	-1.1		
		MCDB	6.4	8.9	11.1	14.2	18.2	19.7	21.1	20.6	18.7	14.7	9.6	6.6		
	10%	WB	-2.5	-0.7	2.1	5.1	8.8	12.5	13.7	13.1	11.6	7.5	1.1	-2.1		
		MCDB	4.8	7.2	9.7	12.9	16.5	18.6	20.0	19.6	17.5	12.6	8.4	5.1		
(35) Mean Daily Temperature Range	MDBR		14.2	13.6	13.4	12.8	12.9	11.6	11.9	12.1	11.9	12.6	14.1	14.4		
	5% DB	MCDBR	16.2	16.4	16.8	16.4	16.2	15.1	15.2	16.0	15.1	15.7	15.9	16.0		
		MCWBR	9.0	8.4	7.9	6.7	5.9	5.1	5.4	5.5	5.8	6.4	7.7	8.9		
	5% WB	MCDBR	15.3	15.0	14.4	13.6	13.5	12.0	12.2	12.2	12.2	13.4	14.4	15.4		
		MCWBR	8.6	7.8	6.7	5.7	5.0	4.4	4.4	4.4	4.9	5.7	7.3	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.250	0.290	0.356	0.377	0.353	0.328	0.326	0.325	0.297	0.271	0.243	0.228		
	taud		2.484	2.358	2.135	2.131	2.308	2.495	2.528	2.514	2.572	2.577	2.573	2.579		
	Ebn at Noon		994	971	920	912	932	951	951	952	975	987	998	1010		
	Edh at Noon		87	109	148	155	131	109	104	104	94	87	78	74		
(44) All-Sky Solar Radiation	RadAvg		3.89	4.57	5.63	6.33	6.29	5.95	6.14	5.79	5.01	4.33	4.18	3.73		
	RadStd		0.27	0.31	0.39	0.40	0.46	0.53	0.48	0.61	0.36	0.22	0.20	0.20		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-1.28	+1.12	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+0.43	+0.56	-1.76	+0.61	N/A	N/A	N/A	-165	+104	+5

Nomenclature: See separate page