

CHENGDU WENJIANG, China

WMO: 561870

Lat: 30.7489N

Lon: 103.8611E

Elev: 555

StdP: 94.83

Time Zone: 8.00 (E08)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.6	0.6	-5.6	2.5	5.8	-3.7	3.0	4.8	4.3	6.5	3.9	7.6	0.8	340	0.303

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	33.2	24.5	32.0	23.8	30.8	23.3	26.1	30.3	25.5	29.4	25.0	28.5	1.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	21.6	27.8	24.6	20.9	27.3	24.0	20.2	26.9	85.2	30.5	82.4	29.4	80.1	28.6	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.2	3.5	3.1	-3.1	35.3	1.4	0.9	-4.1	36.0	-4.9	36.5	-5.7	37.0	-6.7	37.7		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-3.5	27.1	1.4	0.9	-4.5	27.8	-5.4	28.3	-6.2	28.9	-7.2	29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	5.8	8.2	12.9	18.0	21.6	24.3	26.0	26.2	22.2	17.8	12.7	7.3	
	DBStd	7.53	2.33	2.89	3.37	3.24	2.43	2.05	1.93	2.24	2.52	2.47	2.87	2.20	
	HDD10.0	302	131	66	11	0	0	0	0	0	0	9	86		
	HDD18.3	1442	388	285	171	45	3	0	0	2	39	168	341		
	CDD10.0	2843	1	14	100	240	361	428	497	501	366	243	91	3	
	CDD18.3	941	0	0	2	34	106	178	238	242	117	23	0	0	
	CDH23.3	6642	0	0	16	231	623	1190	1958	2031	528	65	0	0	
CDH26.7	2124	0	0	1	44	155	346	677	768	127	7	0	0		
Wind	WSAvg	1.4	1.3	1.4	1.5	1.5	1.6	1.4	1.4	1.3	1.3	1.2	1.1		
Precipitation	PrecAvg	887	9	12	24	51	74	116	216	205	116	41	16	7	
	PrecMax	1365	21	30	52	133	173	234	552	379	244	77	37	17	
	PrecMin	641	0	1	3	9	20	29	76	84	34	16	3	1	
	PrecStd	164	6	9	12	23	34	54	105	76	60	18	8	4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	19.4	25.2	30.1	31.9	32.7	34.3	35.0	31.8	27.6	21.9	15.3	
		MCWB	8.6	11.5	15.7	17.8	20.1	22.0	24.8	24.7	23.5	19.8	15.4	9.4	
	2%	DB	13.1	17.1	22.8	27.9	30.0	31.3	32.8	33.6	29.8	25.1	19.9	13.6	
		MCWB	7.6	10.8	14.5	17.9	19.5	21.9	24.7	24.9	22.0	18.5	14.7	8.8	
	5%	DB	11.2	14.9	20.7	26.1	28.4	30.0	31.7	32.3	28.1	23.2	18.4	12.2	
		MCWB	7.1	9.8	13.8	17.2	19.1	21.9	24.3	24.6	21.5	17.8	14.1	8.3	
	10%	DB	9.8	13.2	18.8	24.2	26.8	28.8	30.4	30.9	26.3	21.5	16.9	11.1	
		MCWB	6.5	9.1	13.1	16.8	19.0	21.9	24.3	24.1	21.1	17.6	13.5	8.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	12.3	17.5	20.9	23.0	25.7	27.1	26.8	25.3	21.5	16.2	11.1
			MCDB	13.4	17.5	22.5	26.5	27.3	28.6	31.5	31.7	29.2	24.5	19.9	13.3
2%		WB	8.7	11.4	15.6	19.2	21.7	24.6	26.2	26.1	24.0	20.1	15.6	10.1	
		MCDB	11.8	15.7	20.3	24.4	26.1	27.5	30.3	30.7	27.2	22.5	18.6	11.9	
5%		WB	7.8	10.5	14.6	18.4	21.0	23.7	25.6	25.6	23.0	19.1	14.9	9.3	
		MCDB	10.1	14.2	18.9	23.5	25.3	27.1	29.3	29.8	25.9	21.7	17.3	11.2	
10%		WB	7.1	9.5	13.7	17.5	20.3	23.0	25.1	25.0	22.0	18.3	14.2	8.6	
		MCDB	9.2	12.7	18.0	22.3	24.5	26.6	28.5	28.8	24.9	20.8	16.4	10.4	
Mean Daily Temperature Range		5% DB	MDBR	6.3	6.7	8.0	8.8	8.3	7.2	7.2	7.6	5.8	5.4	5.8	6.4
			MCDBR	9.7	10.7	12.0	12.5	11.7	10.1	10.2	10.1	8.8	8.7	8.4	8.9
	MCWBR		5.3	5.3	4.6	3.9	3.6	3.2	3.5	3.2	2.5	3.0	3.8	4.9	
	5% WB	MCDBR	8.7	9.5	9.8	10.2	8.7	7.5	8.3	8.7	6.8	6.7	6.8	7.0	
		MCWBR	5.0	4.9	4.1	3.6	3.5	2.9	3.3	3.3	2.7	2.9	3.4	4.1	
Clear-Sky Solar Irradiance	taub	0.663	0.709	0.743	0.733	0.696	0.663	0.691	0.720	0.732	0.735	0.714	0.670		
	taud	1.496	1.450	1.431	1.490	1.599	1.689	1.650	1.583	1.538	1.499	1.485	1.517		
	Ebn at Noon	540	569	595	630	659	679	658	631	596	544	499	506		
	Edh at Noon	246	281	305	297	268	243	252	267	270	263	247	231		
All-Sky Solar Radiation	RadAvg	2.10	2.50	3.19	3.96	4.23	3.96	4.21	4.05	2.94	2.37	2.12	1.98		
	RadStd	0.26	0.34	0.32	0.38	0.48	0.49	0.60	0.55	0.33	0.32	0.16	0.26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.29	N/A	-0.63	+0.45	N/A	N/A	-50	-91	+164	+97

Nomenclature: See separate page