

MIANYANG, China

WMO: 561960

Lat: 31.424N

Lon: 104.749E

Elev: 522

StdP: 95.21

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.6	1.7	-9.4	1.8	7.7	-6.3	2.4	7.7	5.9	7.4	4.8	6.3	1.0	320	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	34.1	24.2	32.9	23.9	31.7	23.4	26.1	31.3	25.6	30.4	25.0	29.5	2.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	21.1	28.9	24.2	20.4	28.3	23.7	19.8	27.8	85.0	31.3	82.5	30.5	79.9	29.7	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.3	4.4	3.7	-1.3	35.9	1.2	0.9	-2.2	36.6	-2.9	37.1	-3.6	37.6	-4.5	38.2		
			-2.3	26.9	1.5	0.7	-3.4	27.4	-4.3	27.8	-5.1	28.2	-6.2	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	6.3	8.9	13.4	18.7	22.5	24.9	27.0	26.8	22.6	18.1	13.1	7.7	(6)
(7)		DBStd	7.68	2.30	2.97	3.58	3.53	2.65	2.37	2.22	2.57	2.77	2.62	2.84	2.27	(7)
(8)		HDD10.0	260	116	52	9	1	0	0	0	0	0	7	75		(8)
(9)		HDD18.3	1359	373	266	158	38	2	0	0	1	36	158	328		(9)
(10)		CDD10.0	3013	2	20	114	261	387	448	528	520	378	252	99	5	(10)
(11)		CDD18.3	1071	0	0	4	48	131	198	269	262	129	29	0	0	(11)
(12)		CDH23.3	8697	0	0	23	290	859	1546	2672	2558	674	74	1	0	(12)
(13)		CDH26.7	3024	0	0	2	67	243	498	1022	1011	175	8	0	0	(13)
(14)	Wind	WSAvg	1.6	1.4	1.5	1.7	1.8	1.9	1.7	1.7	1.5	1.4	1.3	1.3		(14)
(15)	Precipitation	PrecAvg	925	7	10	21	45	83	97	235	218	152	40	17	6	(15)
(16)		PrecMax	1323	26	22	47	132	264	258	461	693	384	86	79	15	(16)
(17)		PrecMin	574	0	0	4	12	29	40	69	54	30	5	1	0	(17)
(18)		PrecStd	216	6	6	11	28	58	52	101	131	90	20	16	4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.0	19.2	25.9	31.0	33.1	34.0	35.6	33.2	27.9	22.0	15.2		(19)
(20)		MCWB	8.3	11.0	15.7	18.6	19.8	22.3	25.3	24.6	23.5	19.1	15.0	9.2		(20)
(21)		2%	DB	12.9	17.1	23.2	28.5	30.9	32.2	33.9	34.3	30.6	25.3	20.1	13.5	(21)
(22)		MCWB	7.5	10.3	14.4	17.7	19.4	22.1	24.9	24.7	22.9	18.4	14.6	8.4		(22)
(23)		5%	DB	11.3	15.3	21.2	26.6	29.3	30.9	32.7	32.9	28.7	23.6	18.5	12.3	(23)
(24)		MCWB	6.7	9.5	13.7	17.1	19.2	22.0	24.6	24.5	21.9	17.9	13.9	8.0		(24)
(25)		10%	DB	10.0	13.6	19.2	24.7	27.7	29.6	31.4	31.5	27.0	22.1	17.1	11.2	(25)
(26)		MCWB	6.2	8.8	12.7	16.7	18.7	21.8	24.4	24.2	21.3	17.5	13.4	7.5		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	12.0	17.7	21.0	22.6	25.2	27.1	26.8	25.8	21.0	16.4	11.2	(27)
(28)		MADB	13.2	17.4	24.9	27.0	27.7	29.2	32.7	32.5	30.6	24.7	19.8	13.3		(28)
(29)		2%	WB	8.2	11.1	15.5	19.3	21.5	24.3	26.3	26.1	24.2	19.9	15.5	10.0	(29)
(30)		MADB	11.7	15.6	20.7	25.4	27.0	28.4	31.4	31.4	28.0	22.8	18.4	11.8		(30)
(31)		5%	WB	7.5	10.2	14.4	18.2	20.7	23.6	25.7	25.5	23.2	19.0	14.9	9.1	(31)
(32)		MADB	10.3	14.2	19.6	24.1	26.1	28.0	30.5	30.6	26.9	22.2	17.3	11.4		(32)
(33)		10%	WB	6.7	9.3	13.5	17.3	20.0	23.0	25.2	25.0	22.1	18.2	14.2	8.3	(33)
(34)		MADB	9.2	12.9	18.3	23.1	25.0	27.5	29.7	29.7	25.6	21.3	16.4	10.4		(34)
(35)	Mean Daily Temperature Range	MDBR	5.4	5.8	6.9	7.9	7.8	6.9	6.7	6.9	5.6	5.2	5.3	5.3		(35)
(36)		5% DB	MADB	8.2	9.0	10.3	11.0	10.8	9.6	9.0	9.1	8.3	7.8	7.8	7.3	(36)
(37)		MCWBR	4.0	3.9	3.8	3.4	3.0	2.6	2.7	2.6	2.3	2.6	3.3	3.6		(37)
(38)		5% WB	MADB	7.1	7.7	8.9	9.2	8.2	7.3	7.6	7.7	6.6	6.2	6.0	5.9	(38)
(39)		MCWBR	3.8	3.7	3.6	3.3	3.1	2.5	2.8	2.8	2.5	2.6	3.1	3.3		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.656	0.708	0.732	0.715	0.674	0.642	0.665	0.694	0.701	0.714	0.699	0.655		(40)
(41)		taud	1.502	1.439	1.435	1.507	1.632	1.728	1.704	1.627	1.589	1.520	1.501	1.530		(41)
(42)		Ebn at Noon	540	565	599	640	673	693	675	646	614	554	504	510		(42)
(43)		Edh at Noon	243	283	302	291	258	234	239	255	255	256	241	226		(43)
(44)	All-Sky Solar Radiation	RadAvg	1.84	2.16	2.99	3.87	4.27	4.07	4.34	4.15	2.90	2.24	1.87	1.73		(44)
(45)		RadStd	0.21	0.37	0.36	0.46	0.50	0.48	0.69	0.60	0.37	0.35	0.21	0.25		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	+0.26	N/A	-0.92	N/A	N/A	N/A	-35	-63	+105	+49

Nomenclature: See separate page