

BATANG, China

WMO: 562470

Lat: 30.0029N

Lon: 99.1077E

Elev: 2589

StdP: 73.85

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -4.7	(c) -3.4	(d) -22.7	(e) 0.7	(f) 6.1	(g) -20.9	(h) 0.8	(i) 6.6	(j) 5.8	(k) 14.7	(l) 5.1	(m) 14.2	(n) 0.5	(o) 160	(p) 0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 12.5	(c) 31.7	(d) 14.9	(e) 30.1	(f) 14.6	(g) 28.6	(h) 14.4	(i) 17.5	(j) 25.1	(k) 16.9	(l) 24.6	(m) 16.5	(n) 23.8	(o) 2.4	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.6	15.3	19.0	15.1	14.8	18.5	14.6	14.3	18.3	61.1	25.5	59.0	24.6	57.3	23.9	20.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.1	5.0	4.2	-7.5	34.7	1.1	1.4	-8.3	35.7	-8.9	36.5	-9.6	37.3	-10.4	38.3
			-10.6	18.7	0.9	0.7	-11.2	19.2	-11.7	19.6	-12.2	20.0	-12.8	20.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	5.9	8.4	11.1	14.4	18.6	21.3	21.0	20.5	18.6	14.6	9.5	5.8
	DBStd	6.19	2.53	2.68	2.44	2.50	3.03	2.97	2.59	2.26	2.52	2.68	2.30	2.30
	HDD10.0	370	129	57	16	2	0	0	0	0	0	1	35	131
	HDD18.3	1860	386	277	224	120	35	7	6	7	26	119	264	388
	CDD10.0	1893	2	13	50	133	266	338	342	327	257	143	21	1
	CDD18.3	340	0	0	0	2	42	95	90	75	33	3	0	0
	CDH23.3	2948	0	1	6	68	519	865	636	504	281	69	1	0
	CDH26.7	855	0	0	0	7	137	317	196	132	62	4	0	0
Wind	WSAvg	1.3	1.3	1.7	1.8	1.7	1.6	1.4	1.0	1.0	0.9	1.1	1.0	1.0
Precipitation	PrecAvg	472	0	1	4	14	32	88	124	99	86	21	2	1
	PrecMax	687	1	6	13	47	100	157	337	211	171	75	24	10
	PrecMin	232	0	0	0	2	2	22	45	18	31	0	0	0
	PrecStd	110	0	1	4	11	21	37	58	52	33	16	5	2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.4	21.9	24.2	27.6	31.7	34.2	33.4	32.0	31.0	27.0	22.2	18.5
		MCWB	5.1	6.1	8.0	10.8	13.5	15.2	16.0	15.4	15.0	12.4	7.9	4.9
	2%	DB	16.6	19.5	21.8	25.2	29.8	32.0	30.9	29.7	28.4	25.2	20.3	16.3
		MCWB	3.7	5.2	7.0	9.7	12.8	14.8	15.9	15.5	14.7	11.8	6.9	4.0
	5%	DB	14.8	17.6	20.1	23.5	28.2	30.2	28.8	28.0	26.6	23.6	18.7	14.7
		MCWB	2.9	4.5	6.3	8.9	12.2	14.5	15.8	15.5	14.5	11.1	6.4	3.3
	10%	DB	13.0	15.8	18.5	21.8	26.4	28.3	26.9	26.2	24.6	21.8	17.0	13.0
		MCWB	2.0	3.7	5.7	8.4	11.7	14.3	15.7	15.4	14.3	10.2	5.7	2.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	6.7	9.0	12.0	15.1	17.7	18.5	18.1	17.1	14.0	9.2	5.5
		MCDB	18.2	19.8	21.0	24.9	27.3	26.2	25.4	25.6	24.8	23.7	19.2	17.0
	2%	WB	4.1	5.6	7.7	10.6	13.8	16.8	17.6	17.3	16.2	13.1	8.0	4.4
		MCDB	15.9	18.0	19.4	22.2	25.7	25.6	25.1	24.6	23.7	22.6	17.7	15.3
	5%	WB	3.0	4.7	6.9	9.8	13.1	16.2	17.0	16.7	15.6	12.3	7.0	3.5
		MCDB	14.1	16.5	18.0	20.7	25.0	24.7	24.7	23.8	22.9	20.8	16.9	13.9
	10%	WB	2.2	4.0	6.1	9.1	12.5	15.6	16.5	16.2	15.0	11.4	6.1	2.7
		MCDB	12.6	15.1	16.9	19.6	23.9	23.7	23.7	23.0	22.0	19.0	15.6	12.4
Mean Daily Temperature Range	5% DB	MDBR	15.9	15.4	14.4	14.1	14.0	12.5	11.4	11.4	12.2	14.9	16.4	16.2
		MCDBR	17.9	18.0	17.3	17.1	16.7	15.7	14.8	14.8	15.7	17.1	18.3	17.8
		MCWBR	9.1	8.7	7.4	6.3	5.3	4.2	3.7	4.1	4.5	6.0	8.3	9.0
	5% WB	MCDBR	17.4	16.9	15.1	15.2	14.4	12.2	11.6	11.4	11.9	14.4	16.7	17.2
		MCWBR	9.0	8.3	6.4	5.7	4.8	3.6	3.6	3.7	4.0	5.2	7.8	8.8
Clear-Sky Solar Irradiance	taub		0.258	0.298	0.374	0.389	0.351	0.337	0.347	0.351	0.320	0.279	0.254	0.242
	taud		2.504	2.395	2.152	2.171	2.390	2.534	2.521	2.492	2.556	2.620	2.598	2.583
	Ebn at Noon		993	971	908	904	936	943	932	929	955	985	994	1001
	Edh at Noon		87	108	147	150	121	105	106	108	97	85	79	77
All-Sky Solar Radiation	RadAvg		4.18	4.83	5.53	5.96	6.20	5.99	5.56	5.42	5.05	4.67	4.29	3.96
	RadStd		0.23	0.30	0.45	0.45	0.39	0.51	0.50	0.51	0.35	0.27	0.25	0.17

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.62	+0.64	-1.62	+1.19	N/A	N/A	-60	-132	+189	+98
(47) Regional (4 neighbors)		+0.51	+0.50	-0.97	+0.77	N/A	N/A	-81	-166	+100	+1

Nomenclature: See separate page