

LITANG, China

WMO: 562570

Lat: 29.9943N

Lon: 100.2708E

Elev: 3950

StdP: 62.04

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.7	-12.9	-27.7	0.5	-3.2	-25.9	0.6	-2.3	9.4	2.9	8.1	4.6	0.3	90	0.652

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	20.0	9.4	18.8	9.1	17.7	8.9	11.2	16.9	10.7	16.1	10.2	15.4	2.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	11.8	13.5	8.7	11.4	13.0	8.2	11.1	12.6	45.7	17.1	43.9	16.2	42.4	15.5	16.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.2	6.1	5.2	-18.4	22.5	2.0	1.3	-19.8	23.4	-21.0	24.1	-22.1	24.8	-23.5	25.8
			-19.5	12.4	1.7	1.0	-20.7	13.2	-21.7	13.7	-22.7	14.3	-23.9	15.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-3.3	-1.6	1.0	4.8	9.0	11.6	12.1	11.8	10.3	6.2	0.8	-2.6	(6)
(7)		DBStd	6.32	3.24	3.00	2.70	2.66	2.99	2.50	2.06	2.01	2.39	3.06	2.74	3.10	(7)
(8)		HDD10.0	2063	411	326	278	157	56	12	6	7	24	121	275	391	(8)
(9)		HDD18.3	4847	669	559	536	407	291	201	194	202	240	374	525	649	(9)
(10)		CDD10.0	258	0	0	0	1	23	62	70	64	34	4	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	1.9	2.1	2.3	2.3	2.1	2.1	1.8	1.5	1.5	1.6	1.7	1.6	1.6	(14)
(15)	Precipitation	PrecAvg	712	1	4	9	20	52	143	181	153	115	32	4	2	(15)
(16)		PrecMax	1096	6	17	24	54	128	249	295	330	203	122	14	14	(16)
(17)		PrecMin	507	0	0	1	2	9	41	96	61	36	0	0	0	(17)
(18)		PrecStd	138	1	5	7	12	32	57	53	59	42	26	4	3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.9	11.8	13.4	17.1	20.7	21.6	20.7	20.8	19.5	17.0	13.3	11.4	(19)
(20)		MCWB	-0.1	0.0	1.7	4.1	7.7	9.3	10.7	9.9	9.3	6.7	1.5	0.0		(20)
(21)		2%	DB	8.6	9.3	10.9	14.5	18.6	20.0	19.2	19.2	17.8	15.3	11.2	8.8	(21)
(22)		MCWB	-1.7	-1.0	0.4	3.1	6.7	9.2	10.4	9.8	8.9	5.7	0.5	-1.4		(22)
(23)		5%	DB	6.2	7.4	9.1	12.7	17.0	18.3	17.9	17.7	16.4	13.9	9.5	6.7	(23)
(24)		MCWB	-2.9	-1.9	-0.4	2.3	6.1	9.0	10.2	9.7	8.5	5.0	-0.1	-2.3		(24)
(25)		10%	DB	4.1	5.5	7.5	11.0	15.3	16.8	16.5	16.3	15.1	12.3	7.9	4.9	(25)
(26)		MCWB	-3.9	-2.8	-1.0	1.7	5.4	8.8	10.0	9.5	8.2	4.3	-0.7	-3.2		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.3	0.7	2.6	5.1	9.1	11.5	12.2	11.7	10.4	8.0	3.1	0.4	(27)
(28)		MCDWB	11.2	9.5	10.6	14.1	17.3	17.9	18.0	17.4	16.7	15.0	9.6	10.1		(28)
(29)		2%	WB	-1.5	-0.7	1.1	4.0	8.0	10.7	11.5	10.9	9.8	7.1	1.6	-1.1	(29)
(30)		MCDWB	7.8	8.0	9.0	12.1	16.3	16.5	17.0	16.5	15.9	13.7	8.9	8.0		(30)
(31)		5%	WB	-2.7	-1.6	0.2	3.1	7.1	10.1	10.9	10.4	9.2	6.2	0.5	-2.1	(31)
(32)		MCDWB	5.7	6.5	7.5	10.6	14.6	15.8	16.2	15.8	14.8	12.1	8.1	6.2		(32)
(33)		10%	WB	-3.8	-2.5	-0.6	2.3	6.4	9.6	10.4	9.9	8.7	5.3	-0.4	-3.1	(33)
(34)		MCDWB	3.6	4.9	6.3	9.5	13.4	15.0	15.3	15.1	13.8	10.5	6.9	4.4		(34)
(35)	Mean Daily Temperature Range	MDBR	14.5	13.7	12.3	11.4	10.9	9.5	8.4	8.7	9.2	11.1	13.7	15.0		(35)
(36)		5% DB	MCDBR	17.4	16.6	14.9	14.0	13.1	11.7	10.7	11.0	10.8	12.5	15.8	17.5	(36)
(37)		MCWBR	9.7	8.9	6.9	5.4	4.4	3.9	3.8	3.9	3.8	4.7	7.4	9.5		(37)
(38)		5% WB	MCDBR	16.5	15.3	12.7	12.2	11.1	9.3	8.5	8.9	9.4	10.5	14.3	16.9	(38)
(39)		MCWBR	9.5	8.4	6.3	4.9	4.2	3.9	3.7	3.7	3.8	4.2	6.8	9.2		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.201	0.225	0.273	0.289	0.276	0.274	0.286	0.288	0.262	0.230	0.206	0.194		(40)
(41)		taud	2.667	2.592	2.438	2.446	2.570	2.679	2.639	2.613	2.701	2.775	2.750	2.735		(41)
(42)		Ebn at Noon	1076	1064	1017	1003	1010	1004	992	993	1018	1046	1063	1075		(42)
(43)		Edh at Noon	73	87	110	114	101	91	94	95	84	72	67	65		(43)
(44)	All-Sky Solar Radiation	RadAvg	4.14	4.72	5.35	5.77	5.90	5.58	5.15	5.04	4.76	4.51	4.20	3.94		(44)
(45)		RadStd	0.21	0.30	0.40	0.33	0.31	0.48	0.42	0.52	0.30	0.27	0.26	0.18		(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.67	+0.92	-1.14	+0.95	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (6 neighbors)	+0.45	+0.47	-1.13	+0.70	N/A	N/A	-76	-162	+117	+7	

Nomenclature: See separate page