

DAOCHENG, China

WMO: 563570

Lat: 29.0426N

Lon: 100.2983E

Elev: 12234

StdP: 9.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.0	9.4	-17.9	3.3	30.6	-14.5	4.0	31.3	22.4	40.6	19.8	42.6	1.5	250	0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	18.9	70.7	49.6	68.5	49.4	66.4	49.2	53.6	64.4	52.8	63.0	52.0	61.7	7.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
50.1	85.8	56.3	49.3	83.1	55.7	48.5	80.7	55.2	27.9	64.8	27.3	63.4	26.7	62.1	61.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.2	14.8	12.8	DB	0.4	75.3	3.0	2.0	-1.7	76.8	-3.5	78.0	-5.1	79.1	-7.3	80.6	(4)
(5)			WB	-1.8	56.0	2.4	1.7	-3.5	57.2	-4.9	58.1	-6.3	59.1	-8.0	60.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.8	26.5	29.8	35.6	42.7	50.4	55.8	55.6	55.2	52.9	44.9	35.3	28.5	(6)	
	DBStd	11.61	4.51	4.89	4.62	4.36	4.96	4.16	3.52	3.29	3.70	4.73	4.38	4.10	(7)	
	HDD50	3326	729	565	446	221	57	6	4	4	16	168	442	668	(8)	
	HDD65	8096	1194	985	911	668	454	276	292	305	363	623	892	1133	(9)	
	CDD50	706	0	0	0	3	68	180	177	164	103	11	0	0	(10)	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH74	8	0	0	0	0	0	6	1	1	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	4.4	4.8	5.4	5.8	5.5	5.3	4.4	3.3	3.3	3.6	4.1	3.9	3.9	(14)	
(15) Precipitation	PrecAvg	24.5	0.0	0.0	0.2	0.6	1.2	4.4	7.4	6.0	3.8	0.8	0.1	0.0	(15)	
	PrecMax	35.5	0.2	0.2	0.4	1.5	3.9	8.3	12.1	12.4	9.2	2.4	0.4	0.2	(16)	
	PrecMin	17.2	0.0	0.0	0.0	0.1	0.2	0.2	3.9	2.2	1.6	0.0	0.0	0.0	(17)	
	PrecStd	4.6	0.0	0.0	0.1	0.4	0.9	1.9	1.9	2.6	1.8	0.6	0.1	0.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	56.0	59.4	65.8	71.9	74.7	72.0	71.2	69.2	64.4	58.4	54.4	(19)	
		MCWB	32.1	33.0	36.8	40.7	46.3	50.0	52.5	51.7	50.2	44.4	36.6	32.9	(20)	
	2%	DB	49.0	51.8	55.1	61.4	68.8	71.3	68.7	67.9	66.3	61.7	54.8	49.8	(21)	
		MCWB	29.7	31.3	34.5	39.1	45.2	49.6	52.2	51.4	49.7	43.8	34.6	30.5	(22)	
	5%	DB	45.0	48.1	51.9	58.3	65.9	68.7	66.2	65.6	63.9	59.3	52.0	46.6	(23)	
		MCWB	27.6	29.8	33.0	37.7	44.3	49.4	52.0	51.1	49.1	42.6	33.4	29.0	(24)	
	10%	DB	41.1	44.4	48.8	55.3	62.8	66.0	63.6	63.1	61.5	56.7	49.1	43.2	(25)	
		MCWB	25.8	28.2	31.6	36.9	43.5	49.2	51.4	50.8	48.6	41.2	32.4	27.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.6	34.0	38.0	42.9	49.5	54.0	54.8	54.3	52.8	47.9	39.5	33.6	(27)	
		MCDB	52.5	52.1	56.3	60.8	64.8	66.0	65.4	65.2	62.8	60.1	51.0	52.4	(28)	
	2%	WB	30.0	31.8	35.6	40.7	47.6	52.9	53.8	53.0	51.4	46.4	36.8	31.1	(29)	
		MCDB	48.0	49.9	52.1	56.6	62.1	64.4	64.4	63.5	61.8	58.3	50.3	48.3	(30)	
	5%	WB	27.9	30.2	34.0	39.1	46.3	51.9	53.0	52.2	50.4	45.0	34.8	29.3	(31)	
		MCDB	44.0	46.8	49.0	54.5	61.3	63.1	62.9	62.1	60.5	55.4	49.5	45.5	(32)	
	10%	WB	26.0	28.6	32.4	37.7	45.0	51.0	52.2	51.4	49.5	43.5	33.1	27.6	(33)	
		MCDB	40.5	43.7	46.6	52.4	59.4	61.7	61.2	60.5	59.1	52.9	47.5	42.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	31.3	29.2	25.7	23.5	21.9	18.9	15.3	15.9	17.3	23.5	28.5	31.9	(35)	
		MCDBR	37.4	35.5	31.1	29.1	27.3	23.6	20.1	20.3	20.7	25.9	32.8	36.4	(36)	
		MCWBR	21.3	18.9	14.8	12.0	9.1	7.1	6.6	6.6	7.1	10.3	15.7	20.1	(37)	
	5% WB	MCDBR	36.0	32.6	26.9	24.6	21.6	18.2	16.3	16.4	17.2	20.1	29.0	35.0	(38)	
		MCWBR	20.6	17.5	13.1	10.6	7.9	6.6	6.3	6.2	6.7	8.3	14.0	19.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.218	0.245	0.303	0.316	0.299	0.296	0.313	0.320	0.289	0.248	0.219	0.205	(40)	
	taud		2.625	2.548	2.372	2.392	2.518	2.613	2.552	2.511	2.591	2.707	2.724	2.720	(41)	
	Ebn at Noon		335	330	313	310	313	312	306	305	314	325	333	337	(42)	
	Edh at Noon		25	30	38	38	34	31	33	34	30	25	22	21	(43)	
(44) All-Sky Solar Radiation	RadAvg		1348	1529	1671	1756	1818	1703	1515	1498	1441	1438	1369	1292	(44)	
	RadStd		77	95	146	141	110	144	123	147	90	97	98	51	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.85	+0.97	N/A	+1.66	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.77	+0.65	-1.19	+1.26	N/A	N/A	-133	-292	+187	N/A

Nomenclature: See separate page