

DAOCHENG, China

WMO: 563570

Lat: 29.0426N

Lon: 100.2983E

Elev: 3729

StdP: 63.85

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.9	-12.5	-27.7	0.5	-0.8	-25.9	0.6	-0.4	10.0	4.8	8.8	5.9	0.7	250	0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	10.5	21.5	9.8	20.3	9.7	19.1	9.5	12.0	18.0	11.5	17.2	11.1	16.5	3.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.1	12.3	13.5	9.6	11.9	13.2	9.2	11.5	12.9	47.1	18.2	45.6	17.4	44.2	16.7	16.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.7	6.6	5.7	-17.6	24.1	1.6	1.1	-18.7	24.9	-19.7	25.5	-20.6	26.2	-21.8	27.0
			-18.8	13.3	1.3	0.9	-19.7	14.0	-20.5	14.5	-21.3	15.0	-22.2	15.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.0	-3.1	-1.2	2.0	6.0	10.2	13.2	13.1	12.9	11.6	7.2	1.8	-2.0		
	DBStd	6.45	2.51	2.71	2.56	2.42	2.76	2.31	1.95	1.83	2.06	2.63	2.43	2.28		
	HDD10.0	1848	405	314	248	123	32	3	2	2	9	93	246	371		
	HDD18.3	4498	663	547	506	371	252	153	162	169	202	346	496	629		
	CDD10.0	392	0	0	0	2	38	100	98	91	57	6	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	4	0	0	0	0	0	3	1	1	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	2.0	2.1	2.4	2.6	2.4	2.3	2.0	1.5	1.5	1.6	1.8	1.7	1.8		
(15) Precipitation	PrecAvg	623	1	1	4	14	30	112	188	153	97	21	3	1		
	PrecMax	901	4	4	10	39	98	212	308	316	234	60	11	5		
	PrecMin	437	0	0	0	2	6	4	99	55	41	0	0	0		
	PrecStd	118	1	1	3	9	22	48	49	66	45	16	3	2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	13.3	15.2	18.8	22.2	23.7	22.2	21.8	20.7	18.0	14.7	12.4		
		MCWB	0.0	0.6	2.6	4.8	8.0	10.0	11.4	10.9	10.1	6.9	2.5	0.5		
	2%	DB	9.4	11.0	12.8	16.3	20.5	21.8	20.4	20.0	19.0	16.5	12.7	9.9		
		MCWB	-1.3	-0.4	1.4	3.9	7.3	9.8	11.2	10.8	9.8	6.5	1.5	-0.8		
	5%	DB	7.2	9.0	11.1	14.6	18.8	20.4	19.0	18.6	17.7	15.2	11.1	8.1		
		MCWB	-2.4	-1.2	0.5	3.2	6.8	9.7	11.1	10.6	9.5	5.9	0.8	-1.6		
	10%	DB	5.1	6.9	9.3	12.9	17.1	18.9	17.5	17.3	16.4	13.7	9.5	6.2		
		MCWB	-3.4	-2.1	-0.2	2.7	6.4	9.5	10.8	10.5	9.2	5.1	0.2	-2.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.3	1.1	3.3	6.1	9.7	12.2	12.7	12.4	11.5	8.9	4.2	0.9		
		MCDB	11.4	11.2	13.5	16.0	18.2	18.9	18.6	18.5	17.1	15.6	10.5	11.4		
	2%	WB	-1.1	-0.1	2.0	4.8	8.6	11.6	12.1	11.7	10.8	8.0	2.7	-0.5		
		MCDB	8.9	9.9	11.2	13.7	16.7	18.0	18.0	17.5	16.6	14.6	10.2	9.1		
	5%	WB	-2.3	-1.0	1.1	3.9	7.9	11.1	11.6	11.2	10.2	7.2	1.5	-1.5		
		MCDB	6.7	8.2	9.5	12.5	16.3	17.3	17.2	16.7	15.9	13.0	9.7	7.5		
	10%	WB	-3.3	-1.9	0.2	3.2	7.2	10.5	11.2	10.8	9.7	6.4	0.6	-2.5		
		MCDB	4.7	6.5	8.1	11.4	15.2	16.5	16.2	15.8	15.1	11.6	8.6	5.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.4	16.2	14.3	13.0	12.2	10.5	8.5	8.8	9.6	13.0	15.8	17.7		
		MCDBR	20.8	19.7	17.3	16.2	15.2	13.1	11.2	11.3	11.5	14.4	18.2	20.2		
	5% WB	MCWBR	11.9	10.5	8.2	6.7	5.1	4.0	3.7	3.7	3.9	5.7	8.7	11.1		
		MCWBR	20.0	18.1	14.9	13.7	12.0	10.1	9.1	9.1	9.6	11.1	16.1	19.4		
(40) Clear-Sky Solar Irradiance	taub		0.218	0.245	0.303	0.316	0.299	0.296	0.313	0.320	0.289	0.248	0.219	0.205		
	taud		2.625	2.548	2.372	2.392	2.518	2.613	2.552	2.511	2.591	2.707	2.724	2.720		
	Ebn at Noon		1055	1041	986	977	987	984	966	961	989	1026	1049	1063		
	Edh at Noon		78	93	119	121	107	97	103	106	94	78	70	67		
(44) All-Sky Solar Radiation	RadAvg		4.25	4.82	5.27	5.54	5.73	5.37	4.78	4.72	4.54	4.53	4.32	4.07		
	RadStd		0.24	0.30	0.46	0.44	0.35	0.46	0.39	0.46	0.28	0.31	0.31	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.47	+0.54	N/A	+0.92	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.43	+0.36	-0.66	+0.70	N/A	N/A	-74	-162	+104	N/A

Nomenclature: See separate page