

EMEI SHAN, China

WMO: 563850

Lat: 29.5214N

Lon: 103.3356E

Elev: 10003

StdP: 10.11

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.2	10.7	-1.5	7.4	32.1	3.1	9.4	27.4	29.5	35.6	26.3	34.1	4.7	320	0.702

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	63.6	55.4	61.7	55.2	59.9	54.7	59.2	61.3	58.1	59.9	57.0	58.5	6.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.4	106.9	60.3	57.4	103.0	59.2	56.4	99.1	58.0	31.3	61.7	30.3	60.1	29.4	58.6	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.7	19.0	16.3	5.4	69.4	3.2	3.2	3.2	71.7	1.3	73.5	-0.5	75.3	-2.8	77.7		
			4.6	62.1	3.1	1.8	2.4	63.5	0.5	64.5	-1.2	65.5	-3.5	66.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.5	23.1	26.6	32.2	39.9	45.2	50.3	54.5	53.5	48.3	40.4	33.9	26.0
	DBStd	12.51	8.52	9.29	8.29	7.61	5.41	4.43	3.33	3.85	5.19	5.87	7.21	7.34
	HDD50	4218	835	655	556	313	166	49	5	14	94	303	484	744
	HDD65	9290	1300	1075	1018	754	613	441	324	358	502	763	933	1209
	CDD50	401	0	0	3	9	17	58	146	121	42	4	1	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.4	7.0	7.2	6.8	6.8	6.4	6.1	5.8	5.8	6.0	5.7	6.5	6.6
Precipitation	PrecAvg	73.3	0.6	0.9	2.1	4.5	6.6	9.1	15.4	18.7	8.5	4.4	1.9	0.7
	PrecMax	98.7	1.5	1.9	3.6	7.4	12.7	17.6	29.1	35.9	16.6	8.8	4.0	1.1
	PrecMin	51.3	0.2	0.3	0.9	2.1	4.3	4.8	6.2	10.0	3.3	1.9	0.9	0.2
	PrecStd	11.7	0.3	0.4	0.8	1.5	1.9	3.5	6.1	6.8	3.7	1.7	0.7	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.5	56.9	60.1	63.4	63.8	64.6	65.4	65.4	63.6	59.1	56.9	53.0
		MCWB	34.3	35.8	40.5	46.0	49.9	55.5	57.5	58.7	56.4	51.0	39.9	34.5
	2%	DB	47.0	51.2	53.9	58.1	58.7	61.1	63.0	62.6	60.2	54.2	51.0	46.4
		MCWB	31.5	34.5	39.1	45.3	49.8	54.5	57.2	57.7	55.4	47.8	39.4	32.4
	5%	DB	41.8	46.0	49.2	53.6	55.3	58.7	61.1	60.6	57.4	50.8	46.8	41.4
		MCWB	30.0	32.4	37.7	44.3	48.8	53.9	56.7	56.6	54.0	47.0	38.9	31.0
	10%	DB	37.1	41.4	44.2	49.9	52.7	56.5	59.4	58.6	55.1	48.0	43.0	37.0
		MCWB	28.4	30.7	36.3	43.6	48.0	52.9	56.0	55.8	52.6	45.5	37.6	29.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.2	37.6	44.5	51.3	54.8	59.7	60.8	60.8	58.7	53.1	44.4	36.5
		MCDB	50.8	52.9	52.5	56.5	57.7	62.1	63.2	63.8	61.4	56.7	50.8	47.7
	2%	WB	32.3	35.3	41.3	48.6	52.6	57.4	59.3	59.0	56.7	50.2	42.1	34.0
		MCDB	44.2	48.3	48.9	52.8	55.3	59.0	61.3	61.1	59.0	52.0	47.2	43.4
	5%	WB	30.5	33.3	39.3	46.6	51.0	55.6	58.2	57.8	55.0	47.8	40.2	31.9
		MCDB	40.6	44.0	45.6	51.0	53.6	57.1	59.9	59.6	56.7	49.7	44.2	39.1
	10%	WB	28.6	31.3	37.3	44.6	49.2	54.0	57.1	56.6	53.3	45.8	38.5	30.2
		MCDB	36.4	39.3	43.0	48.4	51.6	55.5	58.5	58.1	54.6	47.5	41.6	35.8
Mean Daily Temperature Range	5% DB	MDBR	12.6	12.8	11.7	11.2	9.8	8.3	7.8	7.7	7.9	8.1	10.4	11.4
		MCDBR	21.4	21.6	20.4	17.7	13.9	11.6	10.2	10.2	10.8	12.6	16.8	19.4
		MCWBR	10.7	10.2	10.6	10.5	10.9	9.5	8.6	8.3	8.0	8.7	8.4	9.7
	5% WB	MCDBR	19.7	19.6	16.2	13.9	11.7	9.4	8.6	9.3	9.5	10.7	13.5	16.5
		MCWBR	11.1	10.6	10.1	9.7	9.4	7.8	7.2	7.5	6.8	7.9	8.1	9.8
Clear-Sky Solar Irradiance	taub	0.366	0.382	0.410	0.405	0.388	0.375	0.395	0.406	0.406	0.399	0.391	0.371	
	taud	2.100	2.094	2.060	2.142	2.249	2.328	2.266	2.218	2.190	2.136	2.074	2.089	
	Ebn at Noon	269	277	277	282	286	288	282	278	275	267	258	259	
	Edh at Noon	42	47	51	49	44	41	43	45	45	44	43	41	
All-Sky Solar Radiation	RadAvg	610	769	967	1202	1256	1171	1308	1252	883	690	628	551	
	RadStd	94	108	111	133	159	168	168	192	109	99	47	84	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.76	+0.49	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.56	N/A	-1.08	+0.88	N/A	N/A	N/A	-130	+266	+146

Nomenclature: See separate page