

LIJIANG, China

WMO: 566510

Lat: 26.8476N

Lon: 100.2180E

Elev: 2382

StdP: 75.80

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.5	-0.3	-15.8	1.3	11.6	-13.8	1.5	11.4	9.6	12.0	8.7	11.0	1.2	140	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.8	26.4	15.5	25.3	15.6	24.3	15.5	18.1	22.8	17.7	22.1	17.3	21.5	3.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.8	16.1	19.6	16.5	15.8	19.3	16.1	15.4	19.0	62.4	22.9	60.9	22.3	59.5	21.7	20.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.3	6.5	-4.3	28.5	1.2	1.2	-5.2	29.4	-5.9	30.1	-6.6	30.8	-7.5	31.7		
(5)			-5.8	19.1	1.1	0.4	-6.6	19.4	-7.2	19.7	-7.8	19.9	-8.6	20.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	7.6	9.5	11.9	15.0	17.5	19.4	18.9	18.5	17.0	14.6	10.6	7.8		
	DBStd	4.80	2.44	2.62	2.66	2.50	2.87	2.25	1.70	1.50	2.14	2.05	2.25	2.32		
	HDD10.0	227	83	37	12	1	0	0	0	0	1	0	19	75		
	HDD18.3	1698	334	247	201	104	49	14	13	16	46	117	232	326		
	CDD10.0	1706	8	23	69	150	233	283	276	264	212	142	37	8		
	CDD18.3	132	0	0	0	2	24	47	30	21	8	0	0	0		
	CDH23.3	460	0	0	2	13	115	176	69	61	23	2	0	0		
	CDH26.7	26	0	0	0	0	8	14	2	1	0	0	0	0		
(14) Wind	WSAvg	2.8	3.5	4.0	4.0	4.0	3.1	2.5	1.9	1.8	1.9	2.2	2.5	2.8		
(15) Precipitation	PrecAvg	967	2	6	13	18	58	180	237	209	153	69	14	4		
	PrecMax	1212	9	17	48	60	192	418	360	484	315	220	64	35		
	PrecMin	649	0	0	0	2	3	52	98	106	66	2	0	0		
	PrecStd	134	2	5	13	12	42	83	61	81	56	52	15	8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	20.5	22.6	25.0	27.8	28.4	26.5	26.2	25.4	23.5	20.8	18.6		
		MCWB	6.0	6.8	8.5	11.1	13.9	15.8	17.3	17.4	16.6	13.8	9.3	6.4		
	2%	DB	16.9	18.4	20.5	23.1	26.0	26.6	25.0	25.0	23.8	22.1	19.2	16.7		
		MCWB	5.2	6.0	7.9	10.4	13.5	15.7	17.1	17.1	16.3	13.2	8.8	5.6		
	5%	DB	15.1	16.8	19.0	21.7	24.6	25.3	24.0	23.8	22.6	21.0	18.0	15.2		
		MCWB	4.4	5.6	7.5	10.1	13.2	15.8	17.1	16.9	15.9	12.8	8.5	5.3		
	10%	DB	13.5	15.3	17.5	20.3	23.1	24.1	22.7	22.5	21.3	19.8	16.6	14.0		
		MCWB	3.7	5.0	7.1	9.7	12.8	15.8	16.9	16.7	15.7	12.4	8.0	4.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	8.3	10.0	13.0	16.2	18.2	18.7	18.7	17.7	15.7	12.2	8.0		
		MCDB	16.2	16.9	19.1	21.0	21.6	23.0	23.7	24.0	22.3	20.4	15.8	16.1		
	2%	WB	6.1	7.2	9.1	11.9	15.5	17.6	18.2	18.0	17.2	15.1	11.0	7.0		
		MCDB	14.4	15.5	17.8	19.9	21.1	22.5	22.7	22.8	21.7	19.5	15.7	14.2		
	5%	WB	5.1	6.3	8.4	11.1	14.9	17.2	17.7	17.6	16.7	14.4	10.0	6.2		
		MCDB	13.3	14.7	16.7	19.0	20.6	22.0	21.8	21.9	21.0	18.4	15.7	13.3		
	10%	WB	4.3	5.6	7.7	10.4	14.3	16.8	17.4	17.1	16.2	13.8	9.1	5.5		
		MCDB	12.1	13.8	15.7	18.3	19.9	21.5	21.2	21.1	20.0	17.4	14.7	12.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	11.1	10.5	9.7	9.1	7.8	7.0	7.5	7.5	9.9	12.1	12.9		
		MCDBR	14.4	13.4	12.7	11.7	11.4	9.8	9.2	10.0	10.1	11.9	13.8	14.2		
		MCWBR	6.7	5.9	5.1	4.3	3.8	3.2	3.3	3.5	3.8	4.6	5.9	6.5		
		MCDBR	13.0	11.4	10.3	9.9	8.7	7.8	7.5	8.3	8.1	8.7	11.2	13.1		
	5% WB	MCWBR	6.4	5.3	4.5	4.2	3.4	3.1	3.1	3.3	3.3	3.7	5.5	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.260	0.287	0.369	0.378	0.356	0.349	0.364	0.385	0.360	0.314	0.273	0.253		
	taud		2.576	2.509	2.261	2.310	2.450	2.534	2.479	2.394	2.451	2.554	2.610	2.633		
	Ebn at Noon		1007	996	922	920	934	933	918	901	920	954	985	1004		
	Edh at Noon		85	99	135	132	115	105	111	120	110	93	82	77		
(44) All-Sky Solar Radiation	RadAvg		4.26	4.85	5.11	5.16	5.14	4.73	4.28	4.30	3.99	4.13	4.28	4.04		
	RadStd		0.33	0.41	0.55	0.51	0.49	0.43	0.30	0.37	0.30	0.44	0.42	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	+0.47	-0.59	N/A	+0.80	N/A	N/A	-25	-114	+135	+48	
(47) Regional (1 neighbor)	+0.44	N/A	N/A	+0.83	N/A	N/A	-25	-114	+135	+48	

Nomenclature: See separate page