

HUILI, China

WMO: 566710

Lat: 26.6520N

Lon: 102.2424E

Elev: 5866

StdP: 11.84

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 31.3	(c) 33.0	(d) 19.3	(e) 18.1	(f) 62.1	(g) 22.4	(h) 20.9	(i) 56.7	(j) 16.2	(k) 61.6	(l) 14.5	(m) 61.3	(n) 0.8	(o) 180	(p) 0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 13.9	(c) 85.3	(d) 62.9	(e) 83.3	(f) 63.3	(g) 81.5	(h) 63.4	(i) 69.2	(j) 77.6	(k) 68.4	(l) 76.8	(m) 67.8	(n) 76.0	(o) 6.4	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	124.3	71.9	66.2	120.5	71.3	65.4	117.3	71.1	37.4	77.9	36.7	77.3	36.1	76.3	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 13.9	(b) 11.8	(c) 10.0	(e) 27.7	(f) 88.3	(g) 1.6	(h) 2.4	(i) 26.5	(j) 90.1	(k) 25.5	(l) 91.5	(m) 24.6	(n) 92.9	(o) 23.4	(p) 94.6		
			DB	WB	26.0	70.8	1.8	0.9	24.8	71.4	23.7	72.0	22.8	72.5	21.5	73.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.5	47.6	51.7	57.9	64.1	69.1	71.3	71.1	70.8	67.7	62.9	55.0	48.4
	DBStd	9.56	3.19	4.43	4.39	4.54	5.57	4.29	3.00	2.89	4.18	4.33	3.97	3.36
	HDD50	194	85	29	5	0	0	0	0	0	0	0	6	69
	HDD65	2165	538	373	221	66	28	6	2	2	23	91	301	514
	CDD50	4401	12	76	250	424	593	639	655	646	530	401	155	20
	CDD65	897	0	0	2	40	156	195	191	183	103	27	0	0
	CDH74	4693	0	3	77	521	1248	1005	693	731	337	77	1	0
	CDH80	752	0	0	1	59	304	192	72	94	30	0	0	0
(14) Wind	WSAvg	3.6	3.8	4.6	5.1	4.8	4.2	3.2	2.8	2.8	2.7	3.2	3.3	3.2
(15) Precipitation	PrecAvg	44.6	0.2	0.2	0.3	0.7	3.0	9.2	10.6	8.1	7.2	3.9	0.9	0.4
	PrecMax	65.5	1.1	0.8	1.2	2.6	10.1	19.7	19.6	15.9	15.3	9.3	3.0	2.5
	PrecMin	28.7	0.0	0.0	0.0	0.0	0.0	3.3	4.4	2.9	1.8	0.2	0.0	0.0
	PrecStd	9.4	0.3	0.2	0.3	0.7	2.2	4.0	3.5	3.9	3.1	2.4	0.8	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.9	73.8	79.0	84.3	88.6	87.8	84.2	85.3	83.3	78.6	73.0	67.4
		MCWB	47.8	49.3	52.7	56.3	60.8	64.9	67.6	67.0	66.3	62.4	56.0	49.4
	2%	DB	65.3	71.0	76.1	81.8	85.8	84.5	82.0	82.5	80.2	76.2	70.5	64.7
		MCWB	46.7	48.7	51.9	56.1	60.3	65.4	67.3	67.0	65.3	61.2	54.5	48.7
	5%	DB	63.1	68.5	73.9	79.5	83.4	82.0	80.1	80.4	77.9	74.2	68.3	62.4
		MCWB	46.0	48.0	51.4	55.5	60.3	65.6	67.2	66.7	64.3	60.4	53.6	48.0
	10%	DB	60.7	66.0	71.5	77.2	80.9	79.7	78.1	78.3	75.5	72.0	65.9	60.1
		MCWB	45.3	47.3	50.7	55.1	60.0	65.7	67.0	66.3	64.2	59.7	52.8	47.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.4	52.3	56.3	60.7	66.4	69.3	70.6	70.3	68.4	64.8	60.3	52.4
		MCDB	63.3	68.0	72.3	76.6	77.0	78.0	78.3	79.5	78.2	72.7	65.8	62.6
	2%	WB	48.6	50.6	54.4	59.0	65.0	68.4	69.3	69.0	67.0	63.7	57.9	50.5
		MCDB	61.6	66.3	70.3	75.1	76.2	77.4	77.0	78.0	75.6	71.5	65.5	60.9
	5%	WB	47.3	49.3	53.1	57.8	64.0	67.8	68.5	68.2	66.2	62.8	56.1	49.2
		MCDB	60.0	64.8	68.9	73.8	75.4	76.8	76.1	76.9	73.9	70.2	64.7	59.7
	10%	WB	45.9	48.1	52.0	56.6	62.9	67.1	67.8	67.3	65.4	61.8	54.2	48.0
		MCDB	58.2	63.4	68.0	72.5	74.3	75.6	75.3	75.3	72.6	68.7	63.4	58.5
(35) Mean Daily Temperature Range	MDBR		26.3	27.3	25.9	23.7	18.7	13.9	12.8	14.4	13.9	15.5	20.7	23.5
	5% DB	MCDBR	31.1	31.9	30.1	27.8	23.6	18.3	16.8	18.4	18.6	19.6	24.8	28.1
		MCWBR	14.9	13.5	11.0	8.7	6.4	5.1	5.4	5.9	5.7	6.7	10.7	13.7
	5% WB	MCDBR	27.6	28.9	25.9	24.1	17.1	14.1	13.6	15.4	14.7	14.5	19.0	24.1
		MCWBR	14.2	13.2	10.5	8.5	5.4	4.8	5.1	5.6	5.0	5.3	8.8	12.4
(40) Clear-Sky Solar Irradiance	taub		0.315	0.328	0.439	0.453	0.426	0.417	0.434	0.460	0.440	0.405	0.356	0.333
	taud		2.437	2.415	2.060	2.088	2.261	2.337	2.279	2.181	2.217	2.277	2.354	2.393
	Ebn at Noon		298	301	271	270	276	277	272	265	267	271	279	285
	Edh at Noon		31	35	52	52	44	41	43	47	44	39	34	31
(44) All-Sky Solar Radiation	RadAvg		1274	1550	1718	1830	1732	1457	1413	1392	1197	1137	1221	1127
	RadStd		110	148	151	172	191	170	124	146	121	134	151	101

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+1.13	+0.79	-1.75	+1.94	-0.32	-0.95	N/A	N/A	N/A
(47) Regional (7 neighbors)		+0.72	N/A	N/A	+1.53	N/A	N/A	N/A	+200	+95

Nomenclature: See separate page