

HUILI, China

WMO: 566710

Lat: 26.6520N

Lon: 102.2424E

Elev: 1788

StdP: 81.61

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.4	0.5	-7.0	2.6	16.7	-5.3	3.0	13.7	7.2	16.4	6.5	16.3	0.4	180	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.7	29.6	17.1	28.5	17.4	27.5	17.5	20.7	25.3	20.2	24.9	19.9	24.4	2.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	17.8	22.2	19.0	17.2	21.8	18.6	16.8	21.7	69.1	25.5	67.4	25.2	66.0	24.6	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.2	5.3	4.5	DB	-2.4	31.3	0.9	1.4	-3.1	32.3	-3.6	33.0	-4.1	33.8	-4.8	34.8	(4)
			WB	-3.3	21.6	1.0	0.5	-4.0	21.9	-4.6	22.2	-5.1	22.5	-5.8	22.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	8.7	10.9	14.4	17.9	20.6	21.8	21.7	21.6	19.8	17.2	12.8	9.1
	DBStd	5.31	1.77	2.46	2.44	2.52	3.09	2.38	1.67	1.61	2.32	2.40	2.20	1.87
	HDD10.0	108	47	16	3	0	0	0	0	0	0	3	38	
	HDD18.3	1203	299	207	123	37	16	3	1	1	13	51	167	286
	CDD10.0	2445	7	42	139	236	329	355	364	359	294	223	86	11
	CDD18.3	498	0	0	1	22	87	108	106	102	57	15	0	0
	CDH23.3	2607	0	2	43	289	693	558	385	406	187	43	1	0
	CDH26.7	418	0	0	1	33	169	107	40	52	17	0	0	0
Wind	WSAvg	1.6	1.7	2.0	2.3	2.2	1.9	1.4	1.2	1.2	1.2	1.4	1.5	1.5
Precipitation	PrecAvg	1134	6	5	8	18	75	234	268	205	184	98	23	9
	PrecMax	1663	28	20	30	66	256	501	499	404	388	235	76	64
	PrecMin	728	0	0	0	1	1	83	112	73	46	5	0	0
	PrecStd	239	8	4	8	17	55	101	89	100	80	61	21	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.9	23.2	26.1	29.1	31.4	31.0	29.0	29.6	28.5	25.9	22.8	19.7
		MCWB	8.8	9.6	11.5	13.5	16.0	18.3	19.8	19.4	19.0	16.9	13.3	9.7
	2%	DB	18.5	21.6	24.5	27.7	29.9	29.1	27.8	28.1	26.8	24.5	21.4	18.2
		MCWB	8.2	9.3	11.0	13.4	15.7	18.6	19.6	19.4	18.5	16.2	12.5	9.3
	5%	DB	17.3	20.3	23.3	26.4	28.6	27.8	26.7	26.9	25.5	23.4	20.2	16.9
		MCWB	7.8	8.9	10.8	13.1	15.7	18.7	19.6	19.3	18.0	15.8	12.0	8.9
	10%	DB	15.9	18.9	22.0	25.1	27.2	26.5	25.6	25.7	24.2	22.2	18.8	15.6
		MCWB	7.4	8.5	10.4	12.8	15.6	18.7	19.5	19.0	17.9	15.4	11.6	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	11.3	13.5	15.9	19.1	20.7	21.4	21.3	20.2	18.2	15.7	11.3
		MCDB	17.4	20.0	22.4	24.8	25.0	25.5	25.7	26.4	25.7	22.6	18.8	17.0
	2%	WB	9.2	10.3	12.4	15.0	18.4	20.2	20.7	20.6	19.5	17.6	14.4	10.3
		MCDB	16.5	19.1	21.3	24.0	24.6	25.2	25.0	25.6	24.2	22.0	18.6	16.0
	5%	WB	8.5	9.6	11.7	14.4	17.8	19.9	20.3	20.1	19.0	17.1	13.4	9.5
		MCDB	15.6	18.2	20.5	23.2	24.1	24.9	24.5	24.9	23.3	21.2	18.2	15.4
	10%	WB	7.7	8.9	11.1	13.7	17.2	19.5	19.9	19.6	18.5	16.6	12.3	8.9
		MCDB	14.6	17.4	20.0	22.5	23.5	24.2	24.1	24.1	22.6	20.4	17.4	14.7
Mean Daily Temperature Range	5% DB	MDBR	14.6	15.2	14.4	13.2	10.4	7.7	7.1	8.0	7.7	8.6	11.5	13.0
		MCDBR	17.3	17.7	16.7	15.5	13.1	10.1	9.3	10.2	10.3	10.9	13.8	15.6
		MCWBR	8.3	7.5	6.1	4.8	3.5	2.8	3.0	3.3	3.1	3.7	5.9	7.6
	5% WB	MCDBR	15.4	16.1	14.4	13.4	9.5	7.8	7.6	8.6	8.2	8.0	10.6	13.4
		MCWBR	7.9	7.4	5.9	4.7	3.0	2.7	2.8	3.1	2.8	3.0	4.9	6.9
Clear-Sky Solar Irradiance	taub	0.315	0.328	0.439	0.453	0.426	0.417	0.434	0.460	0.440	0.405	0.356	0.333	
	taud	2.437	2.415	2.060	2.088	2.261	2.337	2.279	2.181	2.217	2.277	2.354	2.393	
	Ebn at Noon	938	950	854	851	870	872	857	835	843	854	880	897	
	Edh at Noon	99	109	165	165	139	128	135	148	139	124	107	99	
All-Sky Solar Radiation	RadAvg	4.02	4.89	5.42	5.77	5.46	4.59	4.46	4.39	3.77	3.58	3.85	3.55	
	RadStd	0.35	0.47	0.47	0.54	0.60	0.54	0.39	0.46	0.38	0.42	0.48	0.32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.63	+0.44	-0.97	+1.08	-0.18	-0.53	N/A	N/A	N/A	N/A
Regional (7 neighbors)		+0.40	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	+111	+53

Nomenclature: See separate page