

WEINING, China

WMO: 566910

Lat: 26.8628N

Lon: 104.2803E

Elev: 7336

StdP: 11.20

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.0	24.3	13.1	14.1	49.9	17.0	17.0	44.3	20.2	57.3	17.4	54.5	6.0	20	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	78.0	59.7	76.1	60.1	74.2	60.0	65.4	72.5	64.5	71.4	63.7	70.1	8.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.2	114.5	68.1	62.4	111.4	67.6	61.7	108.5	67.0	34.9	72.9	34.1	71.7	33.4	70.4	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.4	14.0	12.1		18.5	82.3	3.7	2.2	15.8	83.9	13.6	85.1	11.5	86.4	8.8	87.9
				17.5	66.7	3.6	0.9	14.8	67.3	12.7	67.8	10.7	68.3	8.0	68.9
			DB												
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.4	38.3	42.5	48.8	55.9	59.8	62.7	65.5	64.9	60.3	53.8	47.7	39.9
	DBStd	11.64	8.67	10.14	8.86	7.95	6.38	4.77	3.44	3.72	5.55	6.25	6.96	7.26
	HDD50	1263	371	242	132	38	6	0	0	0	2	34	120	318
	HDD65	4402	829	629	503	280	181	98	35	47	156	347	518	779
	CDD50	2508	7	33	94	216	311	382	481	462	313	153	52	4
	CDD65	172	0	0	1	7	21	30	51	45	16	1	0	0
	CDH74	447	0	1	10	67	113	72	76	81	27	0	0	0
	CDH80	14	0	0	0	1	8	3	0	1	1	0	0	0
Wind	WSAvg	6.1	6.3	6.7	7.0	6.9	6.6	5.9	5.6	5.4	5.8	5.7	6.0	6.0
Precipitation	PrecAvg	36.5	0.4	0.4	0.6	1.7	4.2	7.2	7.0	5.6	5.3	2.8	0.9	0.4
	PrecMax	49.7	1.4	1.0	1.3	4.5	8.3	15.4	13.3	11.9	11.9	6.4	2.8	1.5
	PrecMin	21.9	0.1	0.1	0.1	0.1	1.5	3.1	1.7	1.9	1.3	0.7	0.2	0.0
	PrecStd	6.9	0.3	0.3	0.4	1.2	1.9	2.7	2.8	2.6	2.4	1.4	0.7	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.6	70.8	74.9	78.9	80.9	79.5	78.5	78.9	77.3	71.7	68.2	63.4
		MCWB	44.1	46.1	49.1	52.8	57.1	62.3	63.8	62.7	61.7	59.0	50.7	45.0
	2%	DB	61.0	66.9	71.3	76.0	77.1	75.9	76.2	76.3	73.7	69.0	64.5	59.2
		MCWB	42.8	44.5	48.2	52.8	57.4	62.6	63.4	62.6	61.5	57.4	50.6	44.2
	5%	DB	57.3	63.3	68.0	72.8	73.9	73.1	74.1	74.1	71.3	66.3	61.3	55.5
		MCWB	41.9	43.7	47.3	52.6	57.6	62.1	63.1	62.3	60.5	56.6	49.7	43.5
	10%	DB	52.8	59.4	64.0	69.2	70.5	70.6	72.0	71.7	68.9	63.0	58.3	51.3
		MCWB	40.8	42.9	47.0	52.5	57.6	61.8	62.6	62.1	59.8	55.6	49.2	42.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.0	49.1	53.0	59.4	63.9	66.3	66.4	66.1	64.9	61.2	56.3	48.2
		MCDB	58.9	63.6	64.1	68.4	72.7	73.9	73.7	73.9	71.3	68.4	62.4	57.8
	2%	WB	44.7	47.0	51.1	57.1	62.0	65.0	65.4	64.8	63.5	59.5	53.8	46.0
		MCDB	57.1	60.4	62.6	66.2	70.2	71.8	72.4	72.0	69.9	65.8	59.4	55.2
	5%	WB	42.9	45.4	49.7	55.6	60.6	63.9	64.6	63.8	62.3	58.2	51.7	44.5
		MCDB	53.8	58.1	61.4	64.9	67.9	70.1	71.4	70.6	68.6	63.8	58.2	53.0
	10%	WB	41.2	43.8	48.3	54.2	59.3	63.0	63.7	63.0	61.2	56.6	49.7	42.8
		MCDB	51.0	56.2	59.9	64.0	66.2	68.5	69.9	69.0	66.9	61.7	56.2	50.1
Mean Daily Temperature Range	5% DB	MDBR	16.1	17.7	18.9	18.0	15.3	11.6	11.1	11.6	11.5	11.0	13.9	14.5
		MCDBR	25.9	27.1	26.6	23.6	21.2	16.2	14.6	15.4	15.3	16.0	19.6	22.9
		MCWBR	10.5	9.8	8.8	7.1	7.2	6.1	5.1	5.0	5.7	6.2	8.0	10.3
	5% WB	MCDBR	23.5	25.0	22.9	20.5	17.2	13.3	12.2	12.9	13.3	14.1	16.4	20.2
MCWBR		11.2	10.8	9.6	7.6	7.8	6.0	5.1	5.1	5.7	6.8	8.1	10.4	
Clear-Sky Solar Irradiance	taub	0.362	0.378	0.503	0.509	0.458	0.451	0.442	0.466	0.453	0.461	0.415	0.385	
	taud	2.217	2.188	1.829	1.870	2.094	2.171	2.197	2.103	2.114	2.006	2.057	2.123	
	Ebn at Noon	277	283	252	254	267	267	269	263	263	252	255	262	
	Edh at Noon	39	43	66	65	52	48	47	51	49	51	45	41	
All-Sky Solar Radiation	RadAvg	822	1124	1315	1505	1463	1262	1466	1377	1145	858	906	726	
	RadStd	152	215	137	175	154	217	127	150	163	128	119	130	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.88	N/A	N/A	+1.17	+0.72	N/A	N/A	-315	+248	+63
(47)	Regional (5 neighbors)	+0.81	N/A	N/A	+1.30	N/A	N/A	N/A	-189	+221	+86

Nomenclature: See separate page