

WEINING, China

WMO: 566910

Lat: 26.8628N

Lon: 104.2803E

Elev: 2236

StdP: 77.19

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.5	(c) -4.3	(d) -10.5	(e) 2.0	(f) 9.9	(g) -8.3	(h) 2.4	(i) 6.8	(j) 9.0	(k) 14.1	(l) 7.8	(m) 12.5	(n) 2.7	(o) 20	(p) 0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.1	(c) 25.6	(d) 15.4	(e) 24.5	(f) 15.6	(g) 23.4	(h) 15.6	(i) 18.5	(j) 22.5	(k) 18.1	(l) 21.9	(m) 17.6	(n) 21.2	(o) 3.7	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	16.4	20.1	16.9	15.9	19.8	16.5	15.5	19.4	63.3	22.7	61.5	22.1	59.9	21.3	20.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.3	6.3	5.4	-7.5	28.0	2.1	1.2	-9.0	28.8	-10.2	29.5	-11.4	30.2	-12.9	31.1		
			-8.1	19.3	2.0	0.5	-9.5	19.6	-10.7	19.9	-11.8	20.2	-13.3	20.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	3.5	5.9	9.3	13.3	15.5	17.1	18.6	18.3	15.7	12.1	8.7	4.4		
	DBStd	6.46	4.82	5.63	4.92	4.42	3.54	2.65	1.91	2.07	3.09	3.47	3.87	4.04		
	HDD10.0	702	206	134	73	21	3	0	0	0	1	19	67	177		
	HDD18.3	2446	461	349	279	156	101	54	19	26	87	193	288	433		
	CDD10.0	1393	4	18	52	120	173	212	267	257	174	85	29	2		
	CDD18.3	96	0	0	1	4	12	17	28	25	9	1	0	0		
	CDH23.3	248	0	1	6	37	63	40	42	45	15	0	0	0		
	CDH26.7	8	0	0	0	1	4	2	0	1	1	0	0	0		
(14) Wind	WSAvg	2.7	2.8	3.0	3.1	3.1	2.9	2.6	2.5	2.4	2.6	2.5	2.7	2.7		
(15) Precipitation	PrecAvg	928	11	10	15	44	106	182	179	143	135	71	24	10		
	PrecMax	1263	36	26	32	114	212	392	337	301	303	163	71	37		
	PrecMin	555	2	2	3	3	37	79	42	48	32	19	5	1		
	PrecStd	175	7	7	9	30	49	69	71	65	60	35	17	8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.7	21.5	23.8	26.0	27.2	26.4	25.8	26.0	25.2	22.1	20.1	17.4		
		MCWB	6.7	7.8	9.5	11.6	13.9	16.9	17.7	17.1	16.5	15.0	10.4	7.2		
	2%	DB	16.1	19.4	21.8	24.5	25.1	24.4	24.5	24.6	23.2	20.6	18.1	15.1		
		MCWB	6.0	6.9	9.0	11.6	14.1	17.0	17.5	17.0	16.4	14.1	10.3	6.8		
	5%	DB	14.1	17.4	20.0	22.7	23.3	22.9	23.4	23.4	21.8	19.1	16.3	13.0		
		MCWB	5.5	6.5	8.5	11.4	14.2	16.7	17.3	16.9	15.8	13.7	9.8	6.4		
	10%	DB	11.6	15.2	17.8	20.6	21.4	21.4	22.2	22.1	20.5	17.2	14.6	10.7		
		MCWB	4.9	6.1	8.3	11.4	14.2	16.5	17.0	16.7	15.4	13.1	9.6	5.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	9.5	11.7	15.2	17.7	19.1	19.1	19.0	18.3	16.2	13.5	9.0		
		MCDB	14.9	17.5	17.8	20.2	22.6	23.3	23.2	23.3	21.8	20.2	16.9	14.3		
	2%	WB	7.0	8.3	10.6	13.9	16.7	18.3	18.5	18.2	17.5	15.3	12.1	7.8		
		MCDB	13.9	15.8	17.0	19.0	21.2	22.1	22.5	22.2	21.1	18.8	15.2	12.9		
	5%	WB	6.1	7.4	9.8	13.1	15.9	17.7	18.1	17.7	16.9	14.5	11.0	6.9		
		MCDB	12.1	14.5	16.3	18.3	19.9	21.2	21.9	21.4	20.3	17.7	14.6	11.7		
	10%	WB	5.1	6.6	9.1	12.3	15.1	17.2	17.6	17.2	16.2	13.7	9.8	6.0		
		MCDB	10.5	13.4	15.5	17.8	19.0	20.3	21.0	20.6	19.4	16.5	13.5	10.0		
(35) Mean Daily Temperature Range	MDBR		9.0	9.8	10.5	10.0	8.5	6.5	6.1	6.5	6.4	6.1	7.7	8.0		
	5% DB	MCDBR	14.4	15.1	14.8	13.1	11.8	9.0	8.1	8.6	8.5	8.9	10.9	12.7		
		MCWBR	5.8	5.4	4.9	3.9	4.0	3.4	2.8	2.8	3.1	3.5	4.4	5.7		
	5% WB	MCDBR	13.1	13.9	12.7	11.4	9.6	7.4	6.8	7.2	7.4	7.8	9.1	11.2		
		MCWBR	6.2	6.0	5.4	4.2	4.3	3.4	2.8	2.8	3.2	3.8	4.5	5.8		
(40) Clear-Sky Solar Irradiance	taub		0.362	0.378	0.503	0.509	0.458	0.451	0.442	0.466	0.453	0.461	0.415	0.385		
	taud		2.217	2.188	1.829	1.870	2.094	2.171	2.197	2.103	2.114	2.006	2.057	2.123		
	Ebn at Noon		874	891	794	802	842	843	849	829	830	793	803	825		
	Edh at Noon		123	137	208	205	164	151	147	160	154	162	143	130		
(44) All-Sky Solar Radiation	RadAvg		2.59	3.54	4.14	4.74	4.61	3.98	4.62	4.34	3.61	2.71	2.86	2.29		
	RadStd		0.48	0.68	0.43	0.55	0.49	0.69	0.40	0.47	0.52	0.40	0.38	0.41		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.49	N/A	N/A	+0.65	+0.40	N/A	N/A	-175	+138	+35
Regional (5 neighbors)	+0.45	N/A	N/A	+0.72	N/A	N/A	N/A	-105	+123	+48

Nomenclature: See separate page