

BAOSHAN, China

WMO: 567480

Lat: 25.1234N

Lon: 99.1825E

Elev: 5410

StdP: 12.04

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 36.2	(c) 37.9	(d) 25.4	(e) 23.7	(f) 62.6	(g) 28.3	(h) 27.2	(i) 58.2	(j) 16.5	(k) 60.2	(l) 14.5	(m) 61.0	(n) 0.7	(o) 160	(p) 0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.6	83.3	65.7	81.7	65.7	80.2	65.4	69.7	77.9	69.0	76.9	68.3	76.0	6.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.4	123.4	73.1	66.6	120.1	72.3	66.1	118.1	71.9	37.5	78.3	36.8	77.3	36.2	76.3	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.1	12.2	10.6		DB	32.6	86.7	2.3	1.9	30.9	88.1	29.6	89.2	28.3	90.2	26.6	91.6
				WB	31.3	70.9	1.4	1.0	30.3	71.6	29.4	72.2	28.6	72.7	27.6	73.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.4	50.8	54.0	59.5	64.5	69.2	72.2	71.8	72.1	70.2	66.0	58.2	52.3	(6)
	DBStd	8.37	2.62	3.37	3.53	3.20	3.73	2.47	2.51	2.33	3.05	3.46	3.54	2.98	(7)
	HDD50	38	21	6	1	0	0	0	0	0	0	0	0	10	(8)
	HDD65	1612	441	307	174	46	9	0	0	0	5	31	205	394	(9)
	CDD50	4945	45	118	294	435	596	667	676	684	607	496	246	81	(10)
	CDD65	1045	0	0	2	31	139	217	211	219	162	62	2	0	(11)
	CDH74	3956	0	2	66	323	759	763	597	740	512	191	3	0	(12)
	CDH80	371	0	0	1	16	109	89	47	74	30	5	0	0	(13)
(14) Wind	WSAvg	3.3	3.2	3.9	4.0	3.8	3.8	3.8	3.3	2.8	2.8	2.8	2.7	2.7	(14)
(15) Precipitation	PrecAvg	37.8	0.5	1.1	1.3	1.7	2.6	5.7	6.4	6.9	4.9	4.6	1.4	0.7	(15)
	PrecMax	48.9	3.0	2.9	4.1	3.8	6.7	12.6	9.8	11.4	10.8	13.7	5.4	4.1	(16)
	PrecMin	28.8	0.0	0.0	0.0	0.3	0.0	0.7	2.9	3.8	1.5	1.1	0.0	0.0	(17)
	PrecStd	5.3	0.6	0.7	0.9	0.9	1.8	3.2	1.9	2.1	2.3	3.0	1.5	1.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.3	73.7	78.2	81.9	85.8	85.5	83.6	84.4	82.7	80.5	74.2	68.4	(19)
		MCWB	49.9	51.1	53.9	58.6	62.8	65.1	68.6	68.4	66.8	64.3	58.3	51.8	(20)
	2%	DB	65.8	70.6	75.8	79.7	82.9	82.5	81.3	82.0	80.8	78.1	71.9	66.3	(21)
		MCWB	48.7	50.6	53.8	57.9	62.7	66.2	68.5	68.2	66.5	63.1	57.0	51.0	(22)
	5%	DB	63.8	68.2	73.8	77.7	80.7	80.3	79.3	80.1	79.0	76.2	69.9	64.6	(23)
		MCWB	48.1	50.4	53.3	57.4	62.5	66.5	68.1	68.0	66.4	62.5	56.0	50.1	(24)
	10%	DB	61.9	66.0	71.5	75.6	78.4	78.3	77.4	78.2	77.2	74.2	67.9	62.7	(25)
		MCWB	47.5	49.5	52.8	57.1	62.1	66.3	67.7	67.9	66.1	61.6	54.7	49.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.8	54.6	58.0	62.4	67.1	69.3	70.9	70.9	69.6	67.0	62.2	56.0	(27)
		MCDB	63.0	66.7	71.1	74.8	77.0	78.2	78.7	79.5	78.2	74.7	68.3	62.1	(28)
	2%	WB	51.0	53.0	56.5	61.0	66.0	68.4	69.7	69.8	68.3	65.5	60.5	53.7	(29)
		MCDB	61.7	65.3	70.0	73.1	75.3	77.1	77.8	77.9	76.7	73.4	66.9	62.4	(30)
	5%	WB	49.7	51.8	55.4	60.0	65.1	67.7	68.9	69.0	67.5	64.6	58.9	52.1	(31)
		MCDB	60.1	64.5	69.1	72.0	74.0	76.2	76.5	76.9	75.5	72.3	65.2	61.2	(32)
	10%	WB	48.5	50.6	54.3	58.9	64.3	67.1	68.2	68.4	66.9	63.8	57.2	50.8	(33)
		MCDB	58.9	63.5	67.6	70.9	73.0	75.2	75.4	75.8	74.6	70.8	64.7	60.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	23.6	23.9	23.1	20.5	16.0	11.6	10.4	12.1	13.1	15.5	19.8	22.3	(35)
		MCDBR	27.1	27.8	27.6	24.8	20.5	15.7	14.0	15.8	16.4	18.6	21.5	24.1	(36)
	5% WB	MCWBR	12.1	11.5	10.2	8.3	5.8	4.3	4.3	4.7	5.1	6.0	8.3	10.6	(37)
		MCDWR	23.2	23.2	22.1	20.1	14.5	11.9	12.2	13.5	13.8	14.3	15.7	20.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.316	0.357	0.518	0.526	0.445	0.401	0.400	0.430	0.415	0.372	0.324	0.312	(40)
		taud	2.433	2.319	1.835	1.890	2.220	2.425	2.418	2.307	2.326	2.409	2.471	2.477	(41)
	Ebn at Noon		299	292	249	251	271	281	281	273	276	284	294	296	(42)
		Edn at Noon	32	39	66	64	46	37	37	42	40	35	30	30	(43)
(44) All-Sky Solar Radiation	RadAvg		1343	1544	1588	1560	1497	1321	1230	1341	1301	1269	1348	1248	(44)
	RadStd		108	145	176	157	165	122	89	110	106	141	114	96	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.72	N/A	N/A	+0.86	N/A	-0.23	N/A	N/A	N/A	N/A
Regional (6 neighbors)	+0.43	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	+126	+79

Nomenclature: See separate page