

DALI, China

WMO: 567510

Lat: 25.7075N

Lon: 100.1767E

Elev: 1992

StdP: 79.57

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.5	2.6	-7.8	2.5	14.5	-5.9	2.9	13.7	14.2	12.8	11.8	14.2	1.2	250	0.350

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.5	27.6	17.9	26.7	17.8	25.8	17.6	20.1	24.9	19.6	24.3	19.2	23.7	2.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	17.2	22.4	18.2	16.8	21.9	17.9	16.4	21.5	67.9	25.1	66.2	24.5	64.8	24.0	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	7.5	6.3	DB	-0.7	29.3	1.3	1.1	-1.6	30.1	-2.4	30.8	-3.1	31.4	-4.1	32.3	(4)
			WB	-2.0	20.9	1.0	0.5	-2.7	21.2	-3.3	21.5	-3.9	21.8	-4.7	22.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	9.7	11.5	14.3	17.2	19.4	21.0	20.7	20.5	19.3	16.9	13.0	10.0
	DBStd	4.57	2.02	2.26	2.38	2.22	2.44	1.83	1.65	1.51	2.06	2.01	1.97	1.96
	HDD10.0	66	30	9	2	0	0	0	0	0	0	0	1	23
	HDD18.3	1142	269	191	127	46	17	3	3	3	13	52	161	258
	CDD10.0	2309	20	51	134	216	292	331	332	326	279	214	91	24
	CDD18.3	342	0	0	1	11	51	83	76	70	43	8	0	0
	CDH23.3	1188	1	0	4	72	261	317	213	189	117	14	0	0
	CDH26.7	86	0	0	0	2	25	36	12	9	2	0	0	0
Wind	WSAvg	2.4	3.1	3.5	3.5	3.1	2.5	1.9	1.7	1.6	1.6	1.7	2.0	2.3
Precipitation	PrecAvg	1055	14	25	32	24	62	189	181	219	160	99	33	16
	PrecMax	1414	55	68	85	53	166	360	351	360	305	283	177	116
	PrecMin	650	0	0	0	2	1	55	70	106	44	4	0	0
	PrecStd	198	14	20	27	15	45	83	68	72	66	72	38	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.4	21.4	23.9	26.7	28.7	29.3	28.0	27.8	27.0	24.9	21.6	19.3
		MCWB	8.4	8.9	11.0	13.3	16.3	18.4	19.6	19.1	18.8	16.5	12.6	9.4
	2%	DB	17.6	19.8	22.5	25.2	27.3	27.6	26.6	26.5	25.8	23.6	20.2	17.6
		MCWB	7.6	8.8	10.5	12.6	15.9	18.3	19.3	19.2	18.4	16.0	11.9	8.6
	5%	DB	16.2	18.5	21.2	24.0	26.0	26.4	25.6	25.4	24.8	22.5	19.2	16.4
		MCWB	7.1	8.3	10.1	12.2	15.5	18.2	19.3	19.0	18.0	15.4	11.5	8.3
	10%	DB	15.0	17.2	20.0	22.7	24.8	25.2	24.5	24.3	23.7	21.4	18.0	15.3
		MCWB	6.7	7.8	9.7	11.9	15.1	18.3	19.1	18.8	17.7	14.8	10.9	8.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	10.8	12.7	14.9	18.4	20.2	20.7	20.5	19.7	17.8	14.7	11.4
		MCDB	16.5	18.6	20.8	22.5	24.9	25.1	25.7	25.5	25.0	23.1	18.2	16.0
	2%	WB	8.7	9.7	11.7	14.1	17.6	19.7	20.1	19.9	19.1	17.1	14.0	10.0
		MCDB	15.4	17.5	19.8	21.5	23.6	24.7	25.0	24.7	24.1	21.6	17.3	15.7
	5%	WB	7.9	9.0	11.0	13.4	17.1	19.2	19.7	19.5	18.6	16.5	13.0	9.1
		MCDB	14.4	16.9	18.9	21.0	22.8	24.2	24.2	24.0	23.3	20.6	17.1	14.9
	10%	WB	7.2	8.3	10.4	12.8	16.5	18.8	19.2	19.1	18.1	15.9	12.1	8.5
		MCDB	13.6	15.9	18.1	20.4	21.9	23.6	23.4	23.3	22.5	19.5	16.6	14.1
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.1	10.7	10.2	8.9	7.5	6.9	7.3	7.7	8.2	10.2	11.3
		MCDBR	13.2	13.5	13.0	12.6	11.4	9.9	9.2	9.5	9.8	9.9	11.5	12.2
		MCWBR	5.9	5.7	5.1	4.1	3.3	3.1	3.4	3.5	3.5	3.6	4.8	5.4
	5% WB	MCDBR	12.1	12.1	11.1	10.5	8.7	7.9	7.9	8.2	8.4	7.7	9.1	11.4
		MCWBR	6.0	5.6	4.7	3.8	3.0	3.1	3.3	3.4	3.2	3.0	4.3	5.7
Clear-Sky Solar Irradiance	taub	0.287	0.317	0.433	0.440	0.396	0.372	0.385	0.410	0.387	0.345	0.302	0.286	
	taud	2.510	2.435	2.060	2.119	2.351	2.482	2.430	2.335	2.382	2.477	2.529	2.543	
	Ebn at Noon	977	965	862	863	897	912	900	879	896	923	952	964	
	Edh at Noon	92	108	166	160	127	111	116	127	119	102	90	86	
All-Sky Solar Radiation	RadAvg	4.29	4.99	5.24	5.24	5.12	4.71	4.21	4.31	4.10	4.00	4.26	3.97	
	RadStd	0.32	0.44	0.58	0.58	0.52	0.57	0.41	0.25	0.33	0.34	0.47	0.42	0.29

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.41	N/A	N/A	+0.86	N/A	-0.34	N/A	N/A	N/A	N/A
Regional (5 neighbors)		+0.32	N/A	N/A	+0.64	N/A	-0.13	N/A	-53	+91	+42

Nomenclature: See separate page