

CHUXIONG, China

WMO: 567680

Lat: 25.0346N

Lon: 101.5541E

Elev: 1820

StdP: 81.29

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.1	(c) 3.3	(d) -6.1	(e) 2.8	(f) 18.0	(g) -4.4	(h) 3.3	(i) 16.9	(j) 8.7	(k) 16.3	(l) 7.8	(m) 16.9	(n) 0.7	(o) 320	(p) 0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 7.1	(c) 29.1	(d) 16.8	(e) 28.1	(f) 16.8	(g) 27.1	(h) 17.0	(i) 20.0	(j) 24.9	(k) 19.7	(l) 24.4	(m) 19.4	(n) 23.9	(o) 3.7	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 18.7	(b) 17.0	(c) 21.6	(d) 18.4	(e) 16.6	(f) 21.4	(g) 18.1	(h) 16.3	(i) 21.3	(j) 66.7	(k) 25.1	(l) 65.4	(m) 24.6	(n) 64.3	(o) 24.1	(p) 21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.8	6.5	5.5	-0.2	30.9	1.0	1.0	-0.9	31.7	-1.4	32.3	-2.0	32.8	-2.7	33.6
			-0.9	20.7	1.0	0.5	-1.6	21.1	-2.3	21.3	-2.8	21.6	-3.6	22.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	10.4	12.7	16.0	19.2	21.2	22.3	21.8	21.5	20.1	17.8	13.9	10.7
	DBStd	4.78	1.91	2.60	2.64	2.59	2.84	2.07	1.58	1.43	2.06	2.17	2.13	2.11
	HDD10.0	43	17	7	2	0	0	0	0	0	0	0	1	17
	HDD18.3	931	247	157	78	21	10	2	1	1	9	35	134	237
	CDD10.0	2711	28	83	188	276	347	368	364	355	303	243	117	37
	CDD18.3	556	0	0	6	46	99	119	107	97	62	19	0	0
	CDH23.3	2374	0	4	61	324	606	550	339	293	157	38	1	0
CDH26.7	303	0	0	1	36	119	90	28	23	6	0	0	0	
Wind	WSAvg	2.1	2.1	2.5	2.8	2.8	2.4	2.1	1.7	1.5	1.6	1.7	1.7	1.8
Precipitation	PrecAvg	867	16	10	14	20	84	137	192	171	117	69	28	9
	PrecMax	1263	123	45	58	111	306	256	354	335	232	164	116	24
	PrecMin	599	0	0	0	0	6	44	74	92	36	5	0	0
	PrecStd	178	23	11	14	23	66	56	71	61	50	43	28	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.8	24.0	26.2	29.1	30.7	30.5	28.7	28.6	27.5	25.5	23.1	20.5
		MCWB	9.0	10.1	11.5	13.7	16.5	18.1	19.0	19.1	18.5	16.9	13.3	10.8
	2%	DB	19.3	22.2	24.9	27.8	29.2	28.8	27.4	27.2	26.2	24.4	21.5	18.8
		MCWB	8.8	9.9	11.2	13.4	16.0	18.1	19.0	19.0	18.4	16.4	13.1	10.0
	5%	DB	18.1	20.9	23.8	26.5	28.0	27.6	26.4	26.1	25.2	23.4	20.4	17.6
		MCWB	8.5	9.5	11.1	13.1	15.7	18.2	19.1	18.9	18.2	16.2	12.7	9.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	DB	16.7	19.6	22.6	25.3	26.7	26.4	25.3	25.0	24.1	22.3	19.2	16.4
		MCWB	8.2	9.1	10.7	13.0	15.6	18.3	19.0	18.8	18.0	15.9	12.4	9.5
	2%	WB	11.3	12.1	13.7	16.1	19.0	20.2	20.5	20.4	19.7	18.4	16.2	12.7
		MCDB	16.8	20.0	21.3	24.3	24.9	25.3	25.3	25.5	24.7	23.4	19.3	17.4
	5%	WB	10.3	11.2	13.0	15.0	18.3	19.7	20.1	20.0	19.2	17.7	15.1	11.7
		MCDB	16.2	19.4	20.8	23.6	24.1	24.8	24.8	24.9	24.0	22.3	19.0	16.3
Mean Daily Temperature Range	5% DB	WB	9.6	10.4	12.2	14.4	17.7	19.3	19.7	19.6	18.9	17.2	14.2	10.9
		MCDB	15.6	18.7	20.4	22.9	23.5	24.4	24.1	24.1	23.4	21.4	18.0	15.6
	5% WB	WB	8.9	9.8	11.6	13.9	17.2	19.0	19.4	19.2	18.5	16.7	13.4	10.2
		MCWB	14.8	17.9	20.0	22.2	22.8	24.1	23.6	23.4	22.7	20.6	17.5	14.8
Clear-Sky Solar Irradiance	taub	0.314	0.335	0.481	0.472	0.415	0.389	0.407	0.443	0.422	0.390	0.342	0.330	
	taud	2.447	2.391	1.927	2.028	2.306	2.429	2.360	2.233	2.274	2.335	2.412	2.411	
	Ebn at Noon	946	947	819	836	880	897	881	851	864	876	906	910	
	Edh at Noon	100	113	190	176	133	117	125	141	133	118	103	100	
All-Sky Solar Radiation	RadAvg	4.11	5.05	5.35	5.57	5.31	4.80	4.39	4.45	4.04	3.74	4.01	3.61	
	RadStd	0.35	0.49	0.51	0.51	0.65	0.47	0.30	0.34	0.30	0.47	0.43	0.36	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+0.52	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.33	N/A	N/A	+0.80	-0.11	-0.23	N/A	N/A	+70	N/A

Nomenclature: See separate page