

ZHANYI, China

WMO: 567860

Lat: 25.583N

Lon: 103.833E

Elev: 6234

StdP: 11.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.2	32.5	18.6	17.7	58.0	21.8	20.7	57.4	21.2	59.0	18.9	58.4	5.6	0	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	83.0	60.6	81.2	61.2	79.4	61.6	67.7	76.2	67.0	75.1	66.3	74.1	9.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.4	118.8	70.8	64.6	115.5	70.3	63.9	112.5	69.8	36.3	76.5	35.6	75.6	34.9	74.4	70.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	15.8	14.0	25.9	86.6	2.8	1.7	23.8	87.8	22.2	88.8	20.6	89.8	18.6	91.1
			24.1	69.2	2.7	1.1	22.1	70.0	20.6	70.6	19.0	71.2	17.1	72.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.4	48.2	51.4	58.0	64.0	67.3	68.8	69.2	68.6	65.6	60.7	54.3	48.4
	DBStd	9.57	6.87	8.18	6.67	6.28	5.80	4.28	2.89	2.93	4.43	5.05	5.46	6.05
	HDD50	337	112	77	20	2	0	0	0	0	0	2	24	100
	HDD65	2313	522	381	224	89	46	16	4	6	45	145	322	513
	CDD50	4142	55	116	266	423	537	563	596	578	469	335	152	52
	CDD65	643	0	0	6	60	117	129	135	119	64	13	0	0
	CDH74	2714	1	12	93	500	719	478	359	350	177	23	2	0
	CDH80	300	0	0	2	65	134	52	18	23	6	0	0	0
Wind	WSAvg	6.4	7.2	7.8	8.0	7.5	7.0	6.0	5.2	4.9	5.2	5.6	5.8	6.4
Precipitation	PrecAvg	40.3	0.6	0.6	0.7	1.5	4.4	8.3	6.9	7.0	4.6	3.6	1.6	0.5
	PrecMax	53.3	1.7	2.5	2.6	4.7	9.2	13.8	16.2	12.3	10.1	11.3	5.0	2.1
	PrecMin	30.7	0.0	0.1	0.0	0.0	0.6	3.4	3.5	2.4	1.5	1.1	0.3	0.0
	PrecStd	6.8	0.4	0.6	0.7	1.2	2.2	2.7	2.5	3.0	1.9	2.4	1.2	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.0	75.7	79.4	84.4	86.6	84.3	82.1	82.5	80.9	76.6	73.0	68.7
		MCWB	48.0	49.8	52.0	55.8	60.0	64.7	65.4	65.3	64.7	61.4	55.4	49.2
	2%	DB	66.6	71.9	76.7	81.9	83.5	81.3	79.7	80.1	78.3	74.3	70.0	65.5
		MCWB	46.8	48.7	51.5	55.6	59.7	64.9	65.7	65.5	64.4	60.1	54.0	48.5
	5%	DB	64.0	69.3	74.1	79.6	81.0	79.0	77.8	77.8	76.0	72.1	67.5	63.0
		MCWB	46.3	47.9	50.7	55.0	59.9	64.9	65.6	65.1	63.2	59.4	53.2	47.9
	10%	DB	61.1	66.4	71.5	76.9	78.2	76.8	75.8	75.7	73.6	69.6	64.8	59.9
		MCWB	45.6	47.2	50.3	54.5	59.8	64.8	65.4	64.7	62.4	58.7	52.4	47.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.6	53.0	56.1	61.0	66.3	68.4	68.9	68.4	67.2	63.9	59.6	53.0
		MCDB	62.2	67.7	68.9	73.5	76.0	77.3	77.4	77.6	76.0	72.9	67.0	62.5
	2%	WB	49.6	50.9	54.3	59.4	64.8	67.4	67.8	67.3	65.9	62.6	57.5	50.9
		MCDB	60.9	65.9	68.1	72.2	74.0	76.1	75.7	76.0	74.6	70.7	64.6	60.3
	5%	WB	48.0	49.6	53.1	58.0	63.7	66.5	67.0	66.5	65.0	61.5	55.7	49.4
		MCDB	59.4	64.5	67.5	71.3	72.8	74.9	74.5	74.6	73.0	68.4	62.7	58.8
	10%	WB	46.6	48.2	52.0	56.7	62.6	65.8	66.3	65.7	64.0	60.3	54.1	48.2
		MCDB	58.0	62.8	66.3	70.4	71.8	73.6	73.2	73.1	71.2	66.5	61.7	57.3
Mean Daily Temperature Range	5% DB	MDBR	19.2	20.8	21.5	20.4	16.9	12.9	12.0	13.3	13.5	13.2	16.7	17.1
		MCDBR	25.1	26.8	25.9	24.3	21.2	16.9	15.9	17.4	17.2	17.6	21.3	22.8
		MCWBR	9.5	9.4	8.2	6.5	5.4	4.9	5.2	5.5	5.5	5.9	8.2	8.9
	5% WB	MCDBR	22.3	24.6	22.9	21.0	15.7	13.3	12.8	14.4	14.1	13.8	17.3	19.5
		MCWBR	10.3	10.1	8.7	7.0	5.4	5.0	5.0	5.3	5.0	5.6	7.8	8.9
Clear-Sky Solar Irradiance	taub	0.353	0.360	0.500	0.501	0.442	0.441	0.439	0.471	0.454	0.447	0.401	0.381	
	taud	2.295	2.295	1.865	1.930	2.196	2.240	2.239	2.123	2.147	2.105	2.158	2.182	
	Ebn at Noon	284	291	254	257	272	270	271	262	264	258	263	266	
	Edh at Noon	36	39	64	61	47	45	45	50	48	47	42	40	
All-Sky Solar Radiation	RadAvg	1060	1378	1552	1702	1621	1351	1408	1375	1193	989	1085	919	
	RadStd	147	246	150	184	165	172	104	114	133	121	148	135	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.04	N/A	N/A	+1.30	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.77	N/A	N/A	+1.37	N/A	N/A	N/A	N/A	+191	+68

Nomenclature: See separate page