

ZHANYI, China

WMO: 567860

Lat: 25.583N

Lon: 103.833E

Elev: 1900

StdP: 80.49

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	0.3	-7.4	2.5	14.4	-5.6	3.0	14.1	9.5	15.0	8.5	14.7	2.5	0	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	28.4	15.9	27.3	16.2	26.3	16.4	19.8	24.5	19.4	24.0	19.1	23.4	4.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	17.0	21.5	18.1	16.5	21.3	17.7	16.1	21.0	66.4	24.7	64.9	24.2	63.4	23.6	21.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
8.1	7.1	6.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-3.4	30.3	1.6	1.0	-4.5	31.0	-5.4	31.6	-6.3	32.1	-7.5	32.8
			-4.4	20.7	1.5	0.6	-5.5	21.1	-6.4	21.4	-7.2	21.8	-8.3	22.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	9.0	10.8	14.4	17.8	19.6	20.4	20.7	20.4	18.7	16.0	12.4	9.1	(6)
		DBStd	5.31	3.82	4.54	3.70	3.49	3.22	2.38	1.61	1.63	2.46	2.81	3.03	3.36	
		HDD10.0	187	62	43	11	1	0	0	0	0	1	13	56		
		HDD18.3	1285	290	212	124	49	26	9	2	3	25	81	179	285	
		CDD10.0	2301	31	64	148	235	298	313	331	321	261	186	84	29	
		CDD18.3	357	0	0	3	33	65	72	75	66	36	7	0	0	
		CDH23.3	1508	1	7	52	278	399	266	199	194	98	13	1	0	
		CDH26.7	167	0	0	1	36	74	29	10	13	3	0	0	0	
(14)	Wind	WSAvg	2.8	3.2	3.5	3.6	3.4	3.1	2.7	2.3	2.2	2.3	2.5	2.6	2.8	(14)
(15)	Precipitation	PrecAvg	1023	15	15	17	37	112	212	175	178	117	92	40	13	(15)
(16)		PrecMax	1355	44	64	66	120	234	351	412	313	256	286	126	53	(16)
(17)		PrecMin	780	1	2	1	1	14	86	89	62	39	28	7	0	(17)
(18)		PrecStd	172	10	16	18	30	55	68	64	77	48	60	30	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.1	24.3	26.3	29.1	30.3	29.1	27.8	28.0	27.2	24.8	22.8	20.4	(19)
(20)			MCWB	8.9	9.9	11.1	13.2	15.6	18.1	18.6	18.5	18.2	16.3	13.0	9.6	(20)
(21)		2%	DB	19.2	22.2	24.8	27.7	28.6	27.4	26.5	26.7	25.7	23.5	21.1	18.6	(21)
(22)			MCWB	8.2	9.3	10.9	13.1	15.4	18.3	18.7	18.6	18.0	15.6	12.2	9.2	(22)
(23)		5%	DB	17.8	20.7	23.4	26.4	27.2	26.1	25.4	25.5	24.4	22.3	19.7	17.2	(23)
(24)			MCWB	8.0	8.8	10.4	12.8	15.5	18.3	18.7	18.4	17.3	15.2	11.8	8.8	(24)
(25)		10%	DB	16.1	19.1	22.0	25.0	25.7	24.9	24.4	24.3	23.1	20.9	18.2	15.5	(25)
(26)			MCWB	7.6	8.4	10.2	12.5	15.4	18.2	18.5	18.2	16.9	14.8	11.3	8.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	11.7	13.4	16.1	19.0	20.2	20.5	20.2	19.5	17.7	15.3	11.7	(27)
(28)			MCDB	16.8	19.8	20.5	23.0	24.4	25.2	25.2	25.3	24.4	22.7	19.4	16.9	(28)
(29)		2%	WB	9.8	10.5	12.4	15.2	18.2	19.7	19.9	19.6	18.8	17.0	14.2	10.5	(29)
(30)			MCDB	16.0	18.8	20.0	22.3	23.3	24.5	24.3	24.4	23.7	21.5	18.1	15.7	(30)
(31)		5%	WB	8.9	9.8	11.7	14.4	17.6	19.2	19.5	19.1	18.3	16.4	13.2	9.7	(31)
(32)			MCDB	15.2	18.1	19.7	21.8	22.7	23.8	23.6	23.7	22.8	20.2	17.1	14.9	(32)
(33)		10%	WB	8.1	9.0	11.1	13.7	17.0	18.8	19.0	18.7	17.8	15.7	12.3	9.0	(33)
(34)			MCDB	14.4	17.1	19.0	21.3	22.1	23.1	22.9	22.8	21.8	19.2	16.5	14.1	(34)
(35)	Mean Daily Temperature Range	MDBR	10.7	11.6	11.9	11.4	9.4	7.1	6.7	7.4	7.5	7.3	9.3	9.5		(35)
(36)		5% DB	MCDBR	14.0	14.9	14.4	13.5	11.8	9.4	8.8	9.7	9.6	9.8	11.8	12.7	(36)
(37)			MCWBR	5.3	5.2	4.5	3.6	3.0	2.7	2.9	3.0	3.0	3.3	4.6	5.0	(37)
(38)		5% WB	MCDBR	12.4	13.7	12.7	11.7	8.7	7.4	7.1	8.0	7.8	7.7	9.6	10.8	(38)
(39)			MCWBR	5.7	5.6	4.8	3.9	3.0	2.8	2.8	2.9	2.8	3.1	4.3	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.353	0.360	0.500	0.501	0.442	0.441	0.439	0.471	0.454	0.447	0.401	0.381		(40)
(41)		taud	2.295	2.295	1.865	1.930	2.196	2.240	2.239	2.123	2.147	2.105	2.158	2.182		(41)
(42)		Ebn at Noon	894	917	801	811	856	851	853	826	832	814	830	840		(42)
(43)		Edh at Noon	115	124	202	193	148	141	141	158	150	149	132	125		(43)
(44)	All-Sky Solar Radiation	RadAvg	3.34	4.34	4.89	5.37	5.11	4.26	4.44	4.33	3.76	3.12	3.42	2.90		(44)
(45)		RadStd	0.46	0.77	0.47	0.58	0.52	0.54	0.33	0.36	0.42	0.38	0.47	0.43		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.58	N/A	N/A	+0.72	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.43	N/A	N/A	+0.76	N/A	N/A	N/A	N/A	+106	+38

Nomenclature: See separate page