

RUILI, China

WMO: 568380

Lat: 24.0003N

Lon: 97.8456E

Elev: 2503

StdP: 13.41

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	44.8	46.6	39.5	39.0	64.6	41.4	42.1	60.8	9.4	73.1	7.7	72.3	1.1	200	0.236

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.1	90.7	69.7	88.9	70.3	87.4	70.8	76.3	84.7	75.5	83.3	74.9	82.1	6.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.8	138.4	80.0	73.4	136.4	79.1	72.8	133.8	78.5	41.8	85.2	41.1	83.9	40.5	82.6	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.8	8.0	6.9	41.3	94.4	1.6	1.1	40.1	95.2	39.1	95.8	38.2	96.5	37.0	97.3		
			40.3	78.4	1.5	1.5	39.2	79.5	38.3	80.4	37.5	81.2	36.4	82.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	71.9	60.4	64.0	69.7	74.8	77.3	78.1	77.5	78.3	77.7	74.6	68.2	62.1
	DBStd	7.07	2.37	3.18	3.09	3.16	3.02	2.15	2.26	2.39	2.65	3.10	3.41	3.33
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	310	145	50	4	0	0	0	0	0	0	0	9	102
	CDD50	8001	321	393	610	744	847	844	854	877	830	761	545	375
	CDD65	2837	1	23	150	294	382	394	389	412	381	296	104	11
	CDH74	18833	33	336	1340	2478	2908	2589	2235	2623	2314	1503	431	43
	CDH80	5022	0	31	352	955	1039	585	414	639	623	347	37	0
Wind	WSAvg	2.5	1.9	2.4	2.7	3.0	3.1	2.8	2.7	2.8	2.7	2.4	2.0	1.7
Precipitation	PrecAvg	55.1	0.4	0.5	0.7	2.0	6.1	10.4	12.3	9.9	5.9	4.7	2.0	0.4
	PrecMax	77.6	2.3	2.3	2.9	7.1	17.1	18.1	20.9	22.3	10.4	10.9	8.9	1.9
	PrecMin	42.6	0.0	0.0	0.0	0.2	1.0	4.4	6.7	5.7	1.8	1.0	0.0	0.0
	PrecStd	8.3	0.5	0.6	0.7	1.5	3.3	3.2	3.1	3.3	2.2	2.8	2.0	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.3	83.4	88.7	92.6	93.7	90.4	89.0	90.5	90.0	88.5	83.4	77.8
		MCWB	59.4	60.8	62.5	66.0	69.4	73.1	76.0	75.8	73.1	71.9	67.4	63.3
	2%	DB	74.6	80.4	86.0	90.3	90.9	87.5	86.3	87.9	87.9	85.8	80.8	75.0
		MCWB	58.7	60.0	62.7	66.3	69.6	73.8	75.0	75.5	73.5	71.1	66.5	62.0
	5%	DB	72.5	78.2	83.9	88.3	88.4	85.3	84.2	85.9	85.9	83.8	78.8	72.7
		MCWB	58.0	59.3	62.1	66.1	70.0	73.9	74.4	75.1	73.7	70.6	65.6	61.0
	10%	DB	70.1	75.7	81.7	86.0	85.9	83.4	82.2	83.7	83.9	81.7	76.5	70.2
		MCWB	57.2	58.6	61.5	65.9	70.3	73.6	74.0	74.5	73.4	70.2	64.9	60.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.3	63.4	66.8	71.4	74.6	76.4	77.2	77.5	76.3	74.7	71.0	65.7
		MCDB	72.1	78.0	80.9	84.9	84.4	84.9	86.4	87.0	85.1	84.2	78.2	72.8
	2%	WB	60.5	61.8	64.9	69.7	73.6	75.5	75.8	76.4	75.3	73.3	69.3	64.0
		MCDB	70.8	76.1	79.8	83.4	83.2	83.4	83.4	85.0	83.8	81.9	76.1	71.1
	5%	WB	59.2	60.6	63.8	68.5	72.8	74.8	75.1	75.6	74.6	72.4	67.9	62.6
		MCDB	69.2	74.6	78.8	82.1	81.9	82.0	81.9	83.3	82.5	80.1	75.0	70.1
	10%	WB	58.0	59.4	62.7	67.5	72.0	74.3	74.5	74.8	73.9	71.6	66.5	61.1
		MCDB	67.7	73.1	77.4	80.8	80.6	81.0	80.4	81.6	81.1	78.5	73.6	68.5
Mean Daily Temperature Range	5% DB	MDBR	25.4	27.0	26.4	23.0	16.6	11.1	9.4	11.0	13.0	15.6	19.4	21.1
		MCDBR	27.3	29.6	29.4	26.5	21.8	14.5	12.9	14.7	16.3	18.7	21.3	22.6
		MCWBR	12.1	11.0	9.5	7.6	5.9	4.5	4.3	4.9	5.1	6.0	8.0	9.9
	5% WB	MCDBR	24.3	27.0	25.5	22.1	15.7	11.6	11.1	13.1	13.8	14.8	16.7	19.7
		MCWBR	11.3	10.5	8.9	7.2	5.4	4.2	4.2	4.9	5.0	5.1	6.6	9.0
Clear-Sky Solar Irradiance	taub	0.349	0.406	0.630	0.646	0.525	0.462	0.434	0.458	0.459	0.433	0.372	0.345	
	taud	2.378	2.223	1.646	1.680	2.047	2.298	2.375	2.285	2.255	2.292	2.387	2.418	
	Ebn at Noon	288	277	222	222	250	264	272	266	264	266	279	285	
	Edh at Noon	34	43	80	79	55	42	39	43	43	40	34	32	
All-Sky Solar Radiation	RadAvg	1363	1618	1707	1749	1570	1308	1186	1308	1352	1320	1358	1235	
	RadStd	76	101	124	130	169	109	93	95	89	123	96	79	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.74	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.40	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	N/A	+65

Nomenclature: See separate page