

RUILI, China

WMO: 568380

Lat: 24.0003N

Lon: 97.8456E

Elev: 763

StdP: 92.49

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.1	8.1	4.1	5.6	18.1	5.2	6.0	16.0	4.2	22.9	3.4	22.4	0.5	200	0.236

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.1	32.6	21.0	31.6	21.3	30.8	21.6	24.6	29.3	24.2	28.5	23.8	27.8	2.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	19.8	26.7	23.0	19.5	26.2	22.7	19.1	25.9	79.4	29.5	77.7	28.8	76.3	28.1	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.4	3.6	3.1	5.2	34.7	0.9	0.6	4.5	35.1	4.0	35.5	3.4	35.8	2.8	36.3		
			4.6	25.8	0.8	0.8	4.0	26.4	3.5	26.9	3.0	27.3	2.4	27.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.2	15.8	17.8	20.9	23.8	25.2	25.6	25.3	25.7	25.4	23.6	20.1	16.7
	DBStd	3.93	1.32	1.77	1.72	1.75	1.68	1.19	1.26	1.33	1.47	1.72	1.90	1.85
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	172	81	28	2	0	0	0	0	0	0	0	5	57
	CDD10.0	4445	178	218	339	413	471	469	474	487	461	423	303	208
	CDD18.3	1576	1	13	83	163	212	219	216	229	212	164	58	6
	CDH23.3	10463	18	187	744	1377	1616	1438	1242	1457	1286	835	239	24
CDH26.7	2790	0	17	196	531	577	325	230	355	346	193	21	0	
Wind	WSAvg	1.1	0.9	1.1	1.2	1.4	1.4	1.2	1.2	1.3	1.2	1.1	0.9	0.8
Precipitation	PrecAvg	1400	10	12	17	50	154	264	312	252	151	119	51	9
	PrecMax	1970	59	58	74	180	435	461	531	567	263	276	226	49
	PrecMin	1082	0	0	0	4	26	113	170	146	45	26	0	0
	PrecStd	212	13	14	18	37	84	81	80	84	55	71	51	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	28.6	31.5	33.6	34.3	32.4	31.7	32.5	32.2	31.4	28.6	25.4
		MCWB	15.2	16.0	16.9	18.9	20.8	22.8	24.4	24.3	22.8	22.2	19.6	17.4
	2%	DB	23.7	26.9	30.0	32.4	32.7	30.8	30.2	31.0	31.0	29.9	27.1	23.9
		MCWB	14.8	15.5	17.0	19.0	20.9	23.2	23.9	24.2	23.1	21.7	19.1	16.7
	5%	DB	22.5	25.6	28.8	31.3	31.4	29.6	29.0	29.9	30.0	28.8	26.0	22.6
		MCWB	14.4	15.2	16.7	19.0	21.1	23.3	23.6	23.9	23.2	21.4	18.7	16.1
	10%	DB	21.2	24.3	27.6	30.0	29.9	28.6	27.9	28.7	28.9	27.6	24.7	21.2
		MCWB	14.0	14.8	16.4	18.9	21.3	23.1	23.4	23.6	23.0	21.2	18.3	15.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.8	17.4	19.4	21.9	23.7	24.7	25.1	25.3	24.6	23.7	21.7	18.7
		MCDB	22.3	25.5	27.2	29.4	29.1	29.4	30.2	30.5	29.5	29.0	25.7	22.7
	2%	WB	15.8	16.6	18.3	20.9	23.1	24.2	24.3	24.7	24.1	23.0	20.7	17.8
		MCDB	21.6	24.5	26.6	28.6	28.4	28.5	28.6	29.5	28.8	27.7	24.5	21.7
	5%	WB	15.1	15.9	17.7	20.3	22.7	23.8	24.0	24.2	23.6	22.5	20.0	17.0
		MCDB	20.7	23.6	26.0	27.8	27.7	27.8	27.7	28.5	28.0	26.7	23.9	21.2
	10%	WB	14.5	15.2	17.1	19.7	22.2	23.5	23.6	23.8	23.3	22.0	19.2	16.2
		MCDB	19.8	22.8	25.2	27.1	27.0	27.2	26.9	27.6	27.3	25.8	23.1	20.3
Mean Daily Temperature Range	5% DB	MDBR	14.1	15.0	14.7	12.8	9.2	6.1	5.2	6.1	7.2	8.6	10.8	11.7
		MCDBR	15.2	16.4	16.3	14.7	12.1	8.1	7.2	8.2	9.1	10.4	11.9	12.6
		MCWBR	6.7	6.1	5.3	4.2	3.3	2.5	2.4	2.7	2.8	3.4	4.4	5.5
	5% WB	MCDBR	13.5	15.0	14.1	12.3	8.7	6.5	6.2	7.3	7.7	8.2	9.3	10.9
MCWBR		6.3	5.9	4.9	4.0	3.0	2.3	2.3	2.7	2.8	2.8	3.7	5.0	
Clear-Sky Solar Irradiance	taub	0.349	0.406	0.630	0.646	0.525	0.462	0.434	0.458	0.459	0.433	0.372	0.345	
	taud	2.378	2.223	1.646	1.680	2.047	2.298	2.375	2.285	2.255	2.292	2.387	2.418	
	Ebn at Noon	909	874	700	701	789	833	857	839	832	838	878	900	
	Edh at Noon	108	135	253	250	172	133	123	134	136	125	107	101	
All-Sky Solar Radiation	RadAvg	4.30	5.10	5.38	5.51	4.95	4.12	3.74	4.12	4.26	4.16	4.28	3.89	
	RadStd	0.24	0.32	0.39	0.41	0.53	0.34	0.29	0.30	0.28	0.39	0.30	0.25	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.41	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.22	N/A	N/A	+0.43	N/A	N/A	N/A	N/A	N/A	+36

Nomenclature: See separate page