

LINCANG, China

WMO: 569510

Lat: 23.8814N

Lon: 100.0898E

Elev: 1503

StdP: 84.52

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 4.1	(c) 5.1	(d) -2.6	(e) 3.6	(f) 19.7	(g) -1.1	(h) 4.1	(i) 18.8	(j) 6.7	(k) 20.1	(l) 5.7	(m) 19.9	(n) 0.6	(o) 140	(p) 0.256

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 6.6	(c) 29.8	(d) 17.9	(e) 28.8	(f) 17.9	(g) 27.9	(h) 18.0	(i) 21.3	(j) 25.6	(k) 21.0	(l) 25.3	(m) 20.7	(n) 24.6	(o) 2.7	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.1	17.9	22.7	19.8	17.5	22.5	19.6	17.3	22.3	70.0	26.1	68.8	25.5	67.7	24.9	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
5.3	4.4	3.6	DB	1.9	31.9	1.3	1.9	1.0	33.3	0.2	34.4	-0.5	35.5	-1.4	36.9	
			WB	0.7	22.0	1.1	0.5	-0.1	22.3	-0.7	22.6	-1.4	22.8	-2.1	23.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	12.9	14.9	17.7	20.2	21.8	22.8	22.6	22.7	21.8	19.8	16.2	13.3
	DBStd	3.97	1.41	1.78	1.89	1.84	1.96	1.30	1.32	1.27	1.55	1.69	1.82	1.76
	HDD10.0	3	1	1	0	0	0	0	0	0	0	0	0	2
	HDD18.3	539	169	97	33	6	2	0	0	0	2	7	67	157
	CDD10.0	3258	90	137	239	306	367	384	390	395	355	304	187	103
	CDD18.3	752	0	0	13	62	111	134	132	137	107	52	4	0
	CDH23.3	3429	1	36	250	556	673	502	391	487	346	165	23	1
	CDH26.7	522	0	1	17	110	162	79	43	71	34	4	0	0
Wind	WSAvg	1.2	1.1	1.3	1.5	1.5	1.3	1.1	1.0	1.1	1.1	1.0	1.0	1.0
Precipitation	PrecAvg	1161	11	15	16	34	86	201	241	226	149	110	55	17
	PrecMax	1506	49	92	55	84	215	385	362	430	265	216	161	122
	PrecMin	913	0	0	0	2	11	110	131	85	92	29	0	0
	PrecStd	143	13	18	16	19	55	62	64	70	43	51	49	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.1	26.0	28.2	30.5	31.4	30.9	29.3	29.9	29.0	27.2	25.3	22.8
		MCWB	11.3	11.9	13.3	15.1	17.5	19.2	20.5	20.5	19.8	18.2	15.5	12.8
	2%	DB	21.7	24.5	27.1	29.1	29.8	28.7	27.8	28.5	27.6	26.1	24.0	21.4
		MCWB	10.9	11.5	13.1	15.0	17.5	19.6	20.6	20.3	19.4	17.8	14.9	12.1
	5%	DB	20.8	23.2	26.0	28.0	28.5	27.3	26.7	27.3	26.5	25.2	22.9	20.5
		MCWB	10.6	11.3	12.8	14.8	17.5	19.8	20.5	20.3	19.3	17.5	14.5	11.9
	10%	DB	19.5	22.0	24.8	26.7	27.2	26.1	25.5	26.1	25.4	24.1	21.7	19.3
		MCWB	10.3	10.9	12.5	14.7	17.5	19.8	20.4	20.2	19.4	17.5	14.1	11.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	13.6	15.4	17.7	20.4	21.5	21.7	21.7	21.2	20.0	18.0	15.3
		MCDB	18.9	21.3	23.3	23.6	24.9	25.9	26.1	26.6	25.9	25.0	21.5	18.2
	2%	WB	12.3	12.6	14.5	16.9	19.8	21.1	21.3	21.2	20.7	19.3	17.1	13.9
		MCDB	18.7	21.2	22.9	23.9	24.3	25.2	25.5	25.9	25.1	23.7	20.6	18.7
	5%	WB	11.6	12.0	13.9	16.3	19.4	20.7	21.0	20.9	20.3	18.9	16.3	13.1
		MCDB	18.3	20.8	22.3	23.7	23.8	24.6	25.0	25.3	24.4	23.0	19.9	18.2
	10%	WB	10.8	11.4	13.3	15.8	18.9	20.4	20.7	20.6	19.9	18.4	15.5	12.2
		MCDB	17.6	20.0	21.9	23.4	23.3	24.1	24.2	24.6	23.8	22.2	19.4	17.6
Mean Daily Temperature Range	5% DB	MDBR	14.3	14.5	13.7	12.3	9.3	6.6	5.8	6.7	7.3	8.4	11.3	12.7
		MCDBR	16.4	16.5	15.9	14.4	12.5	9.2	8.0	9.0	9.4	10.6	12.9	14.4
	5% WB	MCWBR	6.9	5.8	5.0	4.1	3.4	2.5	2.4	2.7	3.0	3.8	5.2	6.4
		MCWBR	13.9	14.4	12.8	11.3	7.8	6.5	6.3	7.2	7.4	7.7	8.9	11.4
Clear-Sky Solar Irradiance	taub		0.319	0.357	0.542	0.533	0.433	0.394	0.398	0.430	0.417	0.393	0.341	0.326
		taud	2.444	2.340	1.786	1.887	2.276	2.447	2.425	2.306	2.319	2.354	2.433	2.446
	Ebn at Noon		946	927	769	787	865	892	889	863	870	878	912	922
		Edn at Noon	101	120	220	203	137	115	117	132	127	117	102	98
All-Sky Solar Radiation	RadAvg		4.25	5.14	5.24	5.31	4.93	4.31	3.99	4.30	4.16	3.90	4.10	3.76
	RadStd		0.35	0.43	0.45	0.42	0.53	0.41	0.28	0.32	0.30	0.46	0.34	0.35

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	+0.20	N/A	N/A	+0.61	N/A	N/A	N/A	N/A	+96	+59
Regional (7 neighbors)	+0.33	N/A	N/A	+0.53	N/A	N/A	N/A	-44	+144	+105

Nomenclature: See separate page