

JINGHONG, China

WMO: 569590

Lat: 22.0127N

Lon: 100.7822E

Elev: 579

StdP: 94.56

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.9	11.1	5.5	6.0	24.4	7.1	6.7	23.4	4.8	25.4	3.8	26.1	0.5	250	0.247

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.7	35.7	22.2	34.4	22.4	33.2	22.7	25.6	30.9	25.2	30.3	25.0	29.9	2.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.3	20.7	27.2	24.1	20.3	26.8	23.7	19.9	26.6	82.8	31.2	81.3	30.7	80.0	30.1	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.1	3.4	2.9	7.5	38.3	1.8	1.2	6.1	39.1	5.1	39.9	4.0	40.6	2.7	41.4		
			7.2	26.4	1.5	0.8	6.1	27.0	5.3	27.5	4.4	27.9	3.3	28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.1	19.2	21.0	23.2	25.8	26.9	27.4	26.8	26.9	26.4	24.8	21.9	19.2		
	DBStd	3.48	1.77	1.97	1.91	1.97	2.16	1.34	1.47	1.28	1.42	1.67	1.97	2.22		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	35	11	4	1	0	0	0	0	0	0	0	2	17		
	CDD10.0	5159	284	307	410	475	524	522	521	523	493	459	356	285		
	CDD18.3	2152	37	78	153	225	266	272	262	264	243	201	107	43		
	CDH23.3	17655	282	814	1439	2174	2496	2510	2112	2091	1818	1224	511	183		
	CDH26.7	6661	34	281	637	1086	1156	940	689	703	641	385	95	13		
(14) Wind	WSAvg	1.0	0.9	1.0	1.0	1.1	1.2	1.3	1.1	1.0	0.9	0.8	0.7	0.8		
(15) Precipitation	PrecAvg	1172	17	13	21	48	129	166	218	229	138	98	67	22		
	PrecMax	1517	88	60	102	136	315	290	355	374	290	223	213	184		
	PrecMin	876	0	0	0	0	32	43	111	49	52	34	2	1		
	PrecStd	163	20	15	24	32	75	69	66	77	61	52	63	34		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.1	32.8	34.9	37.3	38.0	35.4	34.4	34.0	33.7	32.4	30.3	28.2		
		MCWB	17.8	17.5	18.8	20.3	21.4	24.3	24.7	24.9	24.2	23.6	21.7	20.1		
	2%	DB	27.6	31.2	33.4	35.6	36.0	33.6	32.9	32.7	32.5	31.2	28.9	26.7		
		MCWB	17.8	17.6	18.9	21.2	22.9	24.6	24.6	24.8	24.3	23.3	21.2	19.5		
	5%	DB	26.4	30.0	32.1	34.2	34.2	32.3	31.6	31.6	31.5	30.2	27.8	25.5		
		MCWB	17.7	17.5	19.1	21.5	23.0	24.5	24.6	24.7	24.1	22.9	20.9	18.8		
	10%	DB	25.0	28.5	30.6	32.7	32.3	31.1	30.3	30.4	30.3	29.1	26.5	24.1		
		MCWB	17.4	17.4	19.2	21.5	23.1	24.4	24.5	24.5	24.0	22.7	20.3	18.2		
	0.4%	WB	20.3	20.9	22.7	24.4	25.5	25.9	26.0	26.1	25.7	25.0	23.3	21.9		
		MCDB	25.8	28.8	29.7	31.9	31.9	31.7	31.4	31.4	30.8	30.1	27.6	26.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	19.4	19.7	21.7	23.6	24.8	25.5	25.5	25.5	25.1	24.2	22.6	20.7		
		MCDB	24.8	27.2	28.7	31.2	31.0	30.9	30.4	30.5	30.2	29.1	26.6	24.7		
	5%	WB	18.6	18.9	20.9	22.9	24.3	25.1	25.1	25.1	24.7	23.7	21.9	19.8		
		MCDB	24.0	26.5	28.0	30.5	29.9	30.3	29.6	29.8	29.4	28.2	25.8	23.5		
	10%	WB	18.0	18.1	20.2	22.3	23.8	24.7	24.7	24.7	24.4	23.3	21.2	19.0		
		MCDB	23.2	25.7	27.1	29.6	29.1	29.5	28.7	28.9	28.6	27.2	24.7	22.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	16.2	15.5	13.6	10.1	7.7	6.8	7.4	8.3	8.6	10.0	10.6		
		MCDBR	15.6	18.8	18.6	16.8	13.9	9.7	9.4	9.5	10.1	10.4	11.3	12.0		
		MCWBR	6.3	6.2	5.7	4.6	3.5	2.5	2.4	2.6	2.8	3.2	4.1	4.9		
	5% WB	MCDBR	12.8	15.6	14.2	13.2	9.8	8.1	7.5	8.1	8.5	8.7	9.3	10.2		
		MCWBR	5.6	5.9	5.4	4.6	3.1	2.5	2.4	2.6	2.7	3.0	3.7	4.4		
(40) Clear-Sky Solar Irradiance	taub		0.396	0.467	0.727	0.698	0.484	0.435	0.432	0.467	0.474	0.487	0.416	0.406		
	taud		2.278	2.072	1.494	1.608	2.211	2.386	2.376	2.258	2.215	2.137	2.290	2.275		
	Ebn at Noon		865	821	636	668	823	857	859	834	824	792	838	840		
	Edh at Noon		122	160	297	269	146	122	123	139	142	148	120	119		
(44) All-Sky Solar Radiation	RadAvg		4.09	5.12	5.27	5.67	5.20	4.53	4.11	4.34	4.39	4.02	4.04	3.62		
	RadStd		0.29	0.42	0.33	0.42	0.48	0.36	0.33	0.32	0.25	0.33	0.29	0.32		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.35	N/A	-1.00	+0.53	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.32	N/A	N/A	+0.52	N/A	N/A	N/A	-46	+168	+129

Nomenclature: See separate page