

PU'ER SIMAO, China

WMO: 569640

Lat: 22.795N

Lon: 100.959E

Elev: 4275

StdP: 12.56

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 43.7	(c) 45.7	(d) 32.3	(e) 31.3	(f) 70.4	(g) 35.4	(h) 35.5	(i) 71.2	(j) 9.9	(k) 69.7	(l) 9.1	(m) 69.7	(n) 0.8	(o) 340	(p) 0.227

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.7	87.5	64.0	85.6	64.6	83.9	65.4	72.1	79.4	71.6	78.8	71.0	77.7	5.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.2	130.3	74.8	69.6	127.7	74.3	69.1	125.7	73.9	39.1	80.0	38.5	79.0	37.9	78.2	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	7.7	6.7	DB	39.7	90.7	2.7	2.0	37.7	92.1	36.1	93.2	34.6	94.3	32.6	95.8	
			WB	38.6	74.1	2.7	1.6	36.7	75.3	35.1	76.3	33.6	77.2	31.6	78.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.3	58.7	61.6	66.6	71.5	73.7	74.7	73.7	73.8	72.5	69.6	64.0	59.2
	DBStd	6.60	3.10	3.69	3.68	3.44	3.61	2.30	2.32	2.22	2.77	3.06	3.57	4.05
	HDD50	3	1	0	0	0	0	0	0	0	0	0	0	2
	HDD65	576	196	101	25	3	2	0	0	0	2	5	59	183
	CDD50	6691	270	326	516	645	733	740	735	737	676	607	420	286
	CDD65	1793	0	7	76	199	271	290	270	272	228	147	30	3
	CDH74	8978	5	194	909	1734	1725	1245	904	970	794	414	81	3
(13) CDH80		1777	0	8	153	527	526	214	118	129	86	16	0	0
(14) Wind	WSAvg	2.2	2.1	2.4	2.6	2.7	2.6	2.4	2.1	1.9	2.0	2.0	2.0	1.9
(15) Precipitation	PrecAvg	59.6	0.7	0.6	0.8	1.9	6.0	8.9	12.8	12.8	6.0	5.3	3.0	0.8
	PrecMax	74.3	3.7	1.9	3.7	4.1	11.1	22.8	24.8	24.4	10.0	12.3	12.0	3.6
	PrecMin	44.0	0.0	0.0	0.0	0.0	1.9	3.7	5.2	5.0	2.6	0.9	0.2	0.0
	PrecStd	8.4	0.9	0.5	0.8	1.1	2.6	3.7	5.0	4.3	1.9	2.8	3.0	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.5	81.2	85.6	89.3	90.7	87.5	85.5	85.6	84.5	81.8	78.5	74.3
		MCWB	55.6	56.6	58.0	61.2	63.9	68.8	71.3	70.5	69.5	67.3	63.8	60.5
	2%	DB	72.7	78.6	83.6	87.3	88.0	84.6	83.1	83.2	82.4	79.9	76.4	72.1
		MCWB	55.6	56.1	57.9	61.4	64.6	69.4	70.9	70.4	69.4	66.6	62.7	59.2
	5%	DB	71.0	76.4	81.7	85.5	85.6	82.4	81.0	81.2	80.6	78.3	74.4	70.2
		MCWB	55.5	55.8	57.7	61.5	65.3	69.7	70.7	70.5	68.9	66.3	61.9	58.2
	10%	DB	69.0	74.2	79.5	83.3	82.9	80.4	79.0	79.2	78.7	76.4	72.3	68.2
		MCWB	55.4	55.4	57.7	61.7	65.9	69.9	70.4	70.2	68.8	66.1	61.2	57.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.0	62.4	65.2	68.0	71.0	72.6	73.1	72.9	72.0	70.1	67.2	63.9
		MCDB	67.6	72.2	74.5	77.6	79.5	80.3	80.6	80.7	79.9	77.7	73.4	70.1
	2%	WB	59.3	60.2	63.3	66.6	70.0	71.7	72.0	72.0	71.0	69.1	65.7	62.2
		MCDB	66.4	70.0	72.6	76.4	78.1	79.4	79.0	79.3	78.4	76.0	71.4	68.2
	5%	WB	58.2	58.6	61.9	65.6	69.2	71.0	71.5	71.4	70.4	68.2	64.6	60.5
		MCDB	65.8	69.1	71.5	75.8	76.9	78.2	78.1	78.2	77.2	74.7	70.4	66.6
	10%	WB	57.0	57.3	60.5	64.6	68.5	70.5	70.9	70.8	69.8	67.5	63.5	59.2
		MCDB	65.1	68.3	71.2	75.5	75.8	77.2	76.8	77.0	76.1	73.4	69.1	65.2
(35) Mean Daily Temperature Range	5% DB	MDBR	21.0	24.3	24.0	21.9	16.2	11.7	10.2	11.3	12.2	13.0	16.1	17.3
		MCDBR	24.9	28.6	28.8	26.0	21.9	15.5	14.0	14.7	15.5	16.2	18.8	19.8
		MCWBR	9.6	9.0	7.8	6.2	4.8	4.1	4.4	4.6	4.7	5.0	6.7	7.7
	5% WB	MCDBR	19.1	21.9	20.5	19.5	14.3	11.8	11.6	12.4	12.7	13.0	14.1	15.4
		MCWBR	8.4	8.4	7.6	6.4	4.4	4.0	4.3	4.5	4.5	4.6	5.5	6.5
(40) Clear-Sky Solar Irradiance	taub		0.347	0.390	0.590	0.566	0.426	0.394	0.395	0.425	0.424	0.423	0.365	0.359
	taud		2.380	2.258	1.708	1.831	2.326	2.462	2.443	2.329	2.308	2.272	2.382	2.362
	Ebn at Noon		291	284	233	242	276	283	283	276	275	270	282	282
	Edh at Noon		35	42	76	68	41	36	36	41	41	41	34	34
(44) All-Sky Solar Radiation	RadAvg		1279	1611	1656	1763	1634	1429	1326	1397	1365	1229	1254	1117
(45) RadStd			106	146	118	133	155	115	94	98	87	126	95	107

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	+0.86	N/A	N/A	+0.83	+0.34	N/A	N/A	-92	+315	+234
(47) Regional (7 neighbors)	+0.56	N/A	N/A	+1.04	N/A	N/A	N/A	-79	+259	+189

Nomenclature: See separate page