

YUANJIANG, China

WMO: 569660

Lat: 23.5966N

Lon: 101.9938E

Elev: 398

StdP: 96.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 9.2	(c) 10.7	(d) 3.3	(e) 5.0	(f) 18.1	(g) 4.8	(h) 5.6	(i) 18.3	(j) 10.0	(k) 18.2	(l) 9.1	(m) 17.5	(n) 0.8	(o) 250	(p) 0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	8.3	38.6	22.7	37.4	22.9	36.3	23.2	26.2	32.5	25.8	32.0	25.5	31.6	2.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.8	20.8	28.2	24.5	20.4	28.0	24.1	20.0	27.8	84.5	32.6	82.8	32.3	81.3	31.8	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.4	7.3	6.5	DB	6.2	40.3	2.1	1.1	4.6	41.2	3.4	41.8	2.2	42.5	0.7	43.3	
			WB	5.7	27.0	1.5	0.7	4.6	27.5	3.7	27.9	2.8	28.3	1.7	28.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	18.0	20.5	24.1	27.6	29.1	30.1	29.4	29.0	28.0	25.7	21.8	18.6
	DBStd	4.98	2.49	3.28	2.96	2.88	3.15	2.44	2.08	1.88	2.30	2.47	2.44	2.44
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	85	35	17	2	0	0	0	0	0	0	0	4	27
	CDD10.0	5540	249	293	438	527	593	602	602	589	542	487	353	266
	CDD18.3	2583	26	77	182	277	335	352	343	331	292	228	107	34
	CDH23.3	27818	216	669	1661	3077	4131	4518	4092	3690	3037	1898	641	188
	CDH26.7	13285	49	262	766	1660	2266	2392	1939	1686	1348	722	166	30
Wind	WSAvg	2.3	2.7	3.0	3.0	2.7	2.5	2.3	2.0	1.6	1.7	2.0	1.8	2.3
Precipitation	PrecAvg	782	10	15	17	43	97	124	116	141	80	65	55	21
	PrecMax	1211	55	66	54	120	249	268	266	278	176	186	205	180
	PrecMin	517	0	0	0	0	10	25	32	42	19	15	0	0
	PrecStd	168	12	17	15	34	65	59	52	51	45	46	55	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.4	34.2	36.7	39.4	40.2	39.2	38.7	37.8	37.2	35.1	32.1	29.2
		MCWB	16.9	17.3	18.9	20.5	22.1	24.5	24.8	24.9	24.5	23.2	20.8	18.1
	2%	DB	28.0	32.2	35.1	37.9	38.8	37.7	36.6	36.1	35.5	33.6	30.2	27.4
		MCWB	16.9	17.2	18.8	20.5	22.3	24.4	24.7	24.9	24.3	22.9	20.6	18.1
	5%	DB	25.9	30.2	33.3	36.4	37.2	36.3	35.2	34.7	34.1	32.2	28.7	25.4
		MCWB	16.8	17.4	18.9	20.9	22.7	24.5	24.9	24.9	24.1	22.8	20.2	17.5
	10%	DB	23.6	27.8	31.1	34.5	35.5	34.9	33.7	33.3	32.7	30.7	27.1	23.7
		MCWB	16.2	17.3	19.0	20.9	22.9	24.6	24.9	24.8	23.9	22.5	19.5	16.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.8	19.8	21.7	24.2	25.7	26.6	26.7	26.7	26.1	25.0	23.0	20.2
		MCDB	26.4	29.4	30.6	33.3	33.1	33.1	32.7	33.1	33.0	32.2	29.9	26.0
	2%	WB	17.8	18.9	21.0	23.3	25.0	26.0	26.2	26.1	25.5	24.2	21.9	19.1
		MCDB	25.4	28.2	30.0	31.7	32.6	32.6	32.1	32.4	32.0	30.8	27.3	25.0
	5%	WB	17.1	18.2	20.3	22.7	24.6	25.6	25.7	25.7	25.0	23.6	21.0	18.1
		MCDB	24.3	27.1	29.1	31.1	31.9	32.2	31.5	31.6	31.2	29.8	26.2	24.0
	10%	WB	16.3	17.5	19.7	22.1	24.1	25.2	25.4	25.3	24.6	23.1	20.2	17.2
		MCDB	22.8	26.0	28.3	30.6	31.2	31.8	31.0	30.9	30.4	28.8	25.2	22.8
Mean Daily Temperature Range	5% DB	MDBR	11.2	13.2	13.3	12.6	10.3	8.3	7.8	8.5	8.8	8.9	10.5	10.2
		MCDBR	16.5	18.7	17.7	15.6	13.2	10.4	10.2	10.9	11.1	11.5	13.3	13.8
		MCWBR	6.5	5.9	4.9	4.0	3.0	2.0	2.2	2.3	2.5	3.3	5.0	5.7
	5% WB	MCDBR	14.4	15.3	14.2	12.7	9.9	8.2	8.0	8.8	8.9	9.5	11.0	12.1
		MCWBR	5.9	5.3	4.7	4.0	2.9	2.4	2.4	2.5	2.6	3.2	4.6	5.3
Clear-Sky Solar Irradiance	taub		0.441	0.487	0.735	0.699	0.527	0.474	0.486	0.540	0.536	0.533	0.461	0.464
	taud		2.147	2.016	1.496	1.619	2.088	2.276	2.225	2.049	2.037	2.007	2.155	2.076
	Ebn at Noon		808	796	627	665	788	824	814	772	767	745	783	764
	Edh at Noon		138	167	295	265	165	136	143	170	169	167	136	143
All-Sky Solar Radiation	RadAvg		3.87	4.96	5.22	5.60	5.27	4.57	4.34	4.42	4.17	3.60	3.84	3.35
	RadStd		0.38	0.54	0.43	0.45	0.57	0.40	0.29	0.27	0.22	0.43	0.31	0.37

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.46	N/A	N/A	+0.92	-0.40	-0.52	N/A	N/A	N/A	N/A
Regional (6 neighbors)	+0.30	N/A	N/A	+0.64	N/A	N/A	N/A	N/A	+129	+87

Nomenclature: See separate page