

MENGLA, China

WMO: 569690

Lat: 21.4746N

Lon: 101.5780E

Elev: 2077

StdP: 13.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.3	50.5	42.4	43.2	69.1	45.7	49.0	65.3	11.3	77.2	9.6	77.0	1.5	160	0.236

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.6	93.8	71.5	91.7	72.0	90.0	72.3	77.4	84.8	76.9	84.4	76.3	83.5	5.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.7	145.4	79.6	75.1	142.4	79.3	74.5	139.6	78.8	42.8	84.9	42.2	84.8	41.6	83.9	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	7.8	6.8	DB	44.9	97.2	3.1	2.2	42.7	98.7	40.8	100.0	39.1	101.2	36.8	102.8	(4)
			WB	44.4	78.6	3.1	1.0	42.1	79.3	40.3	79.9	38.5	80.5	36.2	81.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.3	65.8	68.1	72.6	77.4	79.2	79.9	78.9	79.0	78.4	75.7	70.6	65.9
	DBStd	6.15	3.52	4.26	3.89	3.42	3.28	2.09	2.29	2.19	2.41	3.02	3.81	4.28
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	103	32	20	5	0	0	0	0	0	0	0	5	41
	CDD50	8881	491	508	700	822	906	898	896	899	851	797	619	494
	CDD65	3510	58	108	240	372	441	448	431	434	401	332	175	70
	CDH74	24592	383	1026	1956	3015	3610	3529	2891	2786	2529	1793	798	276
	CDH80	8469	39	335	840	1411	1548	1198	813	807	793	510	153	22
Wind	WSAvg	2.4	2.2	2.6	2.4	2.6	2.8	2.8	2.5	2.5	2.4	2.3	2.1	2.0
Precipitation	PrecAvg	59.9	1.0	0.9	1.3	3.7	6.9	8.7	11.7	12.5	6.1	3.8	2.2	1.0
	PrecMax	76.5	4.4	3.8	5.2	8.0	14.8	13.5	21.5	20.0	12.7	9.0	7.6	4.8
	PrecMin	47.5	0.0	0.0	0.0	0.7	2.0	4.9	3.6	6.9	1.6	0.5	0.2	0.0
	PrecStd	7.7	1.1	0.9	1.1	1.9	2.8	2.7	4.0	3.5	2.9	2.0	2.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.3	89.5	92.9	96.7	97.7	93.6	91.8	91.5	90.9	89.1	86.4	82.8
		MCWB	63.2	63.6	66.2	68.9	71.8	74.6	75.7	75.7	74.7	73.3	70.3	68.3
	2%	DB	81.0	87.0	90.6	94.1	93.9	90.6	89.0	88.9	88.8	87.2	84.1	79.8
		MCWB	63.7	63.6	66.0	70.3	72.7	75.2	75.7	75.8	74.5	72.7	69.6	66.5
	5%	DB	78.6	84.5	88.5	91.6	91.1	88.5	86.9	86.8	87.0	85.3	81.7	77.4
		MCWB	63.8	63.9	66.3	71.0	73.4	75.2	75.8	75.6	74.3	72.2	69.0	65.7
	10%	DB	75.7	81.4	85.5	88.8	88.4	86.4	84.6	84.7	84.9	83.0	79.1	74.5
		MCWB	63.4	63.6	66.8	71.2	73.8	75.1	75.5	75.4	74.2	71.7	67.6	64.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.3	69.6	72.9	75.7	77.3	78.2	78.3	78.3	77.4	75.8	73.5	71.0
		MCDB	76.6	81.9	83.2	86.8	86.5	85.3	85.1	85.4	84.3	83.9	81.4	78.3
	2%	WB	66.7	67.8	71.0	74.5	76.3	77.2	77.3	77.2	76.5	74.7	72.0	68.9
		MCDB	75.2	78.8	82.3	85.7	85.4	84.9	84.5	84.3	83.8	82.4	79.2	75.8
	5%	WB	65.4	66.3	69.8	73.5	75.5	76.5	76.5	76.5	75.8	73.9	70.8	67.4
		MCDB	73.9	77.9	81.0	84.4	84.5	83.9	83.3	83.2	82.8	81.1	77.6	74.0
	10%	WB	64.0	64.8	68.4	72.4	74.7	75.9	76.0	75.9	75.1	73.2	69.5	65.8
		MCDB	72.5	76.0	79.4	83.2	83.4	83.0	82.2	82.0	81.8	79.8	75.8	72.0
Mean Daily Temperature Range	5% DB	MDBR	22.0	27.3	26.5	23.1	17.9	13.6	11.6	12.3	14.3	15.6	18.1	18.6
		MCDBR	26.8	33.0	31.9	27.9	23.4	17.5	15.6	15.9	17.2	18.5	20.5	21.2
		MCWBR	10.6	11.2	9.6	7.2	5.7	4.3	4.5	4.6	4.9	5.7	7.3	8.5
	5% WB	MCDBR	22.1	27.0	25.2	23.1	17.8	13.9	13.3	13.4	14.5	15.5	17.0	18.4
	MCWBR	9.6	10.6	9.2	7.5	5.5	4.4	4.6	4.7	4.8	5.3	6.6	7.8	
Clear-Sky Solar Irradiance	taub	0.428	0.513	0.784	0.768	0.494	0.443	0.440	0.476	0.492	0.518	0.436	0.430	
	taud	2.177	1.932	1.405	1.485	2.171	2.354	2.347	2.224	2.150	2.032	2.216	2.184	
	Ebn at Noon	264	247	191	198	258	269	271	262	257	243	260	258	
	Edh at Noon	43	59	103	96	48	40	40	45	48	52	41	42	
All-Sky Solar Radiation	RadAvg	1234	1571	1660	1831	1662	1428	1297	1385	1419	1305	1281	1123	
	RadStd	98	164	119	162	167	118	124	115	70	80	100	99	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.13	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.56	N/A	N/A	+1.01	N/A	N/A	N/A	-92	+315	+234

Nomenclature: See separate page