

BAOJI, China

WMO: 570160

Lat: 34.3524N

Lon: 107.1289E

Elev: 610

StdP: 94.21

Time Zone: 8.00 (E08)

Period: 94-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.7	-4.4	-16.2	1.0	1.7	-13.9	1.2	2.3	6.2	3.2	5.4	3.1	0.5	290	0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	35.3	21.6	34.0	21.4	32.6	21.4	24.9	31.1	24.1	30.2	23.3	29.1	3.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	19.3	28.4	22.4	18.4	27.5	21.6	17.5	26.9	79.9	31.3	76.4	30.3	73.3	29.1	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.2	5.2	4.4	-9.2	38.4	1.6	1.1	-10.4	39.2	-11.3	39.8	-12.2	40.5	-13.4	41.3		
			DB													
			WB	-10.2	26.1	1.4	0.8	-11.2	26.7	-12.0	27.1	-12.7	27.6	-13.7	28.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	1.3	4.4	9.5	15.2	20.7	24.8	27.0	25.1	20.1	14.1	8.0	2.5
	DBStd	9.46	3.02	3.13	4.01	4.28	3.43	3.21	2.70	2.83	3.61	3.38	3.49	3.02
	HDD10.0	811	271	159	57	7	0	0	0	0	0	6	80	233
	HDD18.3	2282	529	391	274	111	17	1	0	0	21	137	310	491
	CDD10.0	2433	0	1	41	164	333	443	527	468	304	132	20	0
	CDD18.3	862	0	0	1	18	91	194	269	211	74	5	0	0
	CDH23.3	8147	0	0	13	184	801	1934	2872	1812	491	40	1	0
	CDH26.7	3379	0	0	1	46	268	873	1342	684	161	4	0	0
Wind	WSAvg	1.4	1.1	1.2	1.6	1.6	1.6	1.8	1.6	1.2	1.0	1.0	1.0	1.0
Precipitation	PrecAvg	690	6	10	27	60	66	65	119	110	131	68	24	5
	PrecMax	951	17	32	85	125	182	142	263	411	288	180	65	23
	PrecMin	431	0	0	0	16	11	6	23	17	27	12	2	0
	PrecStd	138	5	9	17	28	39	41	60	84	65	43	18	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.6	16.5	25.1	30.3	34.3	37.1	37.4	35.7	34.4	26.7	21.2	14.2
		MCWB	5.7	7.3	11.9	16.8	17.9	19.8	22.1	22.9	21.4	14.7	11.6	6.5
	2%	DB	10.9	14.4	21.4	27.6	31.5	35.1	35.3	33.6	30.8	24.1	18.5	11.7
		MCWB	3.8	6.1	10.9	15.9	17.5	20.4	22.4	22.3	21.3	14.9	10.8	5.1
	5%	DB	7.9	12.1	18.7	25.3	29.5	33.4	34.1	31.9	28.3	21.7	15.9	9.5
		MCWB	1.9	5.3	9.9	14.9	16.8	20.0	22.5	22.2	20.4	14.2	9.5	3.8
	10%	DB	6.0	10.1	16.3	22.9	27.7	31.7	32.7	30.3	25.9	19.6	13.5	7.7
		MCWB	0.9	4.3	8.8	13.6	16.8	19.6	22.5	22.3	19.1	13.8	8.4	2.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	8.0	14.2	19.7	20.7	23.7	26.1	25.6	24.1	17.6	13.1	7.0
		MCDB	14.4	14.7	22.0	25.3	28.0	31.8	32.7	31.7	30.3	22.2	19.3	12.8
	2%	WB	3.9	6.9	11.8	17.8	19.6	22.7	25.1	24.7	22.5	16.7	11.4	5.6
		MCDB	10.5	12.7	19.3	24.0	26.7	30.1	31.4	30.9	28.1	20.0	16.5	10.3
	5%	WB	2.3	5.9	10.6	16.0	18.6	21.8	24.3	23.9	21.4	15.6	10.1	4.4
		MCDB	7.0	10.7	17.0	23.2	26.2	29.0	30.8	29.2	26.6	19.7	14.4	8.5
	10%	WB	1.3	5.0	9.4	14.7	17.7	21.1	23.6	23.2	20.2	14.6	9.1	3.3
		MCDB	5.2	9.4	15.1	21.2	24.9	28.0	30.0	28.0	24.7	18.4	13.0	6.9
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.3	9.0	9.3	10.2	10.0	8.8	7.7	7.3	7.7	8.1	7.4
		MCDBR	12.1	12.2	14.0	14.3	14.3	13.8	11.6	10.9	11.4	11.8	12.3	11.6
		MCWBR	6.8	6.3	6.3	5.5	5.1	4.2	3.5	3.8	4.1	4.8	6.1	6.6
	5% WB	MCDBR	11.2	10.5	12.1	11.3	11.4	10.1	8.9	7.9	9.3	9.4	10.4	10.6
		MCWBR	6.5	5.7	5.9	5.3	4.7	3.8	3.4	3.3	3.8	4.5	5.6	6.2
Clear-Sky Solar Irradiance	taub	0.541	0.623	0.659	0.649	0.626	0.625	0.642	0.693	0.647	0.613	0.552	0.495	
	taud	1.691	1.568	1.543	1.594	1.699	1.750	1.756	1.635	1.693	1.691	1.733	1.801	
	Ebn at Noon	613	610	638	678	703	702	687	640	642	612	599	627	
	Edh at Noon	191	240	266	264	240	228	225	250	226	209	182	162	
All-Sky Solar Radiation	RadAvg	2.52	2.92	3.95	4.79	5.12	5.24	4.92	4.26	3.25	2.84	2.51	2.36	
	RadStd	0.27	0.45	0.38	0.53	0.46	0.43	0.71	0.65	0.39	0.48	0.38	0.31	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page