

HUA SHAN, China

WMO: 570460

Lat: 34.4812N

Lon: 110.0767E

Elev: 6768

StdP: 11.44

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 4.4	(c) 8.1	(d) -20.0	(e) 2.4	(f) 19.9	(g) -14.3	(h) 3.3	(i) 20.2	(j) 36.2	(k) 24.4	(l) 32.4	(m) 23.9	(n) 14.3	(o) 290	(p) 0.610

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.5	(c) 74.6	(d) 61.6	(e) 72.8	(f) 61.3	(g) 71.1	(h) 60.3	(i) 66.6	(j) 71.3	(k) 65.1	(l) 69.8	(m) 63.7	(n) 68.3	(o) 5.6	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	119.8	69.8	63.5	113.4	68.3	62.1	107.7	66.9	35.7	71.3	34.3	70.1	33.1	68.4	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 32.1	(b) 27.4	(c) 23.5	(e) -0.6	(f) 78.5	(g) 4.8	(h) 2.4	(i) -4.1	(j) 80.2	(k) -6.9	(l) 81.5	(m) -9.6	(n) 82.9	(o) -13.1	(p) 84.6		
(4) 32.1	(5) 27.4	(6) 23.5	(7) -2.1	(8) 69.5	(9) 4.5	(10) 1.8	(11) -5.4	(12) 70.8	(13) -8.0	(14) 71.8	(15) -10.6	(16) 72.9	(17) -13.9	(18) 74.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.9	22.3	26.8	35.8	46.3	54.2	61.4	65.2	62.9	55.0	45.7	36.1	25.7	
	DBStd	16.32	8.37	8.34	9.21	8.51	6.73	5.44	4.19	4.84	6.06	6.96	8.17	8.01	
	HDD50	3517	858	651	446	165	36	2	0	0	20	167	420	752	
	HDD65	7463	1323	1071	905	560	338	131	51	96	305	598	868	1217	
	CDD50	1647	0	0	7	55	166	344	470	400	169	34	2	0	
	CDD65	119	0	0	0	0	3	24	56	31	5	0	0	0	
	CDH74	80	0	0	0	0	1	24	43	9	3	0	0	0	
	CDH80	3	0	0	0	0	0	1	2	0	0	0	0	0	
Wind	WSAvg	9.8	11.2	10.5	10.6	10.4	9.7	8.2	7.9	7.3	8.1	9.3	11.4	12.5	
Precipitation	PrecAvg	34.4	0.4	0.7	1.8	3.0	3.5	3.3	6.1	5.1	5.2	3.5	1.4	0.4	
	PrecMax	49.7	1.2	1.7	4.6	7.5	8.5	10.1	11.5	10.9	11.8	8.2	2.9	1.4	
	PrecMin	25.9	0.0	0.1	0.0	1.3	0.9	0.8	1.5	1.2	1.6	1.0	0.2	0.0	
	PrecStd	5.7	0.3	0.5	1.0	1.4	1.9	2.2	2.8	2.2	2.8	1.8	0.7	0.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.1	50.9	61.7	68.9	71.8	76.9	77.4	75.2	73.4	64.0	56.1	47.1	
		MCWB	32.4	37.2	43.4	49.9	53.0	57.5	64.0	65.0	58.0	50.0	42.2	32.6	
	2%	DB	40.5	45.3	56.2	65.0	68.6	73.7	74.9	73.0	69.1	59.8	51.9	42.3	
		MCWB	29.3	32.9	41.8	48.4	51.3	58.0	63.0	64.3	57.8	48.4	39.3	30.5	
	5%	DB	37.2	41.6	52.0	61.0	65.8	71.5	73.2	71.2	66.1	57.4	49.0	39.2	
		MCWB	27.4	31.3	38.7	46.4	50.5	57.4	62.5	63.0	55.8	47.6	38.1	29.1	
	10%	DB	34.1	38.1	48.2	58.1	63.5	69.4	71.5	69.5	63.4	55.1	46.5	36.3	
		MCWB	25.8	30.2	37.1	45.0	49.6	56.2	61.7	61.6	54.5	45.7	37.1	27.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.2	38.7	48.1	54.8	58.8	65.2	69.2	68.6	64.1	55.3	45.6	35.2
			MCDB	43.3	45.9	57.7	62.1	64.5	70.9	74.1	72.9	68.8	58.7	51.5	41.0
2%		WB	30.7	35.1	43.3	51.4	56.4	62.7	67.0	66.6	61.1	51.9	43.1	32.5	
		MCDB	38.4	42.0	51.7	59.1	62.6	68.5	72.1	70.8	65.7	56.1	46.7	39.2	
5%		WB	28.1	32.7	40.7	48.9	54.4	60.8	65.5	65.0	58.8	50.0	41.1	30.5	
		MCDB	36.2	39.5	49.5	57.3	61.0	66.8	70.4	69.4	62.7	54.8	46.0	37.3	
10%		WB	26.0	30.7	38.4	46.8	52.5	59.0	64.2	63.6	56.6	47.9	39.2	28.5	
		MCDB	33.2	37.1	46.8	54.9	59.5	65.5	68.9	67.9	60.5	52.9	44.8	35.6	
Mean Daily Temperature Range		5% DB	MDBR	9.7	9.6	10.2	10.6	10.1	9.4	8.5	8.1	8.0	8.6	9.2	9.7
			MCDBR	12.6	12.7	12.4	12.0	11.6	11.1	10.1	9.6	9.8	10.5	10.8	12.1
	MCWBR		7.9	7.9	8.4	8.6	9.1	9.0	8.8	8.5	8.2	7.7	7.5	7.7	
	5% WB	MCDBR	11.1	11.0	11.6	10.9	10.5	9.6	9.0	8.8	8.7	9.4	8.6	11.1	
		MCWBR	7.7	7.9	8.7	8.5	9.2	8.9	7.8	7.8	7.7	7.5	7.0	7.7	
Clear-Sky Solar Irradiance	taub	0.386	0.443	0.459	0.457	0.446	0.479	0.495	0.513	0.470	0.454	0.414	0.365		
	taud	1.992	1.875	1.879	1.938	2.031	1.984	2.000	1.919	1.992	1.945	1.980	2.067		
	Ebn at Noon	248	246	256	264	268	258	253	246	250	240	236	247		
	Edh at Noon	44	56	60	59	55	57	56	60	53	51	44	38		
All-Sky Solar Radiation	RadAvg	807	959	1306	1557	1665	1706	1609	1435	1128	985	817	757		
	RadStd	88	162	133	138	132	162	183	183	122	146	115	102		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+3.33	N/A	+0.81	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	-1.62	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page