

XINZHENG, China

WMO: 570830

Lat: 34.7064N

Lon: 113.6628E

Elev: 364

StdP: 14.50

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	23.2	-8.0	3.6	36.9	-3.1	4.7	37.1	23.2	37.6	19.5	37.1	3.5	270	0.405

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	96.3	74.3	93.6	74.8	91.5	74.7	82.4	89.2	81.0	87.8	79.6	86.2	7.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.7	161.7	87.0	79.1	153.0	85.6	77.7	145.7	84.2	46.9	89.3	45.3	88.1	43.7	86.1	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.4	15.3	12.8	DB	15.5	101.6	3.2	2.5	13.2	103.5	11.3	104.9	9.5	106.3	7.2	108.2
			WB	13.5	85.0	3.0	1.7	11.3	86.2	9.6	87.1	7.9	88.1	5.7	89.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.8	34.0	39.7	50.3	61.5	71.4	79.4	81.8	79.4	71.3	61.5	48.5	37.9
	DBStd	17.66	5.77	6.89	7.69	7.24	5.85	4.97	4.51	4.96	5.57	6.02	7.41	5.76
	HDD50	1379	497	293	91	7	0	0	0	0	0	3	112	376
	HDD65	3778	961	708	458	149	0	0	0	0	12	141	495	840
	CDD50	4967	1	5	101	351	663	882	987	912	638	359	67	1
	CDD65	1889	0	0	3	43	211	432	522	447	200	31	0	0
	CDH74	19339	0	0	44	433	2008	4794	5844	4451	1483	272	10	0
	CDH80	8048	0	0	8	114	743	2275	2634	1764	461	49	0	0
(14) Wind	WSAvg	5.5	5.5	5.8	6.5	6.2	6.1	5.3	4.9	4.9	4.4	4.7	5.3	5.8
(15) Precipitation	PrecAvg	25.0	0.4	0.5	0.9	1.7	2.2	2.4	5.7	4.9	3.3	1.7	1.0	0.4
	PrecMax	41.1	2.1	2.6	3.8	7.6	8.9	9.1	14.5	10.6	10.0	6.1	4.6	2.2
	PrecMin	13.9	0.0	0.0	0.0	0.1	0.0	0.1	1.3	1.3	0.0	0.0	0.0	0.0
	PrecStd	6.1	0.4	0.5	0.8	1.5	1.9	2.0	3.3	2.5	2.5	1.5	1.0	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.9	64.7	79.2	88.4	96.6	99.8	98.9	96.9	93.0	85.5	75.4	61.4
		MCWB	42.1	48.8	56.8	66.3	64.6	70.5	76.7	79.6	72.9	64.1	55.9	44.1
	2%	DB	52.8	59.9	73.3	82.9	91.1	96.3	95.6	93.3	88.1	80.5	69.4	56.1
		MCWB	39.4	45.6	55.9	62.7	65.6	70.8	78.0	78.8	71.6	60.7	53.5	41.6
	5%	DB	48.4	55.7	68.7	79.0	87.4	93.5	93.3	90.5	85.1	76.8	64.8	52.1
		MCWB	36.8	43.2	53.2	61.6	65.7	70.9	78.5	77.9	69.3	60.2	51.5	39.7
	10%	DB	44.7	52.1	64.5	75.1	84.1	91.0	91.1	88.1	82.2	73.2	60.9	48.5
		MCWB	34.8	41.4	50.8	59.6	65.0	70.5	78.3	76.9	68.9	59.1	48.9	38.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.1	52.4	62.7	71.5	74.5	80.6	85.1	84.2	79.8	67.9	59.8	47.4
		MCDB	55.1	61.0	73.1	81.2	83.9	89.6	92.2	92.1	86.8	74.6	68.1	56.5
	2%	WB	40.3	47.9	58.4	67.4	71.8	78.2	83.0	82.1	76.3	65.6	55.7	43.7
		MCDB	50.2	56.0	69.2	77.6	82.0	88.0	90.1	88.3	82.7	74.2	65.3	51.0
	5%	WB	38.0	45.2	55.0	64.6	69.7	76.1	81.6	80.8	73.6	63.6	53.3	41.6
		MCDB	46.3	52.8	66.1	75.2	80.2	86.1	88.7	86.9	80.2	71.2	61.7	49.4
	10%	WB	35.9	42.7	52.1	62.0	67.8	74.3	80.2	79.4	71.2	61.7	51.1	39.5
		MCDB	43.1	50.4	62.2	71.5	78.5	84.4	87.3	85.2	77.6	69.1	58.7	46.9
(35) Mean Daily Temperature Range	5% DB	MDBR	15.9	17.3	18.6	19.6	19.8	19.0	14.7	14.2	16.6	17.9	17.3	15.9
		MCDBR	23.6	24.8	26.4	26.4	26.2	24.4	18.8	17.7	21.9	24.8	25.1	24.1
	5% WB	MCWBR	13.6	13.7	13.2	12.3	9.8	8.1	7.2	7.0	8.4	10.1	12.5	13.2
		MCWBR	20.9	21.9	24.3	22.6	20.3	19.1	15.4	14.9	17.2	18.8	21.6	20.7
(40) Clear-Sky Solar Irradiance	taub		0.579	0.651	0.655	0.663	0.677	0.795	0.778	0.779	0.727	0.712	0.632	0.566
		taud	1.645	1.547	1.563	1.580	1.601	1.434	1.510	1.490	1.544	1.519	1.605	1.682
	Ebn at Noon		182	186	203	212	211	187	189	185	185	169	167	175
		Edh at Noon	63	78	82	85	84	99	91	92	83	79	66	58
(44) All-Sky Solar Radiation	RadAvg		720	880	1265	1512	1656	1609	1437	1356	1144	946	768	692
	RadStd		83	157	123	127	139	118	141	182	144	116	126	101

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+151	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+169	N/A

Nomenclature: See separate page