

JINGHE SHAANXI, China

WMO: 571310

Lat: 34.4458N

Lon: 108.9723E

Elev: 1348

StdP: 13.99

Time Zone: 8.00 (E08)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 20.8	(c) 23.2	(d) -2.9	(e) 4.9	(f) 29.8	(g) 1.6	(h) 6.3	(i) 32.6	(j) 15.9	(k) 33.3	(l) 14.1	(m) 33.4	(n) 4.4	(o) 20	(p) 0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	97.3	73.7	94.8	72.7	92.3	72.2	78.6	91.4	77.3	89.4	75.9	87.4	6.3	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.1	138.6	86.4	73.8	132.2	84.7	72.5	126.8	83.3	43.5	91.1	42.0	89.5	40.6	87.1	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.6	(b) 13.6	(c) 11.9	(e) 17.0	(f) 102.2	(g) 3.6	(h) 1.5	(i) 14.4	(j) 103.4	(k) 12.3	(l) 104.3	(m) 10.2	(n) 105.1	(o) 7.6	(p) 106.3		
(a) 15.6	(b) 13.6	(c) 11.9	(e) 13.9	(f) 80.1	(g) 3.3	(h) 1.5	(i) 11.6	(j) 81.1	(k) 9.7	(l) 82.0	(m) 7.9	(n) 82.8	(o) 5.5	(p) 83.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.6	33.1	40.1	52.2	62.8	70.9	79.3	82.3	79.7	70.1	60.0	47.3	36.8	
	DBStd	17.86	5.76	6.68	7.77	6.96	6.22	5.61	5.51	5.90	5.70	6.00	6.46	5.21	
	HDD50	1412	523	282	66	4	0	0	0	0	0	3	124	410	
	HDD65	3827	988	697	400	119	19	1	0	0	18	178	532	875	
	CDD50	4933	0	5	136	388	646	878	1001	922	603	312	42	0	
	CDD65	1872	0	0	4	53	200	429	536	457	171	22	0	0	
	CDH74	18796	0	0	41	421	1697	4610	6233	4718	969	107	0	0	
	CDH80	8315	0	0	4	89	603	2180	3104	2069	248	18	0	0	
Wind	WSAvg	5.6	4.9	5.5	6.3	6.1	5.8	5.8	6.1	6.1	5.5	4.9	5.0	4.9	
Precipitation	PrecAvg	20.8	0.2	0.4	0.9	1.4	2.2	2.4	3.4	3.3	3.5	2.0	0.9	0.2	
	PrecMax	34.1	0.7	1.1	2.3	4.0	5.6	4.4	8.2	7.7	11.8	5.0	2.6	0.7	
	PrecMin	11.6	0.0	0.0	0.0	0.2	0.1	0.2	0.2	0.4	0.6	0.4	0.0	0.0	
	PrecStd	4.8	0.2	0.3	0.6	0.9	1.4	1.2	1.7	1.8	2.5	1.1	0.7	0.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	64.3	78.4	87.1	94.5	98.9	102.3	98.2	90.7	82.2	69.0	57.6	
		MCWB	38.7	47.6	58.0	61.1	65.1	69.9	76.2	77.3	70.4	63.8	54.0	42.3	
	2%	DB	49.0	58.5	73.6	82.5	89.8	96.4	98.1	95.2	85.9	76.4	63.4	51.8	
		MCWB	36.7	44.3	54.5	60.2	64.5	69.4	75.6	76.4	69.5	60.9	51.7	39.3	
	5%	DB	45.8	54.6	69.3	79.0	86.3	93.8	95.3	92.4	82.6	73.0	59.8	48.5	
		MCWB	35.1	42.7	52.3	59.4	64.7	68.7	74.9	75.7	67.9	59.9	49.9	37.7	
	10%	DB	42.6	51.0	65.2	75.3	83.0	90.8	92.4	89.6	79.5	69.7	56.8	45.7	
		MCWB	33.7	41.0	50.1	58.3	64.0	68.3	74.1	74.7	66.8	58.5	48.8	36.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.2	48.5	60.1	66.0	71.1	75.6	80.8	79.9	74.8	66.2	56.0	43.7
			MCDB	50.5	60.8	73.4	80.0	84.8	87.9	92.4	93.3	84.9	76.0	63.4	52.8
2%		WB	37.8	45.8	56.3	63.8	68.9	73.9	78.9	78.7	71.5	64.1	53.9	40.8	
		MCDB	46.0	55.3	69.9	76.6	81.8	87.7	91.6	91.7	79.5	71.4	59.3	48.8	
5%		WB	36.1	43.8	53.7	61.7	67.4	72.2	77.6	77.5	69.9	62.3	52.0	39.1	
		MCDB	44.2	52.3	66.3	74.0	79.6	85.9	90.5	88.8	77.6	70.2	57.7	46.3	
10%		WB	34.3	41.8	51.4	59.9	66.1	70.8	76.3	76.2	68.5	60.4	50.2	37.6	
		MCDB	41.9	49.6	62.8	71.6	77.6	84.3	88.9	86.7	75.9	67.7	55.6	43.8	
Mean Daily Temperature Range	5% DB	MDBR	13.4	14.5	16.3	17.6	17.6	17.6	15.3	14.0	12.7	13.1	12.8	13.0	
		MCDBR	19.1	21.3	22.6	23.7	23.5	23.5	19.5	17.0	18.2	18.7	18.1	17.9	
		MCWBR	10.7	11.3	9.8	9.5	8.2	6.9	5.6	5.5	6.6	7.4	8.8	9.7	
	5% WB	MCDBR	17.0	18.9	20.0	20.3	18.6	16.8	15.6	15.1	13.5	14.9	14.0	15.4	
		MCWBR	9.9	10.4	9.6	9.4	8.0	6.2	5.6	5.8	6.6	7.2	8.9	8.9	
Clear-Sky Solar Irradiance	taub	0.546	0.626	0.642	0.634	0.616	0.645	0.668	0.702	0.655	0.635	0.579	0.513		
	taud	1.696	1.569	1.570	1.620	1.716	1.700	1.698	1.615	1.671	1.654	1.695	1.775		
	Ebn at Noon	193	193	206	219	225	218	212	201	201	188	182	193		
	Edh at Noon	60	76	82	82	75	76	76	81	73	69	60	53		
All-Sky Solar Radiation	RadAvg	804	947	1292	1537	1646	1710	1635	1427	1111	961	816	754		
	RadStd	87	152	126	148	130	157	205	195	125	147	116	101		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page