

NANYANG, China

WMO: 571780

Lat: 33.1008N

Lon: 112.4869E

Elev: 182

StdP: 99.16

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.5	(c) -3.3	(d) -17.3	(e) 0.8	(f) 2.5	(g) -14.0	(h) 1.1	(i) 2.4	(j) 7.4	(k) 3.9	(l) 6.8	(m) 3.5	(n) 1.5	(o) 40	(p) 0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.0	(c) 35.0	(d) 24.7	(e) 33.8	(f) 24.6	(g) 32.7	(h) 24.4	(i) 27.9	(j) 32.2	(k) 27.2	(l) 31.3	(m) 26.5	(n) 30.5	(o) 2.9	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.8	30.8	26.1	21.9	29.9	25.4	21.0	29.2	90.9	32.2	87.5	31.5	84.4	30.5	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.7	(b) 5.7	(c) 5.0	(e) -7.3	(f) 37.2	(g) 2.0	(h) 1.2	(i) -8.8	(j) 38.0	(k) -9.9	(l) 38.7	(m) -11.0	(n) 39.4	(o) -12.5	(p) 40.2		
(4) 6.7	(5) 5.7	(6) 5.0	(7) -7.3	(8) 37.2	(9) 2.0	(10) 1.2	(11) -8.8	(12) 38.0	(13) -9.9	(14) 38.7	(15) -11.0	(16) 39.4	(17) -12.5	(18) 40.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	2.2	5.3	10.7	16.7	22.0	26.1	27.7	26.8	22.5	17.2	10.2	4.3		
	DBStd	9.43	2.84	3.67	4.04	3.78	3.20	2.77	2.41	2.82	3.09	3.36	3.82	2.77		
	HDD10.0	638	241	136	39	2	0	0	0	0	0	1	43	177		
	HDD18.3	1924	499	364	236	72	7	0	0	1	4	62	245	434		
	CDD10.0	2844	0	4	63	205	372	483	550	522	373	223	48	1		
	CDD18.3	1089	0	0	1	24	120	234	292	264	128	27	0	0		
	CDH23.3	10554	0	0	11	183	997	2386	3227	2709	876	162	3	0		
	CDH26.7	4186	0	0	1	34	349	1034	1377	1090	274	27	0	0		
(14) Wind	WSAvg	2.2	2.1	2.4	2.6	2.5	2.3	2.2	2.1	2.1	2.0	1.8	1.9	2.0		
(15) Precipitation	PrecAvg	762	10	17	33	48	77	105	174	121	83	46	35	11		
	PrecMax	1153	37	57	73	92	245	242	370	242	216	130	101	44		
	PrecMin	546	0	0	1	5	12	23	29	38	7	2	1	0		
	PrecStd	150	11	13	22	26	49	52	83	63	56	37	27	11		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	18.3	24.9	29.7	34.7	36.6	36.1	36.3	34.4	29.7	23.5	15.3		
		MCWB	6.6	10.3	15.6	19.5	19.4	21.8	26.7	26.4	24.0	19.1	14.4	7.9		
	2%	DB	10.9	15.5	21.9	27.4	32.1	34.8	34.7	34.2	31.5	27.1	20.8	12.9		
		MCWB	5.2	8.9	14.0	18.5	19.5	22.5	26.5	26.1	22.7	17.6	13.2	6.8		
	5%	DB	9.1	13.5	19.7	25.5	30.3	33.4	33.6	32.8	29.7	25.2	18.4	11.1		
		MCWB	4.4	7.5	12.8	17.7	19.7	22.5	26.2	25.5	21.6	16.4	12.0	5.9		
	10%	DB	7.4	11.6	17.6	23.4	28.5	31.8	32.4	31.6	28.0	23.2	16.3	9.3		
		MCWB	3.3	6.7	11.6	16.4	19.2	22.2	26.0	25.1	20.8	16.1	11.2	5.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	12.0	17.6	22.2	24.0	26.7	28.9	28.6	26.7	20.7	15.9	9.4		
		MCDB	11.8	16.1	22.7	27.0	28.7	31.7	33.4	33.0	31.9	26.0	19.8	12.7		
	2%	WB	6.1	9.9	15.5	20.2	22.3	25.8	28.1	27.8	25.1	19.2	14.3	8.1		
		MCDB	9.6	13.8	20.3	24.8	27.4	30.6	32.6	31.7	29.2	23.8	18.8	11.3		
	5%	WB	4.9	8.5	13.8	18.7	21.3	25.0	27.5	27.1	23.6	18.3	13.1	7.0		
		MCDB	8.2	12.3	18.4	23.8	27.0	29.6	31.8	30.9	27.1	22.5	17.0	10.1		
	10%	WB	3.7	7.3	12.2	17.3	20.5	24.2	26.8	26.4	22.2	17.4	11.9	5.7		
		MCDB	6.7	11.0	16.7	22.2	26.2	28.7	31.0	30.0	25.8	21.3	15.5	8.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	8.5	8.8	9.3	9.6	8.8	7.0	7.0	7.9	8.5	8.1	7.9		
		MCDBR	11.2	12.1	12.2	12.5	13.0	11.6	8.9	8.8	10.8	12.2	12.0	11.8		
	5% WB	MCWBR	6.9	6.9	6.4	5.9	4.4	3.6	3.1	3.0	3.8	4.6	5.9	6.9		
		MCWBR	10.2	10.5	10.9	11.0	10.1	8.5	7.7	7.3	8.8	9.3	10.0	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.632	0.702	0.702	0.697	0.691	0.769	0.747	0.779	0.736	0.720	0.675	0.615		
	taud		1.547	1.458	1.480	1.525	1.578	1.482	1.555	1.484	1.526	1.500	1.539	1.595		
	Ebn at Noon		544	558	612	648	659	608	618	587	583	538	507	526		
	Edh at Noon		226	273	286	284	272	299	276	293	270	257	227	205		
(44) All-Sky Solar Radiation	RadAvg		2.22	2.61	3.78	4.52	4.79	4.82	4.52	4.23	3.48	2.96	2.38	2.14		
	RadStd		0.30	0.54	0.40	0.41	0.41	0.45	0.59	0.60	0.45	0.44	0.38	0.35		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.22	N/A	-2.45	+0.56	-0.48	-0.64	N/A	N/A	+83	N/A
(47) Regional (6 neighbors)		N/A	N/A	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page