

XIHUA, China

WMO: 571930

Lat: 33.7836N

Lon: 114.5192E

Elev: 174

StdP: 14.60

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	25.0	-0.3	5.4	34.9	5.0	7.2	34.1	13.4	39.8	11.9	39.1	2.6	0	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	95.5	78.1	93.4	77.9	91.3	77.1	83.4	91.2	82.1	89.5	80.8	87.7	4.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.5	164.6	88.6	80.1	157.3	87.3	78.9	150.8	85.6	47.8	91.2	46.3	90.0	44.8	87.9	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.9	10.0	9.0	17.2	99.5	3.0	2.1	15.1	101.0	13.3	102.3	11.6	103.5	9.4	105.0		
			15.2	85.2	2.8	1.2	13.2	86.0	11.6	86.7	10.0	87.4	8.0	88.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.5	35.3	40.7	50.9	61.1	70.8	79.3	82.3	80.2	72.3	62.8	49.7	38.9	
	DBStd	17.34	5.43	6.64	7.36	6.84	5.61	4.88	4.54	4.94	5.55	6.26	7.48	5.60	
	HDD50	1248	457	267	78	6	0	0	0	0	0	2	92	346	
	HDD65	3599	922	682	439	151	14	0	0	0	8	115	459	809	
	CDD50	5070	0	5	106	340	646	878	1002	937	670	400	84	2	
	CDD65	1946	0	0	2	34	195	428	537	473	228	48	1	0	
	CDH74	19221	0	0	21	285	1627	4506	6098	4796	1590	292	6	0	
	CDH80	7867	0	0	2	53	549	2076	2734	1920	483	50	0	0	
Wind	WSAvg	3.8	4.0	4.4	4.9	4.4	3.9	3.4	3.3	3.4	3.2	3.0	3.6	3.9	
Precipitation	PrecAvg	29.3	0.6	0.7	1.3	2.1	2.4	3.0	7.2	4.7	3.5	2.2	1.1	0.5	
	PrecMax	49.7	2.6	2.0	3.2	7.8	8.3	8.0	16.3	11.2	11.9	6.6	4.4	1.6	
	PrecMin	14.2	0.0	0.0	0.0	0.2	0.0	0.2	3.0	0.6	0.4	0.0	0.0	0.0	
	PrecStd	7.2	0.6	0.6	0.8	1.8	1.9	2.1	4.1	2.9	2.6	1.8	1.0	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.3	64.6	76.4	85.5	93.7	98.0	97.7	96.3	92.4	84.9	74.5	60.2	
		MCWB	44.4	51.4	62.5	71.0	68.6	73.0	81.3	82.6	75.9	65.5	58.1	46.6	
	2%	DB	51.8	59.5	71.6	80.8	89.2	95.4	95.4	93.4	88.2	80.6	69.2	54.9	
		MCWB	41.1	47.5	58.2	66.8	69.5	73.2	81.3	81.8	73.7	63.0	55.5	43.5	
	5%	DB	48.1	55.6	67.8	77.1	85.9	93.0	93.4	90.8	85.0	77.1	65.0	51.2	
		MCWB	38.8	45.3	55.5	64.6	68.8	72.6	81.0	80.1	71.8	62.3	53.6	41.9	
	10%	DB	44.4	52.1	63.6	73.6	82.7	90.4	91.2	88.6	82.4	73.5	61.2	47.9	
		MCWB	36.9	43.7	52.9	62.1	68.1	72.4	80.0	78.7	70.2	61.1	51.6	40.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.2	53.9	64.7	73.3	75.7	80.9	85.4	84.6	81.3	69.9	61.2	49.3
			MCDB	53.3	61.4	74.4	83.0	85.3	90.8	92.9	92.4	87.7	76.9	68.8	56.3
2%		WB	42.4	49.4	60.4	69.0	73.3	79.0	83.9	83.1	77.8	66.9	57.8	46.2	
		MCDB	50.5	56.4	69.2	77.2	83.1	88.5	91.9	90.4	84.0	75.1	66.4	51.5	
5%		WB	40.1	47.1	56.9	66.2	71.3	77.3	82.7	81.8	75.0	65.0	55.3	43.7	
		MCDB	46.4	53.8	65.7	75.2	81.0	86.5	90.6	88.6	81.0	72.7	62.6	49.3	
10%		WB	37.9	44.5	54.0	63.6	69.7	75.5	81.5	80.6	72.6	63.2	53.0	41.5	
		MCDB	43.1	50.8	62.1	71.8	79.3	84.6	88.9	86.7	78.9	70.2	59.4	46.5	
Mean Daily Temperature Range	5% DB	MDBR	13.5	14.6	16.1	17.4	17.9	17.7	13.0	12.6	14.9	16.4	15.3	13.5	
		MCDBR	20.5	21.4	22.4	22.8	23.8	22.8	16.3	15.1	19.0	22.5	21.8	20.6	
		MCWBR	12.4	12.5	12.2	12.8	9.4	6.7	6.0	5.9	7.0	8.9	11.2	12.1	
	5% WB	MCDBR	18.2	18.1	20.7	20.5	19.4	17.1	14.7	13.8	15.3	18.0	18.6	17.3	
		MCWBR	11.8	11.7	12.3	12.8	9.6	6.7	6.7	6.4	7.7	8.6	10.5	11.4	
Clear-Sky Solar Irradiance	taub	0.605	0.665	0.670	0.669	0.684	0.789	0.750	0.765	0.719	0.720	0.662	0.599		
	taud	1.600	1.522	1.537	1.566	1.587	1.442	1.549	1.508	1.552	1.503	1.557	1.628		
	Ebn at Noon	178	185	201	211	210	189	195	188	188	169	162	169		
	Edh at Noon	67	81	85	86	85	98	88	90	83	81	70	62		
All-Sky Solar Radiation	RadAvg	706	844	1230	1471	1589	1581	1459	1368	1147	951	761	666		
	RadStd	86	159	116	127	125	132	170	191	168	121	116	106		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	N/A

Nomenclature: See separate page