

DA XIAN, China

WMO: 573280

Lat: 31.2074N

Lon: 107.5067E

Elev: 1129

StdP: 14.11

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.3	36.3	24.6	19.5	41.8	28.4	23.2	41.9	10.3	43.2	8.9	41.9	3.2	40	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	97.9	77.8	95.6	77.5	93.2	77.1	80.7	91.4	79.8	89.9	78.9	88.5	3.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.3	153.2	84.8	77.4	148.4	84.3	76.5	144.0	83.8	45.6	91.6	44.6	90.2	43.6	88.5	96.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.5	8.5	7.4	30.9	101.6	2.1	2.3	29.4	103.3	28.2	104.6	27.0	105.9	25.4	107.6
			29.7	83.0	2.6	3.2	27.9	85.3	26.4	87.2	25.0	89.0	23.1	91.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.5	44.2	48.5	56.4	65.5	71.9	77.5	83.3	83.3	74.9	65.2	56.1	46.6	(6)
(7)		DBStd	14.43	3.62	4.62	6.41	6.48	4.95	4.73	4.40	5.64	6.11	5.48	5.13	3.79	(7)
(8)		HDD50	401	183	77	13	1	0	0	0	0	0	0	9	118	(8)
(9)		HDD65	2366	645	463	277	71	5	0	0	2	63	269	571		(9)
(10)		CDD50	5706	2	34	211	466	680	824	1034	1033	748	471	191	12	(10)
(11)		CDD65	2198	0	0	10	86	220	375	569	568	300	69	1	0	(11)
(12)		CDH74	20958	0	0	74	594	1422	3080	6609	6613	2252	311	3	0	(12)
(13)		CDH80	9292	0	0	13	171	453	1167	3155	3379	878	76	0	0	(13)
(14)	Wind	WSAvg	3.1	2.5	2.8	3.2	3.4	3.3	3.1	3.6	3.2	2.7	2.7	2.5	(14)	
(15)	Precipitation	PrecAvg	47.6	0.6	0.7	1.8	4.0	6.1	6.0	8.2	6.1	7.0	4.2	2.0	0.8	(15)
(16)		PrecMax	61.7	1.7	2.0	4.7	6.8	13.3	15.5	21.3	14.5	13.3	14.4	4.2	2.3	(16)
(17)		PrecMin	33.2	0.0	0.1	0.6	1.6	1.3	0.9	2.0	1.4	1.5	1.0	0.8	0.1	(17)
(18)		PrecStd	8.2	0.4	0.5	0.9	1.3	2.7	3.3	4.5	3.5	3.5	2.6	1.0	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	59.1	67.3	81.7	89.8	92.7	96.2	100.0	101.3	96.9	87.8	72.8	59.7	(19)	
(20)		MCWB	48.7	55.3	64.0	69.3	70.5	77.0	79.1	77.8	77.2	69.9	61.3	51.6	(20)	
(21)		DB	54.3	61.8	75.2	84.9	88.4	92.6	97.1	98.8	92.5	81.2	69.1	56.6	(21)	
(22)		MCWB	47.1	52.5	60.6	67.5	70.1	75.8	78.7	77.4	75.7	67.7	59.7	50.7	(22)	
(23)		DB	51.7	58.5	70.8	80.7	85.0	89.6	94.9	96.3	88.7	77.0	65.8	54.1	(23)	
(24)		MCWB	46.1	50.7	58.4	65.4	69.7	75.1	78.6	77.3	73.8	66.3	59.0	49.2	(24)	
(25)		DB	49.8	55.8	66.6	76.7	81.8	86.8	92.6	93.9	85.1	73.3	63.1	52.2	(25)	
(26)		MCWB	45.5	49.2	56.4	64.3	68.8	74.5	78.1	77.1	72.6	65.0	58.0	48.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	50.6	56.3	66.5	72.2	75.4	80.1	82.2	81.7	79.0	72.7	63.6	54.8	(27)	
(28)		MCDWB	54.7	64.3	78.7	84.9	84.0	89.5	92.8	92.7	92.2	83.8	69.3	57.0	(28)	
(29)		WB	48.5	53.7	61.7	69.5	73.3	78.6	81.0	80.4	77.4	70.0	61.7	52.0	(29)	
(30)		MCDWB	52.4	59.8	71.9	79.2	81.8	87.0	91.3	91.9	88.0	77.1	66.2	54.8	(30)	
(31)		WB	47.2	52.0	59.6	67.6	71.8	77.4	80.1	79.4	76.0	68.0	60.2	50.1	(31)	
(32)		MCDWB	50.8	56.9	68.6	77.0	80.2	85.2	90.0	90.3	84.8	73.2	64.1	53.3	(32)	
(33)		WB	45.9	50.3	57.7	65.5	70.4	76.2	79.4	78.5	74.4	66.4	58.9	48.6	(33)	
(34)		MCDWB	49.2	54.8	65.3	74.3	78.3	83.5	88.6	89.0	82.3	71.6	62.2	51.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	8.7	10.8	13.5	14.6	13.9	12.8	14.1	15.1	12.2	10.3	9.4	8.1	(35)	
(36)		5% DB	13.5	16.9	21.4	22.8	21.3	18.7	18.0	19.2	18.5	17.8	14.6	11.8	(36)	
(37)		MCWBR	7.5	8.8	8.8	8.0	6.7	5.5	4.3	4.2	5.4	6.3	6.8	6.6	(37)	
(38)		5% WB	11.2	14.0	18.7	19.0	15.6	14.5	15.7	16.7	15.6	14.1	12.1	9.2	(38)	
(39)		MCWBR	6.7	7.7	8.0	8.1	6.4	5.3	4.8	5.1	5.6	5.9	6.3	5.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.723	0.759	0.765	0.732	0.672	0.638	0.623	0.645	0.663	0.719	0.752	0.724	(40)	
(41)		taud	1.417	1.379	1.403	1.499	1.653	1.754	1.810	1.742	1.673	1.517	1.441	1.445	(41)	
(42)		Ebn at Noon	156	169	183	200	214	221	223	216	204	175	149	147	(42)	
(43)		Edh at Noon	84	95	99	93	80	72	68	72	75	82	82	79	(43)	
(44)	All-Sky Solar Radiation	RadAvg	505	597	944	1226	1259	1323	1593	1489	1036	744	559	451	(44)	
(45)		RadStd	80	98	95	153	181	167	225	200	142	122	94	75	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.67	+0.99	N/A	+1.01	N/A	N/A	-59	-140	+214	+104
(47)	Regional (5 neighbors)	+0.56	N/A	N/A	+1.33	N/A	N/A	-52	N/A	+158	+65

Nomenclature: See separate page