

FENGJIE, China

WMO: 573480

Lat: 31.0280N

Lon: 109.4783E

Elev: 994

StdP: 14.18

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.6	36.7	19.6	15.3	42.2	23.5	18.4	43.2	14.3	44.0	12.6	44.6	3.9	0	0.337

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.2	99.0	76.9	96.3	76.3	93.5	75.8	80.1	90.5	79.1	89.5	78.1	88.3	3.9	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.1	151.3	83.8	76.5	143.4	83.4	75.5	138.5	83.0	44.8	91.0	43.6	89.5	42.6	88.4	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.0	10.8	9.2	32.4	101.4	3.3	3.2	30.0	103.7	28.1	105.6	26.2	107.4	23.8	109.7		
(5)			29.4	81.9	3.3	2.4	27.0	83.6	25.0	85.0	23.2	86.4	20.8	88.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	45.2	48.9	56.7	65.4	72.0	77.9	83.4	83.5	75.9	66.1	57.2	48.0		
	DBStd	14.37	4.64	5.36	7.17	6.88	5.50	5.45	4.86	5.89	6.25	5.92	5.56	4.48		
	HDD50	359	161	77	20	1	0	0	0	0	0	0	9	91		
	HDD65	2246	615	451	272	77	8	1	0	0	3	56	237	526		
	CDD50	5873	12	46	227	464	681	838	1034	1038	777	501	225	30		
	CDD65	2282	0	0	14	89	223	388	569	573	330	92	4	0		
	CDH74	22199	0	1	100	627	1527	3384	6610	6793	2725	430	2	0		
	CDH80	9883	0	0	20	181	500	1355	3193	3487	1048	99	0	0		
(14) Wind	WSAvg	3.9	3.8	4.1	4.4	4.2	4.1	3.7	3.9	4.1	4.1	3.7	3.7	3.6		
(15) Precipitation	PrecAvg	40.9	0.5	0.9	1.8	3.5	5.7	6.3	6.6	5.0	4.6	3.5	1.8	0.6		
	PrecMax	52.8	1.2	2.9	3.3	6.5	7.7	11.9	11.5	13.7	9.9	7.7	5.3	2.0		
	PrecMin	30.4	0.0	0.0	0.8	1.1	3.0	1.7	2.4	0.4	0.4	0.8	0.1	0.0		
	PrecStd	5.7	0.3	0.7	0.7	1.5	1.5	2.1	2.6	3.0	2.4	1.9	1.1	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.8	69.0	82.9	90.4	93.0	98.9	101.5	102.6	97.2	88.1	73.6	61.9		
		MCWB	48.8	56.0	63.0	67.8	70.3	75.2	78.1	77.1	75.2	70.8	61.5	52.4		
	2%	DB	57.2	63.7	76.1	84.9	89.1	94.3	98.2	99.8	92.8	82.4	70.3	58.6		
		MCWB	47.9	53.2	59.9	65.7	69.8	74.7	78.0	76.6	73.7	67.0	60.1	50.7		
	5%	DB	54.2	60.1	71.9	80.8	85.5	90.5	95.4	97.1	89.2	78.8	67.6	56.5		
		MCWB	47.1	50.8	57.6	64.3	69.2	74.1	77.6	76.3	72.6	66.1	59.0	49.6		
	10%	DB	52.0	57.0	68.1	77.0	82.0	87.3	92.6	94.1	86.1	75.2	65.1	54.5		
		MCWB	45.4	49.0	55.6	63.2	68.1	73.7	77.2	75.8	71.5	64.7	57.8	48.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	58.8	65.6	70.7	76.1	79.8	82.5	81.3	78.1	73.5	64.3	55.0		
		MCDB	56.1	65.6	79.3	84.9	85.3	89.8	90.6	91.9	89.1	83.2	69.2	58.9		
	2%	WB	49.9	54.5	61.3	68.1	73.4	78.0	80.6	79.8	76.5	69.9	62.1	52.2		
		MCDB	55.4	61.0	72.4	79.4	82.8	87.5	90.8	91.0	87.7	77.6	67.2	57.0		
	5%	WB	47.9	52.3	59.1	66.3	71.3	76.6	79.5	78.8	75.2	67.7	60.5	50.6		
		MCDB	53.6	58.5	69.3	76.3	80.1	85.3	89.5	90.2	84.6	74.8	65.6	55.1		
	10%	WB	45.9	50.2	57.2	64.6	69.8	75.3	78.6	77.8	73.7	66.1	59.0	49.1		
		MCDB	51.1	55.8	65.4	74.2	78.2	83.9	88.2	88.8	82.5	72.9	64.0	53.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	10.1	13.2	14.6	13.7	13.3	14.3	15.2	12.8	10.8	9.4	8.2		
		MCDBR	12.8	16.4	21.1	22.8	21.2	20.1	18.9	19.9	18.0	17.2	13.7	11.7		
		MCWBR	6.2	7.6	8.1	7.5	6.7	5.5	4.8	4.4	4.8	5.8	5.9	6.0		
	5% WB	MCDBR	10.6	13.9	18.5	18.6	16.3	15.4	16.1	17.4	14.6	13.8	10.8	10.0		
		MCWBR	5.5	7.1	7.4	7.2	6.3	5.2	5.4	4.9	5.0	5.6	5.2	5.6		
(40) Clear-Sky Solar Irradiance	taub		0.672	0.711	0.740	0.720	0.649	0.641	0.613	0.648	0.645	0.661	0.673	0.638		
	taud		1.490	1.452	1.442	1.519	1.700	1.757	1.843	1.740	1.716	1.614	1.549	1.556		
	Ebn at Noon		168	180	189	202	219	220	226	215	208	189	167	167		
	Edh at Noon		78	89	95	91	77	72	66	72	71	74	73	70		
(44) All-Sky Solar Radiation	RadAvg		572	646	989	1212	1263	1351	1496	1438	1079	842	665	561		
	RadStd		110	120	82	155	202	176	205	152	134	137	108	106		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+2.23	+2.81	N/A	+3.20	+0.97	+0.86	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	+1.08	N/A	N/A	N/A	N/A	+142	N/A

Nomenclature: See separate page