

GAOPING, China

WMO: 574110

Lat: 30.7456N

Lon: 106.1319E

Elev: 1138

StdP: 14.10

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.9	36.8	25.1	19.9	45.4	29.8	24.9	44.8	12.3	41.6	10.0	42.8	2.4	20	0.314

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	97.7	76.7	95.2	76.7	92.7	76.3	80.8	89.7	79.7	88.3	78.8	87.0	4.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.7	155.6	84.8	77.6	149.8	83.9	76.7	145.0	83.2	45.8	90.2	44.5	88.2	43.5	87.1	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.0	7.5	31.4	101.0	2.5	2.9	29.6	103.0	28.1	104.7	26.7	106.3	24.9	108.4		
			30.1	82.3	2.7	1.7	28.2	83.5	26.6	84.5	25.1	85.4	23.1	86.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.6	44.2	48.8	56.8	66.1	72.5	77.3	82.9	83.0	74.5	65.2	56.3	46.8	(6)
(7)		DBStd	14.28	3.71	4.88	6.34	6.60	5.16	4.63	4.64	5.93	6.20	5.27	5.11	3.92	(7)
(8)		HDD50	387	183	73	10	1	0	0	0	0	0	0	8	112	(8)
(9)		HDD65	2320	645	453	264	64	6	0	0	2	61	261	564	(9)	
(10)		CDD50	5727	3	40	223	483	697	818	1021	1024	734	472	199	13	(10)
(11)		CDD65	2182	0	0	11	96	237	368	556	559	286	68	1	0	(11)
(12)		CDH74	20322	0	0	61	606	1563	2942	6366	6518	2032	233	1	0	(12)
(13)		CDH80	8737	0	0	8	166	483	1027	2936	3286	783	48	0	0	(13)
(14)	Wind	WSAvg	2.9	2.4	2.6	3.1	3.3	3.4	3.0	3.1	3.2	3.0	2.6	2.4	2.3	(14)
(15)	Precipitation	PrecAvg	40.4	0.7	0.7	1.2	2.9	5.2	5.2	6.9	5.3	6.5	3.6	1.5	0.7	(15)
(16)		PrecMax	56.4	1.8	2.2	2.4	5.3	9.6	11.6	18.7	10.6	13.8	9.5	3.3	2.6	(16)
(17)		PrecMin	26.9	0.0	0.2	0.2	0.8	2.2	1.8	2.8	0.5	1.3	0.9	0.4	0.1	(17)
(18)		PrecStd	6.7	0.4	0.5	0.6	1.1	2.1	2.4	3.8	2.9	3.3	2.0	0.7	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.5	66.9	80.5	89.7	92.4	94.6	99.5	101.5	98.6	85.6	72.0	58.9	(19)
(20)		MCWB	48.7	54.6	63.8	68.3	70.2	74.4	77.6	76.4	75.1	68.8	61.4	51.1	(20)	
(21)		2%	DB	54.3	62.1	74.8	84.7	88.6	91.6	96.6	98.6	92.7	80.0	68.7	55.9	(21)
(22)		MCWB	47.2	52.3	59.9	66.2	69.3	74.3	77.8	76.5	74.6	67.7	59.9	50.7	(22)	
(23)		5%	DB	51.8	58.9	70.8	80.7	85.4	88.8	94.4	96.2	87.9	75.8	65.9	54.0	(23)
(24)		MCWB	46.5	51.4	58.4	65.0	69.2	74.4	77.8	76.4	73.5	66.6	59.4	49.3	(24)	
(25)		10%	DB	49.6	56.3	67.0	77.0	82.2	86.0	92.0	93.4	84.2	72.5	63.2	52.2	(25)
(26)		MCWB	45.3	50.1	57.0	64.2	68.5	74.1	77.6	76.5	72.7	65.6	58.7	48.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.9	56.1	66.3	72.0	75.0	80.5	82.7	81.7	79.6	72.0	63.8	54.7	(27)
(28)		MCDWB	54.5	62.4	75.6	83.3	83.5	86.4	91.4	91.9	89.5	78.7	68.3	56.4	(28)	
(29)		2%	WB	48.7	54.2	62.1	69.2	73.2	78.2	81.2	80.3	77.7	69.8	62.0	52.2	(29)
(30)		MCDWB	52.4	59.2	70.4	78.4	82.0	85.2	90.0	89.6	85.7	75.9	65.7	54.3	(30)	
(31)		5%	WB	47.3	52.6	60.0	67.4	71.8	77.0	80.2	79.2	75.8	68.2	60.7	50.3	(31)
(32)		MCDWB	50.4	57.4	68.0	75.6	79.8	83.8	88.7	88.3	83.4	73.2	64.0	52.6	(32)	
(33)		10%	WB	46.1	51.0	58.0	65.7	70.4	75.8	79.3	78.3	74.4	66.8	59.4	49.2	(33)
(34)		MCDWB	49.0	55.4	65.3	74.2	78.1	82.3	87.3	87.3	81.9	71.2	62.4	51.5	(34)	
(35)	Mean Daily Temperature Range		MDBR	7.9	9.5	11.9	13.4	13.3	11.7	12.7	13.7	10.7	8.8	8.1	7.0	(35)
(36)		5% DB	MCDBR	13.0	15.0	19.0	20.1	19.7	17.3	16.5	18.2	17.5	15.4	13.2	10.5	(36)
(37)			MCWBR	6.8	6.9	7.2	6.2	5.7	5.1	4.1	4.1	4.7	5.4	6.1	5.7	(37)
(38)			MCDBR	10.2	12.3	16.3	16.1	14.6	12.6	14.2	15.1	13.8	12.1	9.6	7.2	(38)
(39)		5% WB	MCWBR	6.1	6.2	7.1	6.4	5.8	5.0	4.8	4.8	4.8	5.1	5.4	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.763	0.807	0.812	0.781	0.722	0.692	0.678	0.710	0.734	0.813	0.828	0.797	(40)	
(41)		taud	1.361	1.313	1.338	1.422	1.559	1.638	1.682	1.605	1.538	1.382	1.348	1.362	(41)	
(42)		Ebn at Noon	148	160	174	190	204	209	212	202	188	156	135	133	(42)	
(43)		Edh at Noon	90	102	106	101	88	81	77	83	86	94	90	86	(43)	
(44)	All-Sky Solar Radiation	RadAvg	520	649	960	1243	1304	1279	1549	1434	1004	714	556	462	(44)	
(45)		RadStd	73	108	111	161	173	176	223	218	152	121	73	65	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-1.33	N/A	-0.72	N/A	-43	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	-1.64	N/A	-0.43	-0.52	N/A	N/A	+137	N/A

Nomenclature: See separate page