

LIANGPING, China

WMO: 574260

Lat: 30.6805N

Lon: 107.7921E

Elev: 455

StdP: 95.98

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.3	1.5	-2.8	3.2	4.0	-1.4	3.6	4.0	5.1	6.0	4.3	6.3	0.8	40	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	36.0	24.6	34.7	24.6	33.4	24.5	26.7	32.3	26.1	31.5	25.6	30.6	1.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	21.5	29.4	24.7	20.9	28.7	24.2	20.3	28.1	87.1	32.3	84.4	31.4	82.0	30.8	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4.7	4.0	3.4	DB	-2.1	37.8	1.2	1.3	-2.9	38.7	-3.7	39.5	-4.4	40.2	-5.3	41.1
			WB	-2.3	27.6	1.3	0.7	-3.3	28.1	-4.0	28.5	-4.8	28.9	-5.7	29.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	6.2	8.5	12.9	18.0	21.6	24.4	27.9	27.7	23.5	18.0	13.1	7.6	(6)
(7)		DBStd	7.97	2.08	2.68	3.58	3.63	2.80	2.69	2.32	2.93	3.39	2.99	2.92	2.20	(7)
(8)		HDD10.0	274	119	56	11	1	0	0	0	0	0	0	7	80	(8)
(9)		HDD18.3	1414	377	275	173	49	5	1	0	0	2	42	157	334	(9)
(10)		CDD10.0	3008	1	14	101	239	359	433	553	549	404	249	101	4	(10)
(11)		CDD18.3	1107	0	0	4	38	106	184	295	291	156	33	1	0	(11)
(12)		CDH23.3	10220	0	1	32	271	674	1412	3273	3208	1184	163	2	0	(12)
(13)		CDH26.7	4352	0	0	5	73	204	504	1494	1568	462	41	0	0	(13)
(14)	Wind	WSAvg	1.5	1.2	1.4	1.6	1.6	1.5	1.7	1.6	1.6	1.4	1.2	1.2	(14)	
(15)	Precipitation	PrecAvg	1301	16	20	53	112	168	188	202	154	197	113	55	24	(15)
(16)		PrecMax	1878	39	52	158	210	344	375	693	386	460	199	109	53	(16)
(17)		PrecMin	869	2	1	13	57	88	34	32	19	39	47	20	3	(17)
(18)		PrecStd	226	9	13	34	40	56	73	126	97	107	39	24	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.0	20.2	26.9	31.5	33.2	34.9	37.1	37.9	35.8	30.9	22.8	15.3	(19)
(20)			MCWB	9.5	13.4	18.0	20.5	21.2	24.3	25.8	24.6	23.7	20.8	16.1	11.1	(20)
(21)		2%	DB	12.2	16.3	23.5	28.9	30.9	33.0	35.6	36.3	33.5	27.3	20.5	13.5	(21)
(22)			MCWB	8.5	11.8	15.9	19.3	21.2	24.1	25.2	24.5	23.7	19.5	15.5	10.4	(22)
(23)		5%	DB	10.6	14.4	21.0	26.4	29.0	31.3	34.4	35.1	31.4	24.8	18.8	12.1	(23)
(24)			MCWB	7.9	10.5	14.7	18.4	21.0	23.8	25.2	24.5	22.7	19.0	14.9	9.7	(24)
(25)		10%	DB	9.4	12.7	18.8	24.3	27.0	29.7	33.1	33.7	29.4	22.7	17.3	10.9	(25)
(26)			MCWB	7.3	9.6	13.7	17.8	20.4	23.6	25.2	24.4	22.2	18.2	14.4	8.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	14.3	19.3	22.0	24.2	26.6	27.6	27.1	25.7	22.2	17.4	12.5	(27)
(28)			MCDWB	12.4	18.2	25.4	28.5	28.9	30.8	33.6	33.5	32.2	28.1	20.6	13.8	(28)
(29)		2%	WB	9.3	12.4	16.6	20.5	22.9	25.6	26.9	26.3	24.7	20.8	16.4	11.2	(29)
(30)			MCDWB	11.4	15.4	21.8	26.3	27.4	30.3	32.7	32.5	30.8	24.8	19.0	12.7	(30)
(31)		5%	WB	8.3	11.2	15.2	19.4	21.9	24.9	26.4	25.7	24.0	19.8	15.6	10.0	(31)
(32)			MCDWB	10.1	13.6	19.6	24.2	26.5	29.1	31.7	31.6	29.0	22.9	17.8	11.5	(32)
(33)		10%	WB	7.5	10.1	14.2	18.4	21.1	24.2	25.9	25.2	23.2	18.9	14.8	9.1	(33)
(34)			MCDWB	9.1	12.2	18.0	23.0	25.5	28.0	30.8	30.7	27.5	21.8	16.8	10.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.9	5.9	7.3	7.8	7.5	7.2	8.1	8.7	7.1	5.8	5.4	4.8	(35)
(36)			MCDBR	8.5	9.8	12.0	12.9	12.2	11.0	10.6	11.4	10.7	10.6	8.5	7.4	(36)
(37)			MCWBR	5.0	5.4	5.2	4.7	4.0	3.6	2.8	2.6	2.9	3.9	4.1	4.4	(37)
(38)		5% WB	MCDWB	7.1	7.9	10.4	10.3	9.2	8.4	8.9	9.6	9.0	8.2	7.0	5.8	(38)
(39)			MCWBR	4.5	4.7	4.9	4.3	3.9	3.5	3.1	3.0	3.0	3.5	3.7	3.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.723	0.750	0.763	0.734	0.664	0.630	0.605	0.631	0.650	0.717	0.753	0.731	(40)	
(41)		taud	1.410	1.385	1.403	1.495	1.664	1.768	1.848	1.766	1.693	1.512	1.433	1.428	(41)	
(42)		Ebn at Noon	496	541	582	629	681	702	718	692	654	557	473	462	(42)	
(43)		Edh at Noon	270	300	314	295	251	225	207	222	231	260	261	254	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.55	1.87	2.93	3.74	3.81	4.03	5.01	4.67	3.35	2.33	1.77	1.40	(44)	
(45)		RadStd	0.25	0.29	0.26	0.48	0.61	0.56	0.64	0.60	0.46	0.38	0.29	0.23	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		N/A	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		+0.29	N/A	N/A	+0.73	N/A	N/A	N/A	N/A	+89	+41	

Nomenclature: See separate page