

JIANGLING, China

WMO: 574760

Lat: 30.3503N

Lon: 112.1480E

Elev: 33

StdP: 100.93

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.9	-0.7	-9.3	1.7	4.1	-7.0	2.1	3.3	7.1	2.8	6.3	3.4	2.0	20	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	35.2	27.8	34.2	27.3	33.2	26.7	28.7	33.4	28.2	32.7	27.7	32.0	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.6	23.6	31.6	27.1	22.9	31.2	26.5	22.1	30.8	94.0	33.5	91.5	32.7	88.9	32.2	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.5	5.7	5.0	-3.6	36.7	1.3	1.0	-4.5	37.4	-5.3	38.0	-6.1	38.6	-7.1	39.4		
			(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-4.5	29.6	1.2	0.5	-5.3	29.9	-6.0	30.3	-6.7	30.6	-7.6	31.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	4.7	7.2	12.1	17.7	22.6	26.1	28.8	28.1	24.2	18.8	12.7	7.0
	DBStd	8.90	3.11	3.76	4.06	3.79	3.06	2.65	2.51	2.92	3.24	3.34	3.73	2.91
	HDD10.0	401	167	92	24	1	0	0	0	0	0	0	17	99
	HDD18.3	1551	424	313	196	53	4	0	0	2	36	172	352	
	CDD10.0	3156	2	13	89	233	392	482	581	563	426	272	97	7
	CDD18.3	1264	0	0	3	36	137	232	323	304	177	49	2	0
	CDH23.3	12582	0	1	21	218	981	2203	3959	3540	1413	236	10	0
	CDH26.7	5207	0	0	2	42	306	804	1882	1623	503	43	1	0
Wind	WSAvg	2.1	2.0	2.1	2.3	2.3	2.2	2.1	2.4	2.3	2.2	1.9	1.9	1.9
Precipitation	PrecAvg	1083	24	42	77	110	142	153	142	127	96	86	59	25
	PrecMax	1552	54	135	163	280	296	374	350	390	461	260	152	67
	PrecMin	642	2	0	20	19	22	19	4	3	4	0	1	0
	PrecStd	250	15	28	40	54	64	79	92	95	83	58	39	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	20.3	26.1	30.0	33.4	34.7	36.6	36.4	34.7	30.4	24.9	17.7
		MCWB	9.9	14.3	19.6	22.5	23.1	26.3	28.3	28.0	26.3	21.3	16.7	11.3
	2%	DB	13.0	17.0	22.6	27.9	31.5	33.5	35.4	35.1	32.8	27.7	22.1	15.1
		MCWB	8.4	11.6	16.4	21.1	22.6	25.7	28.2	27.9	25.2	19.7	15.6	9.6
	5%	DB	11.2	14.7	20.5	25.8	29.9	32.2	34.4	34.1	31.2	26.0	20.0	13.4
		MCWB	7.2	10.0	15.1	19.8	22.1	25.3	27.9	27.5	24.2	18.4	14.5	8.9
	10%	DB	9.5	12.7	18.4	24.0	28.2	30.8	33.3	32.9	29.6	24.2	18.1	11.7
		MCWB	6.3	9.0	14.0	18.8	21.4	25.0	27.5	26.9	23.2	18.2	13.9	8.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	15.4	20.1	23.9	25.8	28.1	29.6	29.3	27.7	23.2	18.2	12.3
		MCDB	14.3	19.5	24.1	28.1	30.8	32.6	34.3	34.0	32.5	26.8	22.5	15.3
	2%	WB	9.0	12.3	17.6	22.3	24.6	27.3	28.9	28.7	26.6	21.2	16.7	10.9
		MCDB	12.1	15.5	21.0	26.1	28.6	31.7	33.7	33.3	31.1	25.3	19.9	14.0
	5%	WB	7.7	10.8	16.1	20.8	23.6	26.6	28.4	28.2	25.6	20.2	15.7	9.6
		MCDB	10.5	13.7	19.5	24.4	27.3	30.5	33.0	32.5	29.8	24.1	18.9	12.8
	10%	WB	6.6	9.6	14.5	19.4	22.6	25.8	27.9	27.6	24.5	19.2	14.5	8.4
		MCDB	9.0	12.3	17.7	23.3	26.4	29.1	32.3	31.8	28.2	22.8	17.6	11.1
Mean Daily Temperature Range	5% DB	MDBR	5.9	6.4	7.1	7.5	7.6	6.5	6.3	6.5	7.0	7.1	6.7	6.4
		MCDBR	9.6	10.7	10.7	10.6	10.6	8.5	7.7	7.9	9.0	10.2	9.9	10.2
		MCWBR	5.6	6.0	5.6	4.9	3.6	2.8	2.6	2.6	3.0	3.3	4.4	5.5
	5% WB	MCDBR	8.7	9.0	9.5	9.4	8.1	7.1	7.4	7.4	7.9	8.4	8.4	9.3
		MCWBR	5.5	5.5	5.6	5.1	3.8	3.1	2.9	2.9	3.5	3.5	4.3	5.4
Clear-Sky Solar Irradiance	taub	0.685	0.738	0.751	0.743	0.714	0.723	0.659	0.706	0.742	0.743	0.715	0.674	
	taud	1.484	1.422	1.429	1.486	1.580	1.587	1.738	1.621	1.529	1.479	1.497	1.522	
	Ebn at Noon	528	552	591	624	648	640	680	641	591	541	503	507	
	Edh at Noon	251	290	306	298	273	270	231	257	273	270	246	231	
All-Sky Solar Radiation	RadAvg	1.91	2.23	3.24	3.88	4.19	4.34	4.98	4.59	3.68	2.91	2.33	1.94	
	RadStd	0.33	0.54	0.21	0.44	0.48	0.53	0.53	0.46	0.40	0.41	0.33	0.36	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page