

XIUSHUI, China

WMO: 575980

Lat: 29.0301N

Lon: 114.5751E

Elev: 482

StdP: 14.44

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.5	29.9	14.5	11.7	42.7	19.7	15.1	41.6	10.7	43.9	9.4	43.5	1.3	140	0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	97.5	79.0	95.5	78.6	93.4	78.1	81.9	91.1	80.9	89.8	80.0	88.5	4.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	158.5	85.4	78.9	152.7	84.4	77.9	147.7	83.5	46.4	91.5	45.1	90.0	44.1	88.7	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.5	8.9	7.5	23.4	100.9	2.9	2.1	21.3	102.4	19.6	103.6	18.0	104.8	15.9	106.3		
			22.8	83.7	3.0	1.4	20.7	84.7	19.0	85.5	17.3	86.3	15.1	87.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.2	41.8	46.1	53.9	64.4	72.6	78.1	83.8	83.1	76.7	66.9	56.1	45.7
	DBStd	15.60	5.75	7.47	7.60	6.75	4.95	4.63	3.98	4.10	5.80	5.57	6.53	5.42
	HDD50	634	263	154	44	2	0	0	0	0	0	0	18	153
	HDD65	2614	719	530	352	90	5	0	0	0	1	43	276	598
	CDD50	5815	9	44	166	435	699	843	1048	1026	800	525	200	20
	CDD65	2322	0	1	9	73	239	393	583	561	352	103	8	0
	CDH74	22467	0	10	109	604	1785	3376	6805	6029	3013	672	64	0
	CDH80	9770	0	0	22	163	660	1367	3337	2793	1244	176	8	0
(14) Wind	WSAvg	2.6	2.4	2.7	2.8	2.8	2.6	2.5	2.9	2.9	2.8	2.5	2.4	2.4
(15) Precipitation	PrecAvg	60.6	2.2	3.6	5.8	8.3	9.3	10.5	6.0	4.0	3.3	3.0	2.8	1.7
	PrecMax	86.7	5.9	7.0	12.1	18.1	21.2	20.0	20.4	9.1	8.1	7.2	6.9	5.3
	PrecMin	42.8	0.0	0.5	2.1	3.1	2.7	2.6	0.8	0.8	0.6	0.0	0.0	0.0
	PrecStd	10.7	1.2	1.9	2.3	3.9	4.1	4.0	4.2	2.0	2.1	1.9	1.9	1.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.9	74.5	82.8	88.9	93.7	96.0	100.4	100.5	97.6	89.3	80.2	66.9
		MCWB	53.9	60.0	65.6	68.6	72.7	78.2	79.4	78.5	77.6	70.6	64.0	53.4
	2%	DB	59.2	67.8	76.4	84.6	90.3	93.3	97.8	97.4	94.1	84.7	75.3	62.4
		MCWB	49.6	55.8	61.6	66.8	71.2	77.4	79.3	79.4	76.7	68.7	61.1	50.7
	5%	DB	55.1	62.5	71.5	81.0	87.2	90.8	95.8	95.2	90.8	81.0	71.1	58.9
		MCWB	47.2	52.9	58.5	66.2	71.1	76.7	79.0	79.4	75.6	66.0	59.6	51.0
	10%	DB	51.2	57.5	66.4	77.0	83.4	87.8	93.7	92.4	87.3	77.6	67.0	55.4
		MCWB	45.5	50.6	57.1	65.0	70.5	76.1	78.7	78.9	74.2	65.1	58.3	48.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.5	62.3	69.3	75.2	78.7	81.8	83.6	83.8	81.1	75.7	68.6	58.8
		MCDB	60.7	71.1	77.7	82.6	84.2	89.7	92.7	92.3	90.3	83.0	74.8	62.3
	2%	WB	51.9	58.2	64.8	71.9	76.6	80.2	82.0	82.1	79.1	72.4	65.2	54.8
		MCDB	55.6	65.1	71.6	78.0	82.3	87.8	91.4	91.3	88.6	78.6	70.5	59.3
	5%	WB	48.8	54.8	61.8	69.9	74.8	79.1	81.0	80.9	78.0	70.2	62.8	51.6
		MCDB	53.4	59.5	67.3	75.8	80.6	86.3	90.1	89.9	86.3	75.7	66.9	56.7
	10%	WB	46.3	51.9	59.0	67.7	73.1	77.9	80.1	79.8	76.7	68.2	60.2	49.2
		MCDB	50.2	56.6	64.4	73.2	79.5	84.5	88.8	88.4	83.7	74.7	65.0	53.7
(35) Mean Daily Temperature Range	5% DB	MDBR	12.6	13.7	15.8	17.2	16.8	14.6	16.1	16.1	17.0	17.3	16.9	15.6
		MCDBR	22.9	24.7	27.1	26.6	25.7	20.7	21.1	20.9	22.3	24.9	25.7	24.5
		MCWBR	12.9	12.8	12.2	10.7	9.1	6.7	5.2	5.5	6.6	8.8	11.8	13.2
	5% WB	MCDBR	17.9	19.1	20.5	18.6	16.3	15.9	18.1	18.1	17.4	16.9	16.8	18.5
		MCWBR	11.0	11.2	10.9	10.1	7.6	6.6	6.2	6.1	6.0	7.7	9.1	11.0
(40) Clear-Sky Solar Irradiance	taub		0.683	0.732	0.783	0.771	0.708	0.701	0.639	0.694	0.714	0.720	0.661	0.641
	taud		1.492	1.447	1.399	1.459	1.601	1.641	1.786	1.649	1.584	1.510	1.577	1.575
	Ebn at Noon		172	179	183	193	207	208	220	207	195	179	176	174
	Edh at Noon		80	91	101	98	85	81	70	80	82	84	73	71
(44) All-Sky Solar Radiation	RadAvg		595	685	918	1135	1261	1271	1611	1426	1227	1001	785	665
	RadStd		121	192	86	131	166	152	156	136	130	142	128	142

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	+0.56	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	+167	N/A

Nomenclature: See separate page