

YUANLING, China

WMO: 576550

Lat: 28.4634N

Lon: 110.4032E

Elev: 469

StdP: 14.45

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.7	32.7	15.6	12.3	40.8	19.6	15.0	40.8	12.0	42.7	10.4	42.3	3.4	40	0.331

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	96.6	77.8	94.5	77.9	92.4	77.5	81.0	89.8	80.1	88.8	79.3	87.8	5.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	152.9	85.0	78.0	148.0	84.1	77.2	143.9	83.4	45.3	90.1	44.3	89.0	43.4	88.4	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	11.0	9.5	8.1	28.2	100.0	2.5	1.8	26.4	101.3	25.0	102.4	23.5	103.4	21.7	104.7	
(5)				26.4	82.7	2.2	1.3	24.8	83.6	23.5	84.4	22.2	85.1	20.6	86.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.1	42.5	46.3	54.1	63.9	71.6	77.6	83.3	83.0	76.0	66.2	56.4	46.7	(6)
(7)		DBStd	15.19	5.93	6.96	7.29	6.82	5.28	4.76	4.26	4.81	6.04	5.97	6.42	5.13	(7)
(8)		HDD50	567	240	141	40	2	0	0	0	0	0	19	125		(8)
(9)		HDD65	2564	697	524	344	99	8	0	0	3	57	265	567		(9)
(10)		CDD50	5701	8	38	168	419	670	829	1032	1022	781	502	209	23	(10)
(11)		CDD65	2225	0	1	7	67	214	379	567	557	333	94	6	0	(11)
(12)		CDH74	20943	0	8	68	461	1336	3132	6490	6277	2689	460	22	0	(12)
(13)		CDH80	8817	0	1	16	122	440	1170	3024	2896	1041	106	1	0	(13)
(14)	Wind	WSAvg	3.4	3.5	3.6	3.4	3.4	3.1	3.0	3.3	3.5	3.3	3.3	3.4		(14)
(15)	Precipitation	PrecAvg	56.0	1.5	2.2	3.8	7.5	8.6	9.9	6.5	4.4	3.3	4.0	2.8	1.5	(15)
(16)		PrecMax	78.9	3.7	4.1	9.8	15.0	18.3	19.8	17.1	14.5	8.4	9.4	6.8	5.1	(16)
(17)		PrecMin	41.9	0.1	0.1	1.5	1.5	4.4	2.4	1.3	0.5	0.2	0.0	0.2	0.0	(17)
(18)		PrecStd	8.8	0.8	1.2	2.0	3.3	3.3	4.3	4.0	3.7	2.4	2.3	1.7	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.8	72.8	81.2	88.2	92.1	95.2	99.2	99.8	96.3	87.7	77.1	65.0	(19)
(20)			MCWB	50.7	58.6	65.6	71.0	73.5	77.8	77.9	77.1	75.6	69.3	62.8	52.0	(20)
(21)		2%	DB	58.0	65.2	74.3	83.7	88.4	92.2	96.6	96.9	92.6	82.8	72.8	61.0	(21)
(22)			MCWB	47.7	53.5	60.3	68.2	72.1	77.1	78.2	77.7	75.3	67.1	60.5	50.5	(22)
(23)		5%	DB	54.2	60.1	69.8	79.4	85.0	89.6	94.5	94.6	89.4	79.1	69.2	57.5	(23)
(24)			MCWB	46.4	51.0	58.4	66.6	71.4	76.5	78.4	78.2	74.8	65.8	58.9	49.0	(24)
(25)		10%	DB	51.3	56.3	65.1	75.2	81.4	86.7	92.4	92.1	86.2	75.6	65.6	54.4	(25)
(26)			MCWB	45.0	49.2	56.5	65.0	70.6	75.8	78.4	77.7	72.9	65.0	57.6	47.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.0	60.9	68.9	74.4	78.0	80.7	82.4	82.3	79.6	74.5	65.9	55.4	(27)
(28)			MCDWB	58.1	72.1	79.1	84.7	87.3	88.9	90.9	91.4	88.3	82.0	72.0	61.0	(28)
(29)		2%	WB	49.8	55.3	63.3	71.2	75.8	79.2	81.2	81.0	78.3	70.6	63.0	52.5	(29)
(30)			MCDWB	55.3	62.1	70.9	79.8	83.7	87.5	90.0	90.0	87.4	77.2	69.5	58.1	(30)
(31)		5%	WB	47.6	52.5	60.2	68.5	73.8	78.2	80.3	80.1	77.1	68.3	60.8	50.4	(31)
(32)			MCDWB	52.9	58.1	66.7	75.7	80.4	86.1	89.1	88.8	85.3	75.2	66.6	55.8	(32)
(33)		10%	WB	45.4	50.0	57.5	66.2	72.0	77.2	79.5	79.2	75.6	66.7	58.6	48.3	(33)
(34)			MCDWB	50.6	55.8	63.5	73.1	78.5	84.3	88.1	87.6	83.5	73.3	63.9	53.5	(34)
(35)	Mean Daily Temperature Range	MDBR	9.4	10.9	13.0	14.4	14.0	12.7	14.2	14.1	13.6	11.8	11.6	10.3	(35)	
(36)		5% DB	MCDBR	17.9	21.5	24.2	24.1	22.4	18.8	18.6	18.4	19.2	19.4	18.8	18.6	(36)
(37)			MCWBR	9.3	10.7	10.8	9.4	7.8	5.7	4.0	3.9	5.0	6.2	7.7	9.1	(37)
(38)		5% WB	MCDBR	15.2	17.9	19.3	19.5	17.0	14.9	16.2	15.5	16.2	14.5	14.9	15.8	(38)
(39)			MCWBR	8.6	10.0	10.6	9.5	7.3	5.5	4.8	4.7	5.1	6.2	7.4	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.719	0.758	0.801	0.775	0.688	0.679	0.601	0.683	0.721	0.767	0.726	0.707	(40)	
(41)		taud	1.436	1.404	1.376	1.458	1.644	1.686	1.883	1.674	1.575	1.443	1.482	1.468	(41)	
(42)		Ebn at Noon	165	174	180	193	212	213	229	209	194	170	162	159	(42)	
(43)		Edh at Noon	86	95	103	98	82	78	63	78	83	90	81	80	(43)	
(44)	All-Sky Solar Radiation	RadAvg	506	597	835	1020	1132	1206	1544	1405	1129	827	685	538	(44)	
(45)		RadStd	108	160	90	151	205	177	154	133	134	139	126	115	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-0.81	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+0.83	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page